

Mt Robson Visitors Centre ▼

Information

Date of Audit: 2016-09-12

Park Name: Atnarko Camp Ground

Key Features: Camping,Picnic_Site

Location: Central Coast, Bella Coola, Cariboo Chilcotin Coast - Provincial : Campground (Discovery Coast Circle Route)

Description: Located in Tweedsmuir Provincial Park, this is a 15 site campground on the bank of the Atnarko River with a small day use picnic area

Parking

Access Routes

From: : Road at trash receptacle (see picture)

To: : Accessible outhouse

2. What is the condition of the surface along this route? : Good

Comments/Description : 23.5 metres from edge of road to accessible outhouse

4. What is the type of surface? : Gravel

Clear Width

5. What is the typical route width (mm)? : between_1525_-_1220

Comments/Description : 1300 mm typical width

6. What is the narrowest route width (mm)? : between_1220_-915 (Rating: 1)

Comments/Description : 1200 mm minimum width

Obstacles

7. If the route is concrete, asphalt or boardwalk, are there any obstacles that exceed 13mm from the surface? : N_A (Rating: 0)

8. If yes, are the obstacles at least 1220mm apart? : N_A (Rating: 0)

9. If the route is anything other than concrete, asphalt or boardwalk, are there any obstacles that exceed 25mm from the surface? : No (Rating: 0)

10. If yes, are the obstacles at least 1220mm apart? : N_A (Rating: 0)

Openings

11. Are there any gaps or grates present that have an opening greater than 13mm? : No (Rating: 0)

12. If gaps/grates are present, do they run perpendicular to the path of travel? : N_A (Rating: 0)

Running Slope

13. What is the typical running slope on the route? : Moderate_2_-_3 (Rating: 1)

Comments/Description : typical 1.9 degrees

14. What is the maximum running slope on the route? : Very_steep_above_5 (Rating: 0)

Comments/Description : 6.2 degrees for 2 metres near outhouse

Cross Slope

15. What is the typical cross slope on the route? : Flat_Gentle_1_or_less

Comments/Description : 1.1 degrees typical

16. What is the maximum cross slope on the route? : Moderate_2_-_3 (Rating: 1)

Comments/Description : 2.2 degrees max

Resting Intervals

17. Are there resting intervals at the top and bottom of a route where the grade exceeds 3°? : No (Rating: 0)

18. If the running slope is greater than 3°, are there resting intervals in the middle of the route when the length exceeds 9.1m? : N_A (Rating: 0)

Benches

21. Are there any benches along the route? : No (Rating: 0)

22. If yes, are the benches located approximately every 61m? : N_A (Rating: 0)

23. Is the bench seat height between 485mm - 510mm? : N_A (Rating: 0)

Ramps

24. Is there is a ramp? : No (Rating: 0)

25. Is the ramp at least 915mm wide?

Note: If there are handrails, measure between the handrails. : N_A (Rating: 0)

26. Is the surface stable, firm and slip resistant? : N_A (Rating: 0)

27. For each section of the ramp, is the running slope no greater than 5°?

Note: Rises no greater than 76mm with a slope no steeper than 7° and rises no greater than 150mm with a slope no steeper than 6° are permitted when due to space limitations. : N_A (Rating: 0)

28. Is there a level landing that is at least 1525mm long and at least as wide as the ramp: At the top of the ramp? : N_A (Rating: 0)

29. At the bottom of the ramp? : N_A (Rating: 0)

30. Is there a level landing where the ramp changes direction that is at least 1525mm x 1525mm? : N_A (Rating: 0)

31. If the ramp has a rise higher than 150mm are there handrails on both sides? : N_A (Rating: 0)

32. Is the top of the handrail gripping surface no less than 865mm and no greater than 965mm above the ramp surface? : N_A (Rating: 0)

33. Is the handrail gripping surface continuous and not obstructed along the top or sides? : N_A (Rating: 0)

34. If there are obstructions, is the bottom of the gripping surface obstructed no more than 20%? : N_A (Rating: 0)

Stairs

35. Are there floors or surfaces connected only by stairs, not an elevator or ramp? : No (Rating: 0)

36. How many flights of stairs are there? : N_A

37. If there are less than a flight, how many stairs are there? : N_A

38. Do all stair treads have a horizontal strip at the edge that is: 40mm-60mm deep, colour contrasted & extends the full width of the step? : N_A (Rating: 0)

39. If the stairs are not enclosed, is there a tactile warning system present at the landing of entrance to stairs system? : N_A (Rating: 0)

40. Are there handrails on both sides of the stairs at a uniform height of 860mm-920mm above the front step? : N_A (Rating: 0)

41. Do the handrails extend horizontally at the top and bottom of each flight of stairs? : N_A (Rating: 0)

42. Are the handrails continuous around landings? : N_A (Rating: 0)

43. Are the handrails continuously graspable, without interruption by vertical supports, newel posts, or other construction elements which require repositioning the hands while ascending or descending? : N_A (Rating: 0)

44. Do the handrails have a graspable cross-section that is either circular with an outside diameter of 30mm-40mm or elliptical with an outside perimeter of 100mm-125mm? : N_A (Rating: 0)

Trails

Washrooms

Date of Audit : 2016-09-12

Auditors Names : Bob

Weather condition during audit : Sunny

Washroom # : 1

Description of washroom location : Near trash receptacle and across road from double campsite (#14 & #15)

Type of Washroom : Out-house



1. If washrooms are available to the public, is at least one washroom designated as accessible? (Either one for each sex, or one unisex.) : Yes (Rating: 1)

Comments/Description : 4 outhouses in total, 1 designated as accessible

Directional signage

2. Are there signs at inaccessible washrooms that give directions to accessible washrooms? : No (Rating: 0)

Recommendations : add signage at inaccessible outhouses

Improvement Priority : Med

Estimated Cost : Low

3. Is there an accessible route to the accessible washroom? : Yes (Rating: 1)

Comments/Description : See Access Route checklist

4. If not all washrooms are accessible, is there a sign at the accessible washroom with the International Symbol of Accessibility? : Yes (Rating: 1)

5. Do text characters contrast with their backgrounds? : Yes (Rating: 1)

Comments/Description : White symbol on brown background

Recommendations : White on blue would stand out better against brown wall. Consider replacing.

Improvement Priority : Low

Estimated Cost : Low

6. Are text characters raised? : No (Rating: 0)

7. Is there Braille? : No (Rating: 0)

8. Is the sign mounted on the wall, on latch side of the door?

Note: Signs are permitted on the push side of doors with closers and without hold-open devices. : No
(Rating: 0)

Comments/Description : Located on side of outhouse facing road

Recommendations : Also place sign on latch side wall

Improvement Priority : Med

Estimated Cost : Low

9. So the baseline of the lowest character is at least 1220mm above the floor and the baseline of the highest character is no more than 1525mm above the floor?

Note: If the sign is at double doors with one active leaf, the sign should be on the inactive leaf; if both leaves are active, the sign should be on the wall to the right of the right leaf. : Yes (Rating: 1)

Measurement
(mm) : 1420

Interior doors

10. Is the door opening width at least 815mm clear, between the face of the door and the stop, when the door is open 90°? : N_A (Rating: 0)

11. If there is a front approach to the pull side of the door, is there at least 455mm of maneuvering clearance beyond the latch side plus at least 1525mm clear depth? : N_A (Rating: 0)

12. On both sides of the door, is the floor surface of the maneuvering clearance level (no steeper than 1°)? : N_A (Rating: 0)

13. If the threshold is vertical is it no more than 6mm high?

Or : N_A (Rating: 0)

14. If the threshold is beveled, is it no more than 19mm high? : N_A (Rating: 0)

15. Is the door equipped with hardware that is operable with one hand and does not require tight grasping, pinching or twisting of the wrist? : N_A (Rating: 0)

16. Are the operable parts of the hardware no less than 865mm and no greater than 1220mm above the floor? : N_A (Rating: 0)

17. Can the door be opened easily, maximum 2.3kg of force?

Note: You can use a pressure gauge or fish scale to measure force. : Yes (Rating: 1)

Measurement
(kg) : 0.5

Comments/Description : outhouse door

18. If the door has a closer, does it take at least 5 seconds to close from open position of 90° to a position of 12° from the latch? : No (Rating: 0)

Measurement
(seconds) : 4

Comments/Description : outhouse door

19. If there are two doors in a series, e.g. vestibule, is the distance between the doors at least 1220mm plus the width of the doors when swinging into the space? : N_A (Rating: 0)

20. If there is a privacy wall and the door swings out, is there at least 610mm of maneuvering clearance beyond the door latch side and 1065mm to the privacy wall? : N_A (Rating: 0)

21. If there is a privacy wall and the door swings in, is there at least 610mm of maneuvering clearance beyond the door latch side and at least 1220mm to the privacy wall if there is no door closer or at least 1370mm if there is a door closer? : N_A (Rating: 0)

22. In a unisex washroom if the door swings in and over a clear floor space at an accessible fixture, is there a clear floor space at least 760mm x 1220mm beyond the swing of the door? : N_A (Rating: 0)

Toilet stall

23. Is there an individual accessible toilet stall? : Yes (Rating: 1)

24. Is the stall door opening width at least 815mm clear, between the face of the door and the stop, when the door is open 90°? : Yes (Rating: 1)

Measurement
(mm) : 890

25. If there is a front approach to the pull side of the stall door, is there at least 455mm of maneuvering clearance beyond the latch side plus 1525mm clear depth? : Yes (Rating: 1)

Clearance
(mm) : 430

Depth
(mm) : 2100

26. Is the door self-closing? : Yes (Rating: 1)

27. Are there door pulls on both sides of the door that are operable with one hand and do not require tight grasping pinching or twisting of the wrist?* : No (Rating: 0)

Comments/Description : Small D handle on exterior is not operable with closed fist 910 mm long diagonal grab bar on interior (see picture)

Recommendations : Replace small D handle with a larger one to meet standard

Improvement Priority : High

Estimated Cost : Low

28. Is the lock operable with one hand and without tight grasping, pinching or twisting of the wrist? : No (Rating: 0)

Comments/Description : Small hook and eye 1010 mm above floor

Recommendations : Replace with a lock that is easier to operate (e.g. a sliding lock)

Improvement Priority : High

Estimated Cost : Low

29. Are the operable parts of the door hardware mounted no less than 865mm and no greater than 1220mm above the floor? : Yes (Rating: 1)

**Measurement
(mm)** : 950

30. Is the stall at least 1525mm wide? : Yes (Rating: 1)

**Measurement
(mm)** : 1530

31. If the toilet is wall hung, is the stall at least 1420mm deep?

Or : N_A (Rating: 0)

32. If the toilet is floor mounted, is the stall at least 1500mm deep? : Yes (Rating: 1)

**Measurement
(mm)** : 1520

If the door swings in, is the stall area beyond the swing of the door:

33. A minimum of 1525mm wide x 1420mm deep for wall hung toilet?

Or : N_A (Rating: 0)

Comments/Description : door swings out

34. A minimum of 1525mm wide x 1500mm deep for floor mounted toilet? : N_A (Rating: 0)

Toilet

35. Is the centerline of the toilet no less than 405mm and no greater than 455mm from the side wall or partition? : No (Rating: 0)

**Measurement
(mm)** : 540

Comments/Description : 540 mm Distance significantly exceeds standard but it would not be practical to reconfigure the outhouse

**From side wall
(mm)** : 1530

**From rear wall
(mm)** : 1520

37. Is the height of the toilet no less than 430mm and no greater than 485mm above the floor measured to the top of the seat? : No (Rating: 0)

**Measurement
(mm) : 390**

Recommendations : Consider raising toilet (if feasible) or replace with a taller toilet

Improvement Priority : Med

Estimated Cost : High

Grab bars

38. Is there a grab bar at least 1065mm long on the side wall? : No (Rating: 0)

**Measurement
(mm) : 610**

Comments/Description : See photo Angled grab bar. Diagonal section 600 mm long, horizontal section 610 mm long

Recommendations : Replace with longer horizontal grab bar to meet standard

Improvement Priority : High

Estimated Cost : Low

39. Is it located no more than 305mm from the rear wall? : No (Rating: 0)

**Measurement
(mm) : 520**

Comments/Description : Replace with longer horizontal grab bar to meet standard

40. Does it extend at least 1370mm from the rear wall? : No (Rating: 0)

**Measurement
(mm) : 1130**

41. Is it mounted no less than 840mm and no greater than 915mm above the floor to the top of the gripping surface? : No (Rating: 0)

**Measurement
(mm) : 735**

Comments/Description : 735 mm Top of diagonal section is 1240 mm above floor

42. Is there at least 305mm clearance between the grab bar and protruding objects above? : No (Rating: 0)

**Measurement
(mm) : 130**

Comments/Description : TP holder is 130 mm above grab bar

Recommendations : Re-position TP holder when replacing side grab bar

Improvement Priority : Med

Estimated Cost : Low

43. Is there at least 38mm clearance between the grab bar and projecting objects below? : N_A (Rating: 0)

44. Is the space between the wall and the grab bar 38mm : Yes (Rating: 1)

**Measurement
(mm)** : 40

45. Is there a grab bar at least 915mm long on the rear wall? : No (Rating: 0)

**Measurement
(mm)** : 610

Comments/Description : 610 mm grab bar installed VERTICALLY (see photo), 470 mm above floor and 915 mm from side wall

Recommendations : Re-position grab bar so it is horizontal (quick fix) Replace with a longer grab bar to meet standard

Improvement Priority : High

Estimated Cost : Low

46. Does the grab bar extend at least 305mm from the centerline of the toilet on one side (side wall)? : N_A (Rating: 0)

47. Does the grab bar extend at least 610mm on the other (open) side? : N_A (Rating: 0)

48. Is the grab bar mounted no less than 840mm and no greater than 915mm above the floor to the top of the gripping surface? : N_A (Rating: 0)

49. Are there at least 305mm clearance between the grab bar and protruding objects above? : N_A (Rating: 0)

50. Are there at least 38mm clearance between the grab bar and projecting objects below? : N_A (Rating: 0)

51. Is the space between the wall and the grab bar 38mm inches? : Yes (Rating: 1)

**Measurement
(mm)** : 40

Toilet flush controls

52. If the flush control is hand operated, is the operable part located no higher than 1220mm above the floor? : N_A (Rating: 0)

53. If the flush control is hand operated, can it be operated with one hand and without tight grasping, pinching, or twisting of the wrist? : N_A (Rating: 0)

54. Is the force required to activate the flush control no greater than 2.3kg? : N_A (Rating: 0)

55. Is the flush control on the open side of the toilet? : N_A (Rating: 0)

Toilet paper dispenser

56. Is the toilet paper dispenser located no less than 180mm and no greater than 230mm from the front of the toilet to the center line of the dispenser? : No (Rating: 0)

**Measurement
(mm) : 50**

Recommendations : Re-position dispenser as noted above (question 42)

Improvement Priority : Med

Estimated Cost : Low

57. Is the outlet of the dispenser: Located no less than 380mm and no greater than 1220mm above the floor? : Yes (Rating: 1)

**Measurement
(mm) : 870**

58. Is the dispenser located behind grab bars? : No (Rating: 0)

59. Does the dispenser allow continuous paper flow? : Yes (Rating: 1)

Sink

60. Does at least one sink have a clear floor space for a forward approach at least 760mm wide and 1220mm long? : N_A (Rating: 0)

61. Do no less than 430mm and no greater than 635mm of the clear floor space extend under the sink so that a person using a wheelchair can get close enough to reach the faucet? : N_A (Rating: 0)

62. Is the front of the sink or counter surface, whichever is higher, no more than 865mm above the floor? : N_A (Rating: 0)

63. Is there at least 685mm height clearance from the floor to the bottom of the sink that extends at least 205mm deep under the sink for knee clearance? : N_A (Rating: 0)

64. Is there toe clearance at least 230mm high?

Note: Space extending greater than 150mm beyond the available toe clearance at 230mm above the floor is not considered toe clearance. : N_A (Rating: 0)

65. Are pipes below the sink insulated or otherwise configured to protect against contact? : N_A (Rating: 0)

66. Can the faucet be operated without tight grasping, pinching, or twisting of the wrist? : N_A (Rating: 0)

67. Is the force required to activate the faucet no greater than 2.3 kg? : N_A (Rating: 0)

Washroom fixtures

68. Is there a clear path to at least one of each type of fixture, e.g. sink, hand dryer, garbage bin etc., that is at least 915mm wide? : N_A (Rating: 0)

69. Is there clear floor space available for a person in a wheelchair to turn around, i.e. a circle at least 1525mm in diameter or a T-shaped space within a 1525mm square? : N_A (Rating: 0)

Mirror

70. If the mirror is over a sink or countertop, is the bottom edge of the reflecting surface no higher than 1015mm above the floor?

Or : N_A (Rating: 0)

71. If the mirror is not over the sink or countertop, is the bottom edge of the reflecting surface no higher than 890mm above the floor? : N_A (Rating: 0)

Coat hook

72. If there is a coat hook, is it no less than 380mm and no greater than 1220mm above the floor?* : Yes (Rating: 1)

Measurement (mm) : 1740

Recommendations : Re-position coat hook to meet standard

Improvement Priority : High

Estimated Cost : Low

Soap dispenser

Are the operable parts of the soap dispenser within one of the following reach ranges:

73. Above sinks or counters no less than 510mm and no greater than 635mm deep: no higher than 1120mm above the floor?

Or : N_A (Rating: 0)

74. Above sinks less than 510mm deep: no higher than 1220mm above the floor?

Or : N_A (Rating: 0)

75. Not over an obstruction: no higher than 1220mm above the floor? : N_A (Rating: 0)

Hand dryer/Towel dispenser

Are the operable parts of the hand dryer or towel dispenser within one of the following reach ranges:

76. Above sinks or counters no less than 510mm and no greater than 635mm deep: no higher than 1120mm above the floor?

Or : N_A (Rating: 0)

77. Above sinks less than 510mm deep: no higher than 1220mm above the floor?

Or : N_A (Rating: 0)

78. Not over an obstruction: no higher than 1220mm above the floor? : N_A (Rating: 0)

79. Can the operable parts of the hand dryer or towel dispenser be operated without tight grasping, pinching or twisting of the wrist? : N_A (Rating: 0)

80. Is the force required to activate the hand dryer or towel dispenser no greater than 2.3kg? : N_A (Rating: 0)

Controls - light switches

81. Is there a clear floor space at least 760mm wide by at least 1220mm long for a forward or parallel approach? : N_A (Rating: 0)

82. Are the operable parts no higher than 1220mm above the floor? : N_A (Rating: 0)

83. Can the control be operated with one hand and without tight grasping, pinching, or twisting of the wrist? : N_A (Rating: 0)

1. Has the route to the washroom been evaluated? : Yes

Additional comments regarding assessment: : Outhouse is fairly accessible. Grab bars need to be installed to meet code (especially rear grab bar) Route to outhouse is good. There is a 20 cm lip from gravel path to concrete pad which can be easily remedied.



Description of Photo 1 : Inside of door to accessible outhouse. Grab bar handle.



Description of Photo 2 : Good access route to accessible outhouse

Camping

Water Access

Goods and Services