

Mt Robson Visitors Centre ▼

Information

Date of Audit: 2016-09-14

Park Name: Bridge Lake

Key Features: Camping,Picnic_Site,Fishing

Location: Cariboo, One Hundred Mile House, Cariboo Chilcotin Coast - Provincial : Park (Heritage Discovery Circle Route)

Description: 13 campsites with 3 walk in sites. little picnic area down by the boat launch.

Parking

Access Routes

Trails

Washrooms

Camping

Water Access

Date of Audit : 2016-09-14

Body of water : Lake

Location : Bridge Lake

Weather condition during audit : Sunny



2. Are an adequate number of accessible spaces provided? : No - _Below_ Standard (Rating: 0)

Total # : 10

Accessible # : 0

3. Of the accessible spaces, is at least one a van accessible space?* : N_A (Rating: 0)

4. Are accessible spaces at least 2.4m wide with an access aisle at least 1.5m wide? Note: Two spaces may share an access aisle. : N_A (Rating: 0)

5. Are the access aisles marked to discourage parking in them? : N_A (Rating: 0)

6. Is the slope of the accessible parking spaces and access aisles no steeper than 1° in all directions? :

N_A (Rating: 0)

7. Does the access aisle adjoin an accessible route? : N_A (Rating: 0)

8. Are accessible spaces identified with a sign that includes the International Symbol of Accessibility?

Note: The International Symbol of Accessibility is not required on the ground. : N_A (Rating: 0)

9. Of the total parking spaces, are the accessible spaces located on the closest accessible route to the accessible entrance(s)? Note: If parking serves multiple entrances, accessible parking should be dispersed.

: N_A (Rating: 0)

From: : Parking Lot

To: : Boat Launch

2. What is the condition of the surface along this route? : Moderate (Rating: 1)

4. What is the type of surface? : Other_add_in_comments

Comments/Description : Compact dirt and Gravel

Clear Width

5. What is the typical route width (mm)? : More_than_1525 (Rating: 0)

Comments/Description : 3850mm

6. What is the narrowest route width (mm)? : More_than_1525 (Rating: 0)

Comments/Description : 2800mm

Obstacles

7. If the route is concrete, asphalt or boardwalk, are there any obstacles that exceed 13mm from the surface? : N_A (Rating: 0)

8. If yes, are the obstacles at least 1220mm apart? : N_A (Rating: 0)

9. If the route is anything other than concrete, asphalt or boardwalk, are there any obstacles that exceed 25mm from the surface? : No (Rating: 0)

10. If yes, are the obstacles at least 1220mm apart? : N_A (Rating: 0)

Openings

11. Are there any gaps or grates present that have an opening greater than 13mm? : No (Rating: 0)

12. If gaps/grates are present, do they run perpendicular to the path of travel? : N_A (Rating: 0)

Running Slope

13. What is the typical running slope on the route? : Very_steep_above_5 (Rating: 0)

Comments/Description : 6.3 degrees

14. What is the maximum running slope on the route? : Very_steep_above_5 (Rating: 0)

Comments/Description : 11.8 degrees

Comments/Description : 1.5 degree

16. What is the maximum cross slope on the route? : Steep_3_-_5 (Rating: 0)

Comments/Description : 3 degrees

Resting Intervals

17. Are there resting intervals at the top and bottom of a route where the grade exceeds 3°? : N_A (Rating: 0)

18. If the running slope is greater than 3°, are there resting intervals in the middle of the route when the length exceeds 9.1m? : N_A (Rating: 0)

Benches

21. Are there any benches along the route? : No (Rating: 0)

22. If yes, are the benches located approximately every 61m? : N_A (Rating: 0)

23. Is the bench seat height between 485mm - 510mm? : N_A (Rating: 0)

Ramps

24. Is there is a ramp? : No (Rating: 0)

25. Is the ramp at least 915mm wide?

Note: If there are handrails, measure between the handrails. : N_A (Rating: 0)

26. Is the surface stable, firm and slip resistant? : N_A (Rating: 0)

27. For each section of the ramp, is the running slope no greater than 5°?

Note: Rises no greater than 76mm with a slope no steeper than 7° and rises no greater than 150mm with a slope no steeper than 6° are permitted when due to space limitations. : N_A (Rating: 0)

28. Is there a level landing that is at least 1525mm long and at least as wide as the ramp: At the top of the ramp? : N_A (Rating: 0)

29. At the bottom of the ramp? : N_A (Rating: 0)

30. Is there a level landing where the ramp changes direction that is at least 1525mm x 1525mm? : N_A (Rating: 0)

31. If the ramp has a rise higher than 150mm are there handrails on both sides? : N_A (Rating: 0)

32. Is the top of the handrail gripping surface no less than 865mm and no greater than 965mm above the ramp surface? : N_A (Rating: 0)

33. Is the handrail gripping surface continuous and not obstructed along the top or sides? : N_A (Rating: 0)

34. If there are obstructions, is the bottom of the gripping surface obstructed no more than 20%? : N_A (Rating: 0)

Stairs

35. Are there floors or surfaces connected only by stairs, not an elevator or ramp? : No (Rating: 0)

36. How many flights of stairs are there? : N_A

37. If there are less than a flight, how many stairs are there? : N_A

38. Do all stair treads have a horizontal strip at the edge that is: 40mm-60mm deep, colour contrasted & extends the full width of the step? : N_A (Rating: 0)

39. If the stairs are not enclosed, is there a tactile warning system present at the landing of entrance to stairs system? : N_A (Rating: 0)

40. Are there handrails on both sides of the stairs at a uniform height of 860mm-920mm above the front step? : N_A (Rating: 0)

41. Do the handrails extend horizontally at the top and bottom of each flight of stairs? : N_A (Rating: 0)

42. Are the handrails continuous around landings? : N_A (Rating: 0)

43. Are the handrails continuously graspable, without interruption by vertical supports, newel posts, or other construction elements which require repositioning the hands while ascending or descending? : N_A (Rating: 0)

44. Do the handrails have a graspable cross-section that is either circular with an outside diameter of 30mm-40mm or elliptical with an outside perimeter of 100mm-125mm? : N_A (Rating: 0)

Beach

1. Is there a beach area? : No (Rating: 0)

2. What type of surface is the beach area? : N_A

4. Is there a clear route to the water edge that is: at least 915mm wide, level and has a firm/stable surface? : N_A (Rating: 0)

Dock/Fishing Platform

1. Is there a dock or fishing platform? : No (Rating: 0)

2. For each section of the gangway, is the running slope no greater than 5°? : N_A (Rating: 0)

3. Is the gangway at least 9.1m long? : N_A (Rating: 0)

4. If a transition plate is steeper than 3°, is there a landing at the end of the transition plate? : N_A (Rating: 0)

5. Are there any gaps or grates present that have an opening greater than 13mm? : N_A (Rating: 0)
6. If gaps/grates are present, do they run perpendicular to the path of travel? : N_A (Rating: 0)
7. If there are railings/guards/handrails on the dock/fishing platform, are at least 25% accessible with no more than 865mm above the ground or deck? : N_A (Rating: 0)
8. Are the accessible railings dispersed throughout the dock/fishing platform? : N_A (Rating: 0)
9. Is there a clear space at least 1220mm long x 760mm wide at the accessible railing? : N_A (Rating: 0)
10. Is there a curb or barrier extending 51mm minimum above the surface of the dock/fishing platform? : N_A (Rating: 0)
11. If there are no railings, is there a clear space at least 1220mm long x 760mm wide on the dock/fishing platform surface? : N_A (Rating: 0)
12. Is there a clear space for a person in a wheelchair to turn around, i.e. a circle at least 1525mm in diameter? : N_A (Rating: 0)

Measurement
(angle °) : 10

Comments/Description : The boat launch has a 10 degree slope down to the water.

Measurement
(m) : 13

Comments/Description : The boat launch is 13m long.

4. What type of surface is the boat launch? : Concrete
6. Is there a clear, level accessible route to the boat launch? : N_A (Rating: 0)

2. How many accessible picnic tables are there? : N_A

Comments/Description : 0 accessible picnic tables. only 1 at boat launch

3. If the picnic table is up to 2.7m long, is there one wheelchair seating space? : N_A (Rating: 0)
4. If the picnic table is longer than 2.7m, are there at least two wheelchair spaces provided? : N_A (Rating: 0)
5. Is there clear and level ground space, 915mm measured from back edge of seats/benches? : N_A (Rating: 0)
6. Do the accessible spaces have adequate knee clearance, 685mm high x 760mm wide x 430mm deep? : N_A (Rating: 0)
7. Is the ground surface surrounding the accessible picnic table firm and stable? : N_A (Rating: 0)
8. Is there a clear, level accessible route to the picnic table? : N_A (Rating: 0)

Shelters

1. Are there any camp shelters? : No (Rating: 0)
2. What is the slope at the entrance to the camp shelter? : N_A (Rating: 0)
3. What type of surface is in the camp shelter? : N_A
4. Is the shelter surface firm and stable? : N_A (Rating: 0)
5. Is there a clear, level accessible route to the camp shelter? : N_A (Rating: 0)

Benches

1. Are any benches provided? : No (Rating: 0)
3. Is the bench seat height between 485mm - 510mm? : N_A (Rating: 0)
4. Is there a minimum of 915mm x 1220mm clear ground space beside the bench? : N_A (Rating: 0)
5. Is there a clear, level accessible route to the bench? : N_A (Rating: 0)

**Measurement
(mm) : 920**

4. If there are operable parts, can they be operated using one hand, without tightly grasping, pinching, or twisting the wrist and with no more than 2.3kg of force? : No (Rating: 0)

Comments/Description : 4kg force to open

Campfires & Grills

1. Is there an area for campfires? : No (Rating: 0)
2. Is there a minimum of 1220mm clear ground space on all sides? : N_A (Rating: 0)
3. Is the slope 3° or less in all directions? : N_A (Rating: 0)
4. Is the grill height between 380mm - 865mm above the ground? : N_A (Rating: 0)
5. Is the fire building surface height at least 230mm above the ground? : N_A (Rating: 0)
6. If there is a raised edge or wall around the fire building area, is the thickness less than 255mm? : N_A (Rating: 0)
7. Is there a clear, level accessible route to the campfire area? : N_A (Rating: 0)

Playground

1. Is there a playground? : No (Rating: 0)
- 2 What type of surface is in the play area? : N_A
3. Is the play area surface firm and stable? : N_A (Rating: 0)

4. Are any of the playground components accessible to wheelchair users? If yes, please describe. : N_A
(Rating: 0)

5. Is there a clear, level accessible route to the playground? : N_A (Rating: 0)

1. Is there water access in separate areas at the site? : No

2. Are there any trails commencing from water access? : No

3. Are any public washrooms located at water access? : Yes_-
_WASHROOMS_checklist_must_also_be_completed



Description of Photo 1 : accessible trash receptacles



Description of Photo 2 : parking area



Description of Photo 3 : outhouse washrooms are non accessible style

Goods and Services