

Mt Robson Visitors Centre ▼

Information

Date of Audit: 2016-09-21

Park Name: Buckinghorse

Key Features: Camping,Picnic_Site

Location: Peace River, Fort St John, Northern BC - Provincial : Park (Great Northern Circle Route)

Description:

Parking

Access Routes

Trails

Washrooms

Camping

Date of Audit (YYYY-MM-DD) : 2016-09-21

Name of Campground : Buckinghorse River Provincial Park Campground

Location of Campsite : Approximately 200 km NW of Fort St. John on the Alaska Highway

Weather condition during audit : Sunny



1. Does the number of accessible camp sites comply with the table above? : No_ _Below_Standard (Rating: 0)

Comments/Description : None were specified, but many could have been.

Campsite

2. Is the camp site surface firm and stable? : Yes (Rating: 1)

3. What type of surface is in the campsite? : Gravel

Comments/Description : Hard Packed

4. Is the accessible campsite at least 4.9m wide?

Or : N_A (Rating: 0)

Comments/Description : There are areas that exceed the standard in this park, if certain sites were designated

5. If it is an RV site, is the parking area at least 6m wide? : N_A (Rating: 0)

Comments/Description : There are areas in this park that exceed the standard if they were designated accessible

6. If the campsite surface is concrete or asphalt, is the slope 1° or less? : Yes - _Meets_Standard (Rating: 1)

7. If the campsite surface is anything other than concrete & asphalt, is the slope 3° or less? : Yes - _Meets_Standard (Rating: 1)

Tent Pads/Platforms

8. Is there a minimum of 1220mm clear space on all sides surrounding the tent pad or platform? : N_A (Rating: 0)

Comments/Description : NO tent pads but I believe a tent could be set up.

9. What type of surface is the tent pad/ platform? : Gravel

Comments/Description : Hard Packed

10. What is the slope of the tent pad/ platform? : N_A (Rating: 0)

Comments/Description : flat/gentle less than 1 degree slope

11. Is there an accessible entrance or ramp on to the tent pad/platform? : N_A (Rating: 0)

Utility & Sewage Hook Ups

12. Is there sufficient clear ground space, a minimum of 1220mm x 1525mm surrounding the hook ups? : N_A (Rating: 0)

13. If there are operable parts, can they be operated using one hand, without tightly grasping, pinching, or twisting the wrist and with no more than 2.3kg of force? : N_A (Rating: 0)

Campfires & Grills

14. Is there an area for campfires? : Yes (Rating: 1)

15. Is there a minimum of 1220mm clear ground space on all sides? : No - _Below_Standard (Rating: 0)

Measurement (mm) : 1140

16. Is the slope 3° or less in all directions? : Yes (Rating: 1)

17. Is the grill height between 380mm - 865mm above the ground? : Yes (Rating: 1)

Measurement (mm) : 400

18. Is the fire building surface height at least 230mm above the ground? : No (Rating: 0)

Measurement**(mm) : 60**

19. If there is a raised edge or wall around the fire building area, is the thickness less than 255mm? : No
(Rating: 0)

20. Is there a clear, level accessible route to the campfire area? : Yes (Rating: 1)

21. Are picnic tables provided? : Yes (Rating: 1)

22. How many accessible picnic tables are there? : 5

23. If the picnic table is up to 2.7m long, is there one wheelchair seating space? : Yes (Rating: 1)

24. If the picnic table is longer than 2.7m, are there at least two wheelchair spaces provided? : N_A
(Rating: 0)

25. Is there clear and level ground space, 915mm measured from back edge of seats/benches? : Yes -
_Exceeds_Standard

Measurement**(mm) : 1140**

26. Do the accessible spaces have adequate knee clearance, 685mm high x 760mm wide x 430mm deep? :
Yes (Rating: 1)

27. Is the ground surface surrounding the accessible picnic table firm and stable? : Yes (Rating: 1)

28. Is there a clear, level accessible route to the picnic table? : Yes (Rating: 1)

Water Taps

1. Are there any water taps? : No (Rating: 0)

2. Is there sufficient clear ground space, a minimum of 1829mm x 1220mm surrounding the water tap? :
N_A (Rating: 0)

3. Is the water spout height between 280mm - 305mm? : N_A (Rating: 0)

4. Is the height of operable parts (i.e. taps or levers) between 380mm - 1220mm above the ground? : N_A
(Rating: 0)

5. If there are operable parts, can they be operated using one hand, without tightly grasping, pinching, or twisting the wrist and with no more than 2.3kg of force? : N_A (Rating: 0)

6. Is there a clear, level accessible route to the water tap? : N_A (Rating: 0)

Water Fountains

1. Is there a water fountain? : No (Rating: 0)

2. Does it have a lever or push bar control on the front or both sides? : N_A (Rating: 0)

3. Is the spout opening height between 750mm - 915mm above the ground? : N_A (Rating: 0)

4. Is there a minimum width of 800mm clearance space directly in front of the water fountain? : N_A (Rating: 0)

5. Is there a clear, level accessible route to the water fountain? : N_A (Rating: 0)

Trash & Recycling Receptacles

1. Are there any trash &/or recycling receptacles? : Yes (Rating: 1)

2. Is the approach to the receptacle level, with no-step? : Yes (Rating: 1)

3. If there are operable parts, is their height between 380mm - 1220mm above the ground? : Yes (Rating: 1)

Measurement (mm) : 960

4. If there are operable parts, can they be operated using one hand, without tightly grasping, pinching, or twisting the wrist and with no more than 2.3kg of force? : Yes (Rating: 1)

5. Is there a clear, level accessible route to the trash/recycling receptacle? : Yes (Rating: 1)

Shelters

1. Are there any camp shelters? : No (Rating: 0)

2. What is the slope at the entrance to the camp shelter? : N_A (Rating: 0)

3. What type of surface is in the camp shelter? : N_A

4. Is the shelter surface firm and stable? : N_A (Rating: 0)

5. Is there a clear, level accessible route to the camp shelter? : N_A (Rating: 0)

Benches

1. Are any benches provided? : No (Rating: 0)

2. If yes, how many benches are there? : N_A

3. Is the bench seat height between 485mm - 510mm? : N_A (Rating: 0)

4. Is there a minimum of 915mm x 1220mm clear ground space beside the bench? : N_A (Rating: 0)

5. Is there a clear, level accessible route to the bench? : N_A (Rating: 0)

Playground

1. Is there a playground? : No (Rating: 0)

2 What type of surface is in the play area? : N_A

3. Is the play area surface firm and stable? : N_A (Rating: 0)

4. Are any of the playground components accessible to wheelchair users? If yes, please describe. : N_A (Rating: 0)

5. Is there a clear, level accessible route to the playground? : N_A (Rating: 0)

Amphitheatre

1. Is there an amphitheatre? : No (Rating: 0)

Amphitheatre Seating

2. Are an adequate number of wheelchair spaces provided? : N_A (Rating: 0)

3. Are wheelchair spaces dispersed to allow location choices and viewing angles equivalent to other seating, including specialty seating areas that provide distinct services and amenities? : N_A (Rating: 0)

4. Where people are expected to remain seated, do people in wheelchair spaces have a clear line of sight over and between the heads of others in front of them? : N_A (Rating: 0)

5. Where people are expected to stand, do people in wheelchair spaces have a clear line of sight over and between the heads heads of others in front of them? : N_A (Rating: 0)

6. If there is a single wheelchair space, is it at least 915mm wide? : N_A (Rating: 0)

7. If there are two adjacent wheelchair spaces, are they each at least 840mm wide? : N_A (Rating: 0)

8. If the wheelchair space can be entered from the front or rear, is it at least 1220mm deep? : N_A (Rating: 0)

9. If the wheelchair space can only be entered from the side, is it at least 1525mm deep? : N_A (Rating: 0)

10. Do wheelchair spaces adjoin, but not overlap, accessible routes? : N_A (Rating: 0)

11. Is there at least one companion seat for each wheelchair space? : N_A (Rating: 0)

12. Is the companion seat located so the companion is shoulder-to-shoulder with the person in a wheelchair? : N_A (Rating: 0)

13. Is the companion seat equivalent in size, quality, comfort and amenities to seating in the immediate area? : N_A (Rating: 0)

2. Are there any public buildings (visitors centre/ interpretive centre/cafes etc) at the campground? : No (Rating: 0)

3. Are there any trails at the campground? : No (Rating: 0)

4. Is there a beach, dock/fishing platform or boat launch? : No (Rating: 0)

Additional comments regarding assessment: : The addition of accessible toilets would make this campsite Perfect!




Description of Photo 1 : Campsites are close together



Description of Photo 2 : One of the more secluded campsites



Description of Photo 3 : A view of the inaccessible toilets



Description of Photo 4 : A great place to stop for lunch

Water Access

Goods and Services