

Mt Robson Visitors Centre ▼

#### Information

Date of Audit: 2016-10-13

Park Name: Canada Games Plaza

Key Features: View\_Point

Location: Fraser Fort George, Prince George, Northern BC - Municipal : Site (Great Northern Circle Route)

Description: This is described as a special event gathering place

Parking

Access Routes

**From:** : Parking under the library

**To:** : Plaza

**2. What is the condition of the surface along this route?** : Good

**4. What is the type of surface?** : Concrete

#### Clear Width

**5. What is the typical route width (mm)?** : between\_1525\_-\_1220

**6. What is the narrowest route width (mm)?** : between\_1525\_-\_1220

#### Obstacles

**7. If the route is concrete, asphalt or boardwalk, are there any obstacles that exceed 13mm from the surface?** : No (Rating: 0)

**8. If yes, are the obstacles at least 1220mm apart?** : N\_A (Rating: 0)

**9. If the route is anything other than concrete, asphalt or boardwalk, are there any obstacles that exceed 25mm from the surface?** : N\_A (Rating: 0)

**10. If yes, are the obstacles at least 1220mm apart?** : N\_A (Rating: 0)

#### Openings

**11. Are there any gaps or grates present that have an opening greater than 13mm?** : No (Rating: 0)

**12. If gaps/grates are present, do they run perpendicular to the path of travel?** : N\_A (Rating: 0)

#### Running Slope

**13. What is the typical running slope on the route?** : Flat\_Gentle\_1\_or\_less

**14. What is the maximum running slope on the route?** : Flat\_Gentle\_1\_or\_less

#### Cross Slope

**15. What is the typical cross slope on the route? :** Flat\_Gentle\_1\_or\_less

**16. What is the maximum cross slope on the route? :** Flat\_Gentle\_1\_or\_less

### Resting Intervals

**17. Are there resting intervals at the top and bottom of a route where the grade exceeds 3°? :** N\_A (Rating: 0)

**18. If the running slope is greater than 3°, are there resting intervals in the middle of the route when the length exceeds 9.1m? :** N\_A (Rating: 0)

### Benches

**21. Are there any benches along the route? :** No (Rating: 0)

**22. If yes, are the benches located approximately every 61m? :** N\_A (Rating: 0)

**23. Is the bench seat height between 485mm - 510mm? :** N\_A (Rating: 0)

### Measurement

**(mm) :** 1500

**27. For each section of the ramp, is the running slope no greater than 5°?**

**Note: Rises no greater than 76mm with a slope no steeper than 7° and rises no greater than 150mm with a slope no steeper than 6° are permitted when due to space limitations. :** Yes\_-\_meets\_standard (Rating: 1)

### Measurement

**(angle °) :** 5

**28. Is there a level landing that is at least 1525mm long and at least as wide as the ramp: At the top of the ramp? :** Yes\_-\_meets\_standard (Rating: 1)

### Measurement

**(mm) l x w :** 1525 x 1525

**29. At the bottom of the ramp? :** Yes\_-\_meets\_standard (Rating: 1)

### Measurement

**(mm) l x w :** 1525 x 1525

**30. Is there a level landing where the ramp changes direction that is at least 1525mm x 1525mm? :** Yes\_-\_meets\_standard (Rating: 1)

### Measurement

**(mm) l x w :** 1525 x 1525

**32. Is the top of the handrail gripping surface no less than 865mm and no greater than 965mm above the ramp surface? :** No\_-\_Below\_Standard (Rating: 0)

### Measurement

**(mm) :** 810

**34. If there are obstructions, is the bottom of the gripping surface obstructed no more than 20%? : Yes\_-  
\_Exceeds\_Standard**

### Stairs

**35. Are there floors or surfaces connected only by stairs, not an elevator or ramp? : No (Rating: 0)**

**36. How many flights of stairs are there? : N\_A**

**37. If there are less than a flight, how many stairs are there? : N\_A**

**38. Do all stair treads have a horizontal strip at the edge that is: 40mm-60mm deep, colour contrasted & extends the full width of the step? : N\_A (Rating: 0)**

**39. If the stairs are not enclosed, is there a tactile warning system present at the landing of entrance to stairs system? : N\_A (Rating: 0)**

**40. Are there handrails on both sides of the stairs at a uniform height of 860mm-920mm above the front step? : N\_A (Rating: 0)**

**41. Do the handrails extend horizontally at the top and bottom of each flight of stairs? : N\_A (Rating: 0)**

**42. Are the handrails continuous around landings? : N\_A (Rating: 0)**

**43. Are the handrails continuously graspable, without interruption by vertical supports, newel posts, or other construction elements which require repositioning the hands while ascending or descending? : N\_A (Rating: 0)**

**44. Do the handrails have a graspable cross-section that is either circular with an outside diameter of 30mm-40mm or elliptical with an outside perimeter of 100mm-125mm? : N\_A (Rating: 0)**

Trails

Washrooms

Camping

Water Access

Goods and Services