

Mt Robson Visitors Centre ▼

Information

Date of Audit: 2016-08-08

Park Name: Crooked River

Key Features: Camping,Picnic\_Site,Beach,Trails,Playground

Location: Fraser Fort George, Prince George, Northern BC - Provincial : Campground (Great Northern Circle Route)

Description: Bear Lake campsite has 5 playgrounds, all set in sand

Parking

**2. Are an adequate number of accessible spaces provided?** : N\_A (Rating: 0)

**3. Of the accessible spaces, is at least one a van accessible space?\*** : N\_A (Rating: 0)

**4. Are accessible spaces at least 2.4m wide with an access aisle at least 1.5m wide? Note: Two spaces may share an access aisle.** : N\_A (Rating: 0)

**5. Are the access aisles marked to discourage parking in them?** : N\_A (Rating: 0)

**6. Is the slope of the accessible parking spaces and access aisles no steeper than 1° in all directions?** : N\_A (Rating: 0)

**7. Does the access aisle adjoin an accessible route?** : N\_A (Rating: 0)

**8. Are accessible spaces identified with a sign that includes the International Symbol of Accessibility? Note: The International Symbol of Accessibility is not required on the ground.** : N\_A (Rating: 0)

**9. Of the total parking spaces, are the accessible spaces located on the closest accessible route to the accessible entrance(s)? Note: If parking serves multiple entrances, accessible parking should be dispersed.** : N\_A (Rating: 0)

**2. What is the condition of the surface along this trail?** : Moderate (Rating: 1)

Access Routes

**From:** : Parking Lot

**To:** : Day use picnic area

**2. What is the condition of the surface along this route?** : Moderate (Rating: 1)

**Comments/Description** : poor for a wheelchair, the surface is a mix of loose and packed gravel and grass

**Recommendations** : A clearly defined, packed, level path connecting elements in the park

**Improvement Priority** : Med

**Estimated Cost** : Med

Surface

**3. Is the surface firm and stable?** : No (Rating: 0)

**Comments/Description** : It varies

**4. What is the type of surface?** : Gravel

**Comments/Description** : often loose

#### Clear Width

**5. What is the typical route width (mm)?** : between\_1220\_-915 (Rating: 1)

**6. What is the narrowest route width (mm)?** : less\_than\_915 (Rating: 0)

#### Obstacles

**7. If the route is concrete, asphalt or boardwalk, are there any obstacles that exceed 13mm from the surface?** : N\_A (Rating: 0)

**Comments/Description** : the nature of the trail is the obstacle, fine for the agile, a challenge for the rest

**8. If yes, are the obstacles at least 1220mm apart?** : N\_A (Rating: 0)

**Comments/Description** : loose gravel from time to time, tree roots

#### Openings

**11. Are there any gaps or grates present that have an opening greater than 13mm?** : No (Rating: 0)

**12. If gaps/grates are present, do they run perpendicular to the path of travel?** : N\_A (Rating: 0)

#### Running Slope

**13. What is the typical running slope on the route?** : Moderate\_2\_-\_3 (Rating: 1)

**14. What is the maximum running slope on the route?** : Moderate\_2\_-\_3 (Rating: 1)

#### Cross Slope

**15. What is the typical cross slope on the route?** : Flat\_Gentle\_1\_or\_less

**16. What is the maximum cross slope on the route?** : Flat\_Gentle\_1\_or\_less

#### Resting Intervals

**17. Are there resting intervals at the top and bottom of a route where the grade exceeds 3°?** : N\_A (Rating: 0)

**18. If the running slope is greater than 3°, are there resting intervals in the middle of the route when the length exceeds 9.1m?** : N\_A (Rating: 0)

#### Benches

**21. Are there any benches along the route?** : No (Rating: 0)

**22. If yes, are the benches located approximately every 61m? : N\_A (Rating: 0)**

**23. Is the bench seat height between 485mm - 510mm? : N\_A (Rating: 0)**

### **Ramps**

**24. Is there is a ramp? : No (Rating: 0)**

**25. Is the ramp at least 915mm wide?**

**Note: If there are handrails, measure between the handrails. : N\_A (Rating: 0)**

**26. Is the surface stable, firm and slip resistant? : N\_A (Rating: 0)**

**27. For each section of the ramp, is the running slope no greater than 5°?**

**Note: Rises no greater than 76mm with a slope no steeper than 7° and rises no greater than 150mm with a slope no steeper than 6° are permitted when due to space limitations. : N\_A (Rating: 0)**

**28. Is there a level landing that is at least 1525mm long and at least as wide as the ramp: At the top of the ramp? : N\_A (Rating: 0)**

**29. At the bottom of the ramp? : N\_A (Rating: 0)**

**30. Is there a level landing where the ramp changes direction that is at least 1525mm x 1525mm? : N\_A (Rating: 0)**

**31. If the ramp has a rise higher than 150mm are there handrails on both sides? : N\_A (Rating: 0)**

**32. Is the top of the handrail gripping surface no less than 865mm and no greater than 965mm above the ramp surface? : N\_A (Rating: 0)**

**33. Is the handrail gripping surface continuous and not obstructed along the top or sides? : N\_A (Rating: 0)**

**34. If there are obstructions, is the bottom of the gripping surface obstructed no more than 20%? : N\_A (Rating: 0)**

### **Stairs**

**35. Are there floors or surfaces connected only by stairs, not an elevator or ramp? : No (Rating: 0)**

**36. How many flights of stairs are there? : N\_A**

**37. If there are less than a flight, how many stairs are there? : N\_A**

**38. Do all stair treads have a horizontal strip at the edge that is: 40mm-60mm deep, colour contrasted & extends the full width of the step? : N\_A (Rating: 0)**

**39. If the stairs are not enclosed, is there a tactile warning system present at the landing of entrance to stairs system? : N\_A (Rating: 0)**

**40. Are there handrails on both sides of the stairs at a uniform height of 860mm-920mm above the front**

**step?** : N\_A (Rating: 0)

**41. Do the handrails extend horizontally at the top and bottom of each flight of stairs?** : N\_A (Rating: 0)

**42. Are the handrails continuous around landings?** : N\_A (Rating: 0)

**43. Are the handrails continuously graspable, without interruption by vertical supports, newel posts, or other construction elements which require repositioning the hands while ascending or descending?** : N\_A (Rating: 0)

**44. Do the handrails have a graspable cross-section that is either circular with an outside diameter of 30mm-40mm or elliptical with an outside perimeter of 100mm-125mm?** : N\_A (Rating: 0)

Trails

**Date of Audit** : 2016-08-08

**Name of Trail** : Square Lake Livingston Springs

**Section of trail audited** : First quarte

**Weather condition during audit** : Cloudy



**Clear Width**

**5. What is the typical trail width (mm)?** : between\_1220\_-915 (Rating: 1)

**6. What is the narrowest trail width (mm)?** : less\_than\_915 (Rating: 0)

**Obstacles**

**7. If the trail is concrete, asphalt or boardwalk, are there any obstacles that exceed 13mm from the surface?** : N\_A (Rating: 0)

**8. If yes, are the obstacles at least 1220mm apart?** : N\_A (Rating: 0)

**10. If yes, are the obstacles at least 1220mm apart?** : No (Rating: 0)

**Comments/Description** : roots and muddy soft parts

**Openings**

**11. Are there any gaps or grates present that have an opening greater than 13mm? : No (Rating: 0)**

**12. If gaps/grates are present, do they run perpendicular to the path of travel? : N\_A (Rating: 0)**

**14. What is the maximum running slope on the trail? : Steep\_3\_-\_5 (Rating: 0)**

**16. What is the maximum cross slope on the trail? : Moderate\_2\_-\_3 (Rating: 1)**

**18. If the running slope is greater than 3°, are there resting intervals in the middle of the trail when the length exceeds 9.1m? : No (Rating: 0)**

### **Protruding Objects**

**19. Is there a minimum of 2030mm vertical clearance for users to safely pass along the trail without coming into contact with overhanging obstacles? : Yes\_-\_meets\_standard (Rating: 1)**

**20. Is there a minimum of 100mm horizontal clearance for users to safely pass along the trail without coming into contact with side obstacles? : Yes\_-\_meets\_standard (Rating: 1)**

### **Benches**

**21. Are there any benches along the trail? : No (Rating: 0)**

**22. If yes, are the benches located approximately every 61m? : N\_A (Rating: 0)**

**23. Is the bench seat height between 485mm - 510mm? : N\_A (Rating: 0)**

### **Ramps**

**24. Is there is a ramp? : No (Rating: 0)**

**25. Is the ramp at least 915mm wide?**

**Note: If there are handrails, measure between the handrails. : N\_A (Rating: 0)**

**26. Is the surface stable, firm and slip resistant? : N\_A (Rating: 0)**

**27. For each section of the ramp, is the running slope no greater than 5°?**

**Note: Rises no greater than 76mm with a slope no steeper than 7° and rises no greater than 150mm with a slope no steeper than 6° are permitted when due to space limitations. : N\_A (Rating: 0)**

**28. Is there a level landing that is at least 1525mm long and at least as wide as the ramp: At the top of the ramp? : N\_A (Rating: 0)**

**29. At the bottom of the ramp? : N\_A (Rating: 0)**

**30. Is there a level landing where the ramp changes direction that is at least 1525mm x 1525mm? : N\_A (Rating: 0)**

**31. If the ramp has a rise higher than 150mm are there handrails on both sides? : N\_A (Rating: 0)**

**32. Is the top of the handrail gripping surface no less than 865mm and no greater than 965mm above the ramp surface? : N\_A (Rating: 0)**

**33. Is the handrail gripping surface continuous and not obstructed along the top or sides? : N\_A (Rating: 0)**

**34. If there are obstructions, is the bottom of the gripping surface obstructed no more than 20%? : N\_A (Rating: 0)**

### Stairs

**35. Are there floors or surfaces connected only by stairs, not an elevator or ramp? : No (Rating: 0)**

**36. How many flights of stairs are there? : N\_A**

**37. If there are less than a flight, how many stairs are there? : N\_A**

**38. Do all stair treads have a horizontal strip at the edge that is: 40mm-60mm deep, colour contrasted & extends the full width of the step? : N\_A (Rating: 0)**

**39. If the stairs are not enclosed, is there a tactile warning system present at the landing of entrance to stairs system? : N\_A (Rating: 0)**

**40. Are there handrails on both sides of the stairs at a uniform height of 860mm-920mm above the front step? : N\_A (Rating: 0)**

**41. Do the handrails extend horizontally at the top and bottom of each flight of stairs? : N\_A (Rating: 0)**

**42. Are the handrails continuous around landings? : N\_A (Rating: 0)**

**43. Are the handrails continuously graspable, without interruption by vertical supports, newel posts, or other construction elements which require repositioning the hands while ascending or descending? : N\_A (Rating: 0)**

**44. Do the handrails have a graspable cross-section that is either circular with an outside diameter of 30mm-40mm or elliptical with an outside perimeter of 100mm-125mm? : N\_A (Rating: 0)**

### Viewing Area

**1. Is there a viewing area on the trail? : No (Rating: 0)**

**Comments/Description :** There is potential for wide spots where the view of the area is good

**2. Is there sufficient clear ground space, a minimum of 915mm x 1220mm for the user to view the key features? : N\_A (Rating: 0)**

**3. Is the viewing area surface firm and stable? : N\_A (Rating: 0)**

**4. What type of surface is the viewing area? : N\_A**

**Recommendations :** viewing areas needs wide flat packed areas to stop

**Improvement Priority :** Low

**Estimated Cost :** Med

**5. Is there a clear space between 815mm - 1320mm above the ground, free of obstructions and extending the full width of clear space? : N\_A (Rating: 0)**

### **Picnic Area**

**1. Are picnic tables provided? : No (Rating: 0)**

**2. How many accessible picnic tables are there? : N\_A**

**3. If the picnic table is up to 2.7m long, is there one wheelchair seating space? : N\_A (Rating: 0)**

**4. If the picnic table is longer than 2.7m, are there at least two wheelchair spaces provided? : N\_A (Rating: 0)**

**5. Is there clear and level ground space, 915mm measured from back edge of seats/benches? : N\_A (Rating: 0)**

**6. Do the accessible spaces have adequate knee clearance, 685mm high x 760mm wide x 430mm deep? : N\_A (Rating: 0)**

**7. Is the ground surface surrounding the accessible picnic table firm and stable? : N\_A (Rating: 0)**

**8. Is there a clear, level accessible route to the picnic table? : N\_A (Rating: 0)**

### **Shelters**

**1. Are there any camp shelters? : No (Rating: 0)**

**2. What is the slope at the entrance to the camp shelter? : N\_A (Rating: 0)**

**3. What type of surface is in the camp shelter? : N\_A**

**4. Is the shelter surface firm and stable? : N\_A (Rating: 0)**

**5. Is there a clear, level accessible route to the camp shelter? : N\_A (Rating: 0)**

### **Benches**

**1. Are any benches provided? : No (Rating: 0)**

**2. If yes, how many benches are there? : N\_A**

**3. Is the bench seat height between 485mm - 510mm? : N\_A (Rating: 0)**

**4. Is there a minimum of 915mm x 1220mm clear ground space beside the bench? : N\_A (Rating: 0)**

**5. Is there a clear, level accessible route to the bench? : N\_A (Rating: 0)**

### **Measurement**

**(mm) : 960**

**4. If there are operable parts, can they be operated using one hand, without tightly grasping, pinching, or twisting the wrist and with no more than 2.3kg of force? : No (Rating: 0)**

**Comments/Description** : bear proof

### **Campfires & Grills**

- 1. Is there an area for campfires?** : No (Rating: 0)
  - 2. Is there a minimum of 1220mm clear ground space on all sides?** : N\_A (Rating: 0)
  - 3. Is the slope 3° or less in all directions?** : N\_A (Rating: 0)
  - 4. Is the grill height between 380mm - 865mm above the ground?** : N\_A (Rating: 0)
  - 5. Is the fire building surface height at least 230mm above the ground?** : N\_A (Rating: 0)
  - 6. If there is a raised edge or wall around the fire building area, is the thickness less than 255mm?** : N\_A (Rating: 0)
  - 7. Is there a clear, level accessible route to the campfire area?** : N\_A (Rating: 0)
- 1. Are any public washrooms located at the trail head or on the trail?** : No

**Additional comments regarding assessment** : This trail is steep, then flat and mucky, then steep and circles Square Lake. The trail is packed earth, sandy in spots and some gravel. Not good for wheelchairs. A visually impaired person would need a way of spotting the roots before they tripped. This is a picturesque trail for the able bodied but could be frustrating for some mobility challenged. There is potential for wildlife encounters along the trail at times.



**Description of Photo 1** : Parts of the trail are good.



**Description of Photo 2** : Parts of the trail are not so good.



**Description of Photo 3** : Parts of the trail are steep but lots of potential for seeing wildlife.





**Description of Photo 4 :** The entrance meets width standard

Washrooms

**Date of Audit :** 2016-08-08

**Auditors Names :** Cathy

**Weather condition during audit :** Cloudy

**Washroom # :** 1

**Description of washroom location :** Change Room near day use & beach

**Type of Washroom :** Washroom\_Building



**1. If washrooms are available to the public, is at least one washroom designated as accessible? (Either one for each sex, or one unisex.) :** Yes (Rating: 1)

**Comments/Description :** by size and presence of grab bar only

**Directional signage**

**2. Are there signs at inaccessible washrooms that give directions to accessible washrooms? :** No (Rating: 0)

**Recommendations :** install directional signs please

**Improvement Priority :** Med

**Estimated Cost :** Low

**3. Is there an accessible route to the accessible washroom? :** Yes (Rating: 1)

**Comments/Description :** Paved but a bit steep

**Recommendations :** Level and pack the path so it is flush with the floor of the washroom

**Improvement Priority : Med**

**Estimated Cost : Med**

**4. If not all washrooms are accessible, is there a sign at the accessible washroom with the International Symbol of Accessibility? : No (Rating: 0)**

**Recommendations : replace or paint the sign on the building**

**Improvement Priority : Med**

**Estimated Cost : Low**

**5. Do text characters contrast with their backgrounds? : Yes (Rating: 1)**

**6. Are text characters raised? : No (Rating: 0)**

**7. Is there Braille? : No (Rating: 0)**

**8. Is the sign mounted on the wall, on latch side of the door?**

**Note: Signs are permitted on the push side of doors with closers and without hold-open devices. : N\_A (Rating: 0)**

**9. So the baseline of the lowest character is at least 1220mm above the floor and the baseline of the highest character is no more than 1525mm above the floor?**

**Note: If the sign is at double doors with one active leaf, the sign should be on the inactive leaf; if both leaves are active, the sign should be on the wall to the right of the right leaf. : Yes (Rating: 1)**

**Measurement (mm) : 1480**

**Interior doors**

**10. Is the door opening width at least 815mm clear, between the face of the door and the stop, when the door is open 90°? : Yes (Rating: 1)**

**Measurement (mm) : 820**

**11. If there is a front approach to the pull side of the door, is there at least 455mm of maneuvering clearance beyond the latch side plus at least 1525mm clear depth? : Yes (Rating: 1)**

**Comments/Description : 1525 plus clear depth 800 maneuvering**

**12. On both sides of the door, is the floor surface of the maneuvering clearance level (no steeper than 1°)? : Yes (Rating: 1)**

**Measurement (angle °) : 0**

**Comments/Description : flat concrete**

**13. If the threshold is vertical is it no more than 6mm high?**

**Or : Yes (Rating: 1)**

**Measurement  
(mm) : 5**

**14. If the threshold is beveled, is it no more than 19mm high? : N\_A (Rating: 0)**

**15. Is the door equipped with hardware that is operable with one hand and does not require tight grasping, pinching or twisting of the wrist? : Yes (Rating: 1)**

**Comments/Description : D handle a bit narrow**

**16. Are the operable parts of the hardware no less than 865mm and no greater than 1220mm above the floor? : Yes (Rating: 1)**

**Measurement  
(mm) : 920**

**17. Can the door be opened easily, maximum 2.3kg of force?**

**Note: You can use a pressure gauge or fish scale to measure force. : Yes (Rating: 1)**

**Measurement  
(kg) : 6**

**Comments/Description : tough**

**Recommendations : adjust if possible**

**Improvement Priority : Med**

**Estimated Cost : Low**

**18. If the door has a closer, does it take at least 5 seconds to close from open position of 90° to a position of 12° from the latch? : Yes (Rating: 1)**

**Measurement  
(seconds) : 3**

**Comments/Description : fast**

**Recommendations : adjust closer if possible**

**Improvement Priority : Med**

**Estimated Cost : Low**

**19. If there are two doors in a series, e.g. vestibule, is the distance between the doors at least 1220mm plus the width of the doors when swinging into the space? : N\_A (Rating: 0)**

**20. If there is a privacy wall and the door swings out, is there at least 610mm of maneuvering clearance beyond the door latch side and 1065mm to the privacy wall? : N\_A (Rating: 0)**

**21. If there is a privacy wall and the door swings in, is there at least 610mm of maneuvering clearance beyond the door latch side and at least 1220mm to the privacy wall if there is no door closer or at least 1370mm if there is a door closer? : N\_A (Rating: 0)**

**22. In a unisex washroom if the door swings in and over a clear floor space at an accessible fixture, is there a clear floor space at least 760mm x 1220mm beyond the swing of the door? : N\_A (Rating: 0)**

#### **Toilet stall**

**23. Is there an individual accessible toilet stall? : Yes (Rating: 1)**

**24. Is the stall door opening width at least 815mm clear, between the face of the door and the stop, when the door is open 90°? : No (Rating: 0)**

**Measurement  
(mm) : 815**

**Comments/Description : door opens out**

**25. If there is a front approach to the pull side of the stall door, is there at least 455mm of maneuvering clearance beyond the latch side plus 1525mm clear depth? : Yes (Rating: 1)**

**Clearance  
(mm) : 800**

**Depth  
(mm) : 1440**

**26. Is the door self-closing? : No (Rating: 0)**

**27. Are there door pulls on both sides of the door that are operable with one hand and do not require tight grasping pinching or twisting of the wrist?\* : Yes (Rating: 1)**

**Comments/Description : could be bigger**

**28. Is the lock operable with one hand and without tight grasping, pinching or twisting of the wrist? : Yes (Rating: 1)**

**29. Are the operable parts of the door hardware mounted no less than 865mm and no greater than 1220mm above the floor? : Yes (Rating: 1)**

**Measurement  
(mm) : 1030**

**30. Is the stall at least 1525mm wide? : Yes (Rating: 1)**

**Measurement  
(mm) : 1770**

**31. If the toilet is wall hung, is the stall at least 1420mm deep?**

**Or : No (Rating: 0)**

**Measurement**  
**(mm) : 1410**

**32. If the toilet is floor mounted, is the stall at least 1500mm deep? : Yes (Rating: 1)**

**Measurement**  
**(mm) : 1410**

**If the door swings in, is the stall area beyond the swing of the door:**

**33. A minimum of 1525mm wide x 1420mm deep for wall hung toilet?**

**Or : Yes (Rating: 1)**

**Measurement**  
**(mm x mm) : 1770**

**34. A minimum of 1525mm wide x 1500mm deep for floor mounted toilet? : Yes (Rating: 1)**

**Measurement**  
**(mm x mm) : 1440 x 1960**

**Comments/Description : 1770 mm wide by 1410 mm deep**

**Toilet**

**35. Is the centerline of the toilet no less than 405mm and no greater than 455mm from the side wall or partition? : Yes (Rating: 1)**

**Measurement**  
**(mm) : 430**

**36. Is clearance provided around the toilet measuring at least 1525mm from the side wall and at least 1420mm from the rear wall? : Yes (Rating: 1)**

**From side wall**  
**(mm) : 1770**

**From rear wall**  
**(mm) : 1410**

**37. Is the height of the toilet no less than 430mm and no greater than 485mm above the floor measured to the top of the seat? : Yes (Rating: 1)**

**Measurement**  
**(mm) : 490**

**Grab bars**

**38. Is there a grab bar at least 1065mm long on the side wall? : No (Rating: 0)**

**Measurement**  
**(mm) : 820**

**Comments/Description** : poor positioning, see picture a straight horizontal bar meets the widest range of accessibility

**Recommendations** : replace with horizontal bar that meets or exceeds the standard

**Improvement Priority** : Med

**Estimated Cost** : Low

**39. Is it located no more than 305mm from the rear wall?** : Yes (Rating: 1)

**Measurement  
(mm)** : 260

**40. Does it extend at least 1370mm from the rear wall?** : No (Rating: 0)

**Measurement  
(mm)** : 1080

**41. Is it mounted no less than 840mm and no greater than 915mm above the floor to the top of the gripping surface?** : No (Rating: 0)

**Measurement  
(mm)** : 830

**Recommendations** : install the new horizontal bar within standards

**Improvement Priority** : Med

**Estimated Cost** : Low

**42. Is there at least 305mm clearance between the grab bar and protruding objects above?** : No (Rating: 0)

**Measurement  
(mm)** : 180

**43. Is there at least 38mm clearance between the grab bar and projecting objects below?** : N\_A (Rating: 0)

**44. Is the space between the wall and the grab bar 38mm** : Yes (Rating: 1)

**Measurement  
(mm)** : 45

**45. Is there a grab bar at least 915mm long on the rear wall?** : No (Rating: 0)

**Measurement  
(mm)** : 590

**Recommendations** : replace with a grab bar that meets or exceeds the standard

**Improvement Priority** : Med

**Estimated Cost** : Low

**46. Does the grab bar extend at least 305mm from the centerline of the toilet on one side (side wall)? : No (Rating: 0)**

**Measurement (mm) : 295**

**47. Does the grab bar extend at least 610mm on the other (open) side? : No (Rating: 0)**

**Measurement (mm) : 295**

**48. Is the grab bar mounted no less than 840mm and no greater than 915mm above the floor to the top of the gripping surface? : No (Rating: 0)**

**Measurement (mm) : 830**

**Recommendations : install the grab bar at a height that is between the standards set**

**Improvement Priority : Med**

**Estimated Cost : Low**

**49. Are there at least 305mm clearance between the grab bar and protruding objects above? : N\_A (Rating: 0)**

**50. Are there at least 38mm clearance between the grab bar and projecting objects below? : Yes (Rating: 1)**

**Measurement (mm) : 160**

**51. Is the space between the wall and the grab bar 38mm inches? : Yes (Rating: 1)**

**Measurement (mm) : 40**

#### **Toilet flush controls**

**52. If the flush control is hand operated, is the operable part located no higher than 1220mm above the floor? : Yes (Rating: 1)**

**Measurement (mm) : 570**

**53. If the flush control is hand operated, can it be operated with one hand and without tight grasping, pinching, or twisting of the wrist? : Yes (Rating: 1)**

**54. Is the force required to activate the flush control no greater than 2.3kg? : Yes (Rating: 1)**

**Measurement (kg) : 4**

**55. Is the flush control on the open side of the toilet? : No (Rating: 0)**

**Toilet paper dispenser**

**56. Is the toilet paper dispenser located no less than 180mm and no greater than 230mm from the front of the toilet to the center line of the dispenser? : No (Rating: 0)**

**Measurement  
(mm) : 0**

**Comments/Description : right beside**

**57. Is the outlet of the dispenser: Located no less than 380mm and no greater than 1220mm above the floor? : Yes (Rating: 1)**

**Measurement  
(mm) : 1030**

**58. Is the dispenser located behind grab bars? : No (Rating: 0)**

**59. Does the dispenser allow continuous paper flow? : Yes (Rating: 1)**

**Sink**

**60. Does at least one sink have a clear floor space for a forward approach at least 760mm wide and 1220mm long? : Yes (Rating: 1)**

**Measurement  
(mm x mm) : 1520**

**Comments/Description : more than 1500**

**61. Do no less than 430mm and no greater than 635mm of the clear floor space extend under the sink so that a person using a wheelchair can get close enough to reach the faucet? : Yes (Rating: 1)**

**Measurement  
(mm) : 465**

**62. Is the front of the sink or counter surface, whichever is higher, no more than 865mm above the floor? : Yes (Rating: 1)**

**Measurement  
(mm) : 790**

**Recommendations : lower sink and counter to within standards**

**Improvement Priority : Med**

**Estimated Cost : Med**

**63. Is there at least 685mm height clearance from the floor to the bottom of the sink that extends at least 205mm deep under the sink for knee clearance? : Yes (Rating: 1)**

**Height  
(mm) : 700**



**Depth**  
**(mm) : 260**

**64. Is there toe clearance at least 230mm high?**

**Note: Space extending greater than 150mm beyond the available toe clearance at 230mm above the floor is not considered toe clearance. : Yes (Rating: 1)**

**Measurement**  
**(mm) : 340**

**65. Are pipes below the sink insulated or otherwise configured to protect against contact? : Yes (Rating: 1)**

**66. Can the faucet be operated without tight grasping, pinching, or twisting of the wrist? : Yes (Rating: 1)**

**67. Is the force required to activate the faucet no greater than 2.3 kg? : Yes (Rating: 1)**

**Comments/Description : easy push lever that slowly turns itself off**

#### **Washroom fixtures**

**68. Is there a clear path to at least one of each type of fixture, e.g. sink, hand dryer, garbage bin etc., that is at least 915mm wide? : Yes (Rating: 1)**

**Measurement**  
**(mm) : 1530**

**69. Is there clear floor space available for a person in a wheelchair to turn around, i.e. a circle at least 1525mm in diameter or a T-shaped space within a 1525mm square? : Yes (Rating: 1)**

**Measurement**  
**(mm) : 1530**

#### **Mirror**

**70. If the mirror is over a sink or countertop, is the bottom edge of the reflecting surface no higher than 1015mm above the floor?**

**Or : Yes (Rating: 1)**

**Measurement**  
**(mm) : 938**

**Comments/Description : no mirrors**

**71. If the mirror is not over the sink or countertop, is the bottom edge of the reflecting surface no higher than 890mm above the floor? : N\_A (Rating: 0)**

#### **Coat hook**

**72. If there is a coat hook, is it no less than 380mm and no greater than 1220mm above the floor?\* : No (Rating: 0)**

**Measurement**

**(mm) : 1480**

**Comments/Description : no coat hook**

**Recommendations : lower the hook to within standards**

**Improvement Priority : Med**

**Estimated Cost : Low**

**Soap dispenser**

**Are the operable parts of the soap dispenser within one of the following reach ranges:**

**73. Above sinks or counters no less than 510mm and no greater than 635mm deep: no higher than 1120mm above the floor?**

**Or : N\_A (Rating: 0)**

**Comments/Description : no soap dispenser**

**74. Above sinks less than 510mm deep: no higher than 1220mm above the floor?**

**Or : N\_A (Rating: 0)**

**75. Not over an obstruction: no higher than 1220mm above the floor? : N\_A (Rating: 0)**

**Hand dryer/Towel dispenser**

**Are the operable parts of the hand dryer or towel dispenser within one of the following reach ranges:**

**76. Above sinks or counters no less than 510mm and no greater than 635mm deep: no higher than 1120mm above the floor?**

**Or : N\_A (Rating: 0)**

**Comments/Description : no paper towel dispenser or blow dryer**

**77. Above sinks less than 510mm deep: no higher than 1220mm above the floor?**

**Or : N\_A (Rating: 0)**

**78. Not over an obstruction: no higher than 1220mm above the floor? : Yes (Rating: 1)**

**Measurement**

**(mm) : 940**

**79. Can the operable parts of the hand dryer or towel dispenser be operated without tight grasping, pinching or twisting of the wrist? : Yes (Rating: 1)**

**Comments/Description : automatic sensor**

**80. Is the force required to activate the hand dryer or towel dispenser no greater than 2.3kg? : Yes (Rating: 1)**

**Comments/Description** : automatic sensor

**Controls - light switches**

**81. Is there a clear floor space at least 760mm wide by at least 1220mm long for a forward or parallel approach?** : N\_A (Rating: 0)

**Comments/Description** : motion sensor turns the light on when someone enters

**82. Are the operable parts no higher than 1220mm above the floor?** : N\_A (Rating: 0)

**83. Can the control be operated with one hand and without tight grasping, pinching, or twisting of the wrist?** : N\_A (Rating: 0)

**Additional comments regarding assessment:** : Access route is steep at 8 to 10 degrees running slope coming up from the beach or down from the parking lot. It is almost 2 meters wide, paved and in moderate condition



**Description of Photo 1** : Path from the beach



**Description of Photo 2** : Sinks in the change room washroom building



**Description of Photo 3** : Path from the parking lot to the beach. The accessible washroom is halfway down.

Camping

**Date of Audit (YYYY-MM-DD)** : 2016-08-08

**Name of Campground** : Bear Lake Campground

**Location of Campsite** : west side of Highway 97 north of Prince George, south of Mackenzie

**Weather condition during audit** : Cloudy



**1. Does the number of accessible camp sites comply with the table above? :** No\_ \_Below\_Standard (Rating: 0)

**Comments/Description :** there are no designated accessible campsites

### Campsite

**2. Is the camp site surface firm and stable? :** Yes (Rating: 1)

**Comments/Description :** primarily packed gravel

**3. What type of surface is in the campsite? :** Gravel

**4. Is the accessible campsite at least 4.9m wide?**

**Or :** N\_A (Rating: 0)

**5. If it is an RV site, is the parking area at least 6m wide? :** N\_A (Rating: 0)

**6. If the campsite surface is concrete or asphalt, is the slope 1° or less? :** N\_A (Rating: 0)

**7. If the campsite surface is anything other than concrete & asphalt, is the slope 3° or less? :** Yes\_ \_Meets\_Standard (Rating: 1)

**Comments/Description :** 1' or less

### Tent Pads/Platforms

**8. Is there a minimum of 1220mm clear space on all sides surrounding the tent pad or platform? :** N\_A (Rating: 0)

**9. What type of surface is the tent pad/ platform? :** Gravel

**10. What is the slope of the tent pad/ platform? :** Flat\_Gentle\_1\_or\_less

**11. Is there an accessible entrance or ramp on to the tent pad/platform? :** No (Rating: 0)

### Utility & Sewage Hook Ups

**12. Is there sufficient clear ground space, a minimum of 1220mm x 1525mm surrounding the hook ups? :** N\_A (Rating: 0)

**13. If there are operable parts, can they be operated using one hand, without tightly grasping, pinching, or twisting the wrist and with no more than 2.3kg of force? : N\_A (Rating: 0)**

### **Campfires & Grills**

**14. Is there an area for campfires? : Yes (Rating: 1)**

**15. Is there a minimum of 1220mm clear ground space on all sides? : No\_-\_Below\_Standard (Rating: 0)**

**16. Is the slope 3° or less in all directions? : Yes (Rating: 1)**

### **Measurement**

**(angle °) : 1 to 2**

**17. Is the grill height between 380mm - 865mm above the ground? : N\_A (Rating: 0)**

**Comments/Description : metal ring with welded on grill**

**18. Is the fire building surface height at least 230mm above the ground? : N\_A (Rating: 0)**

**19. If there is a raised edge or wall around the fire building area, is the thickness less than 255mm? : Yes (Rating: 1)**

### **Measurement**

**(mm) : 5**

**Comments/Description : thick metal**

**20. Is there a clear, level accessible route to the campfire area? : Yes (Rating: 1)**

**21. Are picnic tables provided? : Yes (Rating: 1)**

**22. How many accessible picnic tables are there? : N\_A**

**Comments/Description : none**

**23. If the picnic table is up to 2.7m long, is there one wheelchair seating space? : N\_A (Rating: 0)**

**24. If the picnic table is longer than 2.7m, are there at least two wheelchair spaces provided? : N\_A (Rating: 0)**

**25. Is there clear and level ground space, 915mm measured from back edge of seats/benches? : N\_A (Rating: 0)**

**26. Do the accessible spaces have adequate knee clearance, 685mm high x 760mm wide x 430mm deep? : N\_A (Rating: 0)**

**27. Is the ground surface surrounding the accessible picnic table firm and stable? : N\_A (Rating: 0)**

**28. Is there a clear, level accessible route to the picnic table? : N\_A (Rating: 0)**

### **Water Taps**

**1. Are there any water taps? : Yes (Rating: 1)**

**2. Is there sufficient clear ground space, a minimum of 1829mm x 1220mm surrounding the water tap? :  
Yes - Meets Standard (Rating: 1)**

**3. Is the water spout height between 280mm - 305mm? : Yes (Rating: 1)**

**Measurement  
(mm) : 300**

**4. Is the height of operable parts (i.e. taps or levers) between 380mm - 1220mm above the ground? : No  
(Rating: 0)**

**Measurement  
(mm) : 315**

**Recommendations : raise the tap**

**Improvement Priority : Med**

**Estimated Cost : Med**

**5. If there are operable parts, can they be operated using one hand, without tightly grasping, pinching, or  
twisting the wrist and with no more than 2.3kg of force? : No (Rating: 0)**

**Recommendations : change tap accordingly**

**Improvement Priority : Med**

**Estimated Cost : Med**

**6. Is there a clear, level accessible route to the water tap? : Yes (Rating: 1)**

### **Water Fountains**

**1. Is there a water fountain? : No (Rating: 0)**

**2. Does it have a lever or push bar control on the front or both sides? : N\_A (Rating: 0)**

**3. Is the spout opening height between 750mm - 915mm above the ground? : N\_A (Rating: 0)**

**4. Is there a minimum width of 800mm clearance space directly in front of the water fountain? : N\_A  
(Rating: 0)**

**5. Is there a clear, level accessible route to the water fountain? : N\_A (Rating: 0)**

### **Trash & Recycling Receptacles**

**1. Are there any trash &/or recycling receptacles? : Yes (Rating: 1)**

**2. Is the approach to the receptacle level, with no-step? : Yes (Rating: 1)**

**3. If there are operable parts, is their height between 380mm - 1220mm above the ground? : Yes (Rating:  
1)**

**Measurement****(mm) : 960****Comments/Description** : bear proof**4. If there are operable parts, can they be operated using one hand, without tightly grasping, pinching, or twisting the wrist and with no more than 2.3kg of force?** : No (Rating: 0)**5. Is there a clear, level accessible route to the trash/recycling receptacle?** : Yes (Rating: 1)**Shelters****1. Are there any camp shelters?** : No (Rating: 0)**2. What is the slope at the entrance to the camp shelter?** : N\_A (Rating: 0)**3. What type of surface is in the camp shelter?** : N\_A**4. Is the shelter surface firm and stable?** : N\_A (Rating: 0)**5. Is there a clear, level accessible route to the camp shelter?** : N\_A (Rating: 0)**Benches****1. Are any benches provided?** : No (Rating: 0)**2. If yes, how many benches are there?** : N\_A**3. Is the bench seat height between 485mm - 510mm?** : N\_A (Rating: 0)**4. Is there a minimum of 915mm x 1220mm clear ground space beside the bench?** : N\_A (Rating: 0)**5. Is there a clear, level accessible route to the bench?** : N\_A (Rating: 0)**Playground****1. Is there a playground?** : Yes (Rating: 1)**Comments/Description** : There are several different play structures through out the park and campground**2 What type of surface is in the play area?** : Sand**3. Is the play area surface firm and stable?** : No (Rating: 0)**4. Are any of the playground components accessible to wheelchair users? If yes, please describe.** : No (Rating: 0)**5. Is there a clear, level accessible route to the playground?** : Yes (Rating: 1)**Comments/Description** : but only to the edge, once the sand starts I doubt wheelchairs could go in**Amphitheatre**

**1. Is there an amphitheatre? : No (Rating: 0)**

### **Amphitheatre Seating**

**2. Are an adequate number of wheelchair spaces provided? : N\_A (Rating: 0)**

**3. Are wheelchair spaces dispersed to allow location choices and viewing angles equivalent to other seating, including specialty seating areas that provide distinct services and amenities? : N\_A (Rating: 0)**

**4. Where people are expected to remain seated, do people in wheelchair spaces have a clear line of sight over and between the heads of others in front of them? : N\_A (Rating: 0)**

**5. Where people are expected to stand, do people in wheelchair spaces have a clear line of sight over and between the heads of others in front of them? : N\_A (Rating: 0)**

**6. If there is a single wheelchair space, is it at least 915mm wide? : N\_A (Rating: 0)**

**7. If there are two adjacent wheelchair spaces, are they each at least 840mm wide? : N\_A (Rating: 0)**

**8. If the wheelchair space can be entered from the front or rear, is it at least 1220mm deep? : N\_A (Rating: 0)**

**9. If the wheelchair space can only be entered from the side, is it at least 1525mm deep? : N\_A (Rating: 0)**

**10. Do wheelchair spaces adjoin, but not overlap, accessible routes? : N\_A (Rating: 0)**

**11. Is there at least one companion seat for each wheelchair space? : N\_A (Rating: 0)**

**12. Is the companion seat located so the companion is shoulder-to-shoulder with the person in a wheelchair? : N\_A (Rating: 0)**

**13. Is the companion seat equivalent in size, quality, comfort and amenities to seating in the immediate area? : N\_A (Rating: 0)**

**2. Are there any public buildings (visitors centre/ interpretive centre/cafes etc) at the campground? : No (Rating: 0)**

**3. Are there any trails at the campground? : No (Rating: 0)**

**4. Is there a beach, dock/fishing platform or boat launch? : Yes -  
\_WATER\_ACCESS\_checklist\_must\_also\_be\_completed (Rating: 0)**

**Additional comments regarding assessment:** : This is a wilderness campground with some amenities. The sites are not wheelchair accessible but there are washrooms that are. All of the washrooms have problems with access, see comments on the washroom check list please. The play structures are a pleasant surprise. Not one of them is wheelchair accessible, however, they are imaginative and creatively designed. A young, agile family would enjoy them immensely.





**Description of Photo 1 : Play structure in sand****Description of Photo 2 : Play structure at the campground, note the barriers of a high curb and sand.****Description of Photo 3 : Typical table near the beach**

Water Access

**Date of Audit :** 2016-08-08

**Body of water :** Lake

**Location :** Beach on Bear Lake at Crooked River Provincial Park

**Weather condition during audit :** Cloudy



**2. Are an adequate number of accessible spaces provided? :** N\_A (Rating: 0)

**Comments/Description :** paved, no designated spots

**Recommendations :** pick spots and mark with sign

**Improvement Priority :** Med

**Estimated Cost :** Med

**3. Of the accessible spaces, is at least one a van accessible space?\* :** N\_A (Rating: 0)

**4. Are accessible spaces at least 2.4m wide with an access aisle at least 1.5m wide? Note: Two spaces may share an access aisle. :** N\_A (Rating: 0)

**5. Are the access aisles marked to discourage parking in them? :** N\_A (Rating: 0)

**6. Is the slope of the accessible parking spaces and access aisles no steeper than 1Â° in all directions? :** N\_A (Rating: 0)

**7. Does the access aisle adjoin an accessible route? :** N\_A (Rating: 0)

**8. Are accessible spaces identified with a sign that includes the International Symbol of Accessibility? Note: The International Symbol of Accessibility is not required on the ground. :** N\_A (Rating: 0)

**9. Of the total parking spaces, are the accessible spaces located on the closest accessible route to the accessible entrance(s)? Note: If parking serves multiple entrances, accessible parking should be dispersed. :** N\_A (Rating: 0)

**From :** parking lot

**To :** beach area

**2. What is the condition of the surface along this route? :** Moderate (Rating: 1)

**4. What is the type of surface? :** Asphalt

**Comments/Description :** and some gravel paths

**Clear Width**

**5. What is the typical route width (mm)? :** More\_than\_1525 (Rating: 0)

**6. What is the narrowest route width (mm)? :** between\_1220\_-915 (Rating: 1)

**Comments/Description :** cracks and tree roots

**Recommendations :** budget for repair or repave

**Improvement Priority :** Med

**Estimated Cost :** Med

**Comments/Description :** tree roots, puddles, pea gravel

**Openings**

**11. Are there any gaps or grates present that have an opening greater than 13mm? :** No (Rating: 0)

**12. If gaps/grates are present, do they run perpendicular to the path of travel? :** No (Rating: 0)

**14. What is the maximum running slope on the route? :** Very\_steep\_above\_5 (Rating: 0)

**Comments/Description :** the path from the parking lot to the beach was 7 to 8 degrees

**Recommendations :** consider switch backs

**Improvement Priority : Med**

**Estimated Cost : High**

### **Resting Intervals**

**17. Are there resting intervals at the top and bottom of a route where the grade exceeds 3°? : No (Rating: 0)**

**18. If the running slope is greater than 3°, are there resting intervals in the middle of the route when the length exceeds 9.1m? : No (Rating: 0)**

### **Benches**

**21. Are there any benches along the route? : No (Rating: 0)**

**22. If yes, are the benches located approximately every 61m? : N\_A (Rating: 0)**

**23. Is the bench seat height between 485mm - 510mm? : N\_A (Rating: 0)**

### **Ramps**

**24. Is there is a ramp? : No (Rating: 0)**

**25. Is the ramp at least 915mm wide?**

**Note: If there are handrails, measure between the handrails. : N\_A (Rating: 0)**

**26. Is the surface stable, firm and slip resistant? : N\_A (Rating: 0)**

**27. For each section of the ramp, is the running slope no greater than 5°?**

**Note: Rises no greater than 76mm with a slope no steeper than 7° and rises no greater than 150mm with a slope no steeper than 6° are permitted when due to space limitations. : N\_A (Rating: 0)**

**28. Is there a level landing that is at least 1525mm long and at least as wide as the ramp: At the top of the ramp? : N\_A (Rating: 0)**

**29. At the bottom of the ramp? : N\_A (Rating: 0)**

**30. Is there a level landing where the ramp changes direction that is at least 1525mm x 1525mm? : N\_A (Rating: 0)**

**31. If the ramp has a rise higher than 150mm are there handrails on both sides? : N\_A (Rating: 0)**

**32. Is the top of the handrail gripping surface no less than 865mm and no greater than 965mm above the ramp surface? : N\_A (Rating: 0)**

**33. Is the handrail gripping surface continuous and not obstructed along the top or sides? : N\_A (Rating: 0)**

**34. If there are obstructions, is the bottom of the gripping surface obstructed no more than 20%? : N\_A (Rating: 0)**

## Stairs

35. Are there floors or surfaces connected only by stairs, not an elevator or ramp? : No (Rating: 0)
36. How many flights of stairs are there? : 1
37. If there are less than a flight, how many stairs are there? : N\_A
38. Do all stair treads have a horizontal strip at the edge that is: 40mm-60mm deep, colour contrasted & extends the full width of the step? : N\_A (Rating: 0)
39. If the stairs are not enclosed, is there a tactile warning system present at the landing of entrance to stairs system? : N\_A (Rating: 0)
40. Are there handrails on both sides of the stairs at a uniform height of 860mm-920mm above the front step? : N\_A (Rating: 0)
41. Do the handrails extend horizontally at the top and bottom of each flight of stairs? : N\_A (Rating: 0)
42. Are the handrails continuous around landings? : N\_A (Rating: 0)
43. Are the handrails continuously graspable, without interruption by vertical supports, newel posts, or other construction elements which require repositioning the hands while ascending or descending? : N\_A (Rating: 0)
44. Do the handrails have a graspable cross-section that is either circular with an outside diameter of 30mm-40mm or elliptical with an outside perimeter of 100mm-125mm? : N\_A (Rating: 0)
2. What type of surface is the beach area? : Sand

## Measurement (m) : 45

4. Is there a clear route to the water edge that is: at least 915mm wide, level and has a firm/stable surface? : No (Rating: 0)

## Dock/Fishing Platform

1. Is there a dock or fishing platform? : No (Rating: 0)
2. For each section of the gangway, is the running slope no greater than 5°? : N\_A (Rating: 0)
3. Is the gangway at least 9.1m long? : N\_A (Rating: 0)
4. If a transition plate is steeper than 3°, is there a landing at the end of the transition plate? : N\_A (Rating: 0)
5. Are there any gaps or grates present that have an opening greater than 13mm? : No (Rating: 0)
6. If gaps/grates are present, do they run perpendicular to the path of travel? : N\_A (Rating: 0)
7. If there are railings/guards/handrails on the dock/fishing platform, are at least 25% accessible with no more than 865mm above the ground or deck? : N\_A (Rating: 0)

8. Are the accessible railings dispersed throughout the dock/fishing platform? : N\_A (Rating: 0)
9. Is there a clear space at least 1220mm long x 760mm wide at the accessible railing? : N\_A (Rating: 0)
10. Is there a curb or barrier extending 51mm minimum above the surface of the dock/fishing platform? : N\_A (Rating: 0)
11. If there are no railings, is there a clear space at least 1220mm long x 760mm wide on the dock/fishing platform surface? : N\_A (Rating: 0)
12. Is there a clear space for a person in a wheelchair to turn around, i.e. a circle at least 1525mm in diameter? : N\_A (Rating: 0)

### Boat Launch

1. Is there a boat launch? : No (Rating: 0)
4. What type of surface is the boat launch? : N\_A
5. Is the boat launch surface firm and stable? : N\_A (Rating: 0)
6. Is there a clear, level accessible route to the boat launch? : N\_A (Rating: 0)
2. How many accessible picnic tables are there? : N\_A

**Comments/Description** : no accessible tables were found at this site

**Recommendations** : Install a few accessible tables in conjunction with connecting path and pad

**Improvement Priority** : Med

**Estimated Cost** : Med

3. If the picnic table is up to 2.7m long, is there one wheelchair seating space? : N\_A (Rating: 0)
4. If the picnic table is longer than 2.7m, are there at least two wheelchair spaces provided? : N\_A (Rating: 0)
5. Is there clear and level ground space, 915mm measured from back edge of seats/benches? : N\_A (Rating: 0)
6. Do the accessible spaces have adequate knee clearance, 685mm high x 760mm wide x 430mm deep? : N\_A (Rating: 0)
7. Is the ground surface surrounding the accessible picnic table firm and stable? : N\_A (Rating: 0)
8. Is there a clear, level accessible route to the picnic table? : N\_A (Rating: 0)

### Shelters

1. Are there any camp shelters? : No (Rating: 0)
2. What is the slope at the entrance to the camp shelter? : N\_A (Rating: 0)

**3. What type of surface is in the camp shelter? : N\_A**

**4. Is the shelter surface firm and stable? : N\_A (Rating: 0)**

**5. Is there a clear, level accessible route to the camp shelter? : N\_A (Rating: 0)**

#### **Benches**

**1. Are any benches provided? : No (Rating: 0)**

**2. If yes, how many benches are there? : N\_A**

**3. Is the bench seat height between 485mm - 510mm? : N\_A (Rating: 0)**

**4. Is there a minimum of 915mm x 1220mm clear ground space beside the bench? : N\_A (Rating: 0)**

**5. Is there a clear, level accessible route to the bench? : N\_A (Rating: 0)**

#### **Trash & Recycling Receptacles**

**1. Are there any trash &/or recycling receptacles? : No (Rating: 0)**

**Measurement  
(mm) : 950**

**Comments/Description : bear proof**

#### **Campfires & Grills**

**1. Is there an area for campfires? : No (Rating: 0)**

**2. Is there a minimum of 1220mm clear ground space on all sides? : N\_A (Rating: 0)**

**3. Is the slope 3° or less in all directions? : N\_A (Rating: 0)**

**4. Is the grill height between 380mm - 865mm above the ground? : N\_A (Rating: 0)**

**5. Is the fire building surface height at least 230mm above the ground? : N\_A (Rating: 0)**

**6. If there is a raised edge or wall around the fire building area, is the thickness less than 255mm? : N\_A  
(Rating: 0)**

**7. Is there a clear, level accessible route to the campfire area? : N\_A (Rating: 0)**

**2 What type of surface is in the play area? : Sand**

**3. Is the play area surface firm and stable? : No (Rating: 0)**

**Recommendations : ideally the play surface at least should be an accessible one such as recycled rubber that is flush with the connecting path**

**Improvement Priority : Med**

**Estimated Cost :** High

**4. Are any of the playground components accessible to wheelchair users? If yes, please describe. :** No  
(Rating: 0)

**Comments/Description :** loose dry sand

**5. Is there a clear, level accessible route to the playground? :** No (Rating: 0)

**Comments/Description :** across sand gravel and grass

**Recommendations :** need packed level path that connects all the elements

**Improvement Priority :** Med

**Estimated Cost :** Med

**Additional comments regarding assessment :** the beach is lovely, the tables look over the beach but it is not a wheel chair accessible site due to the lack of a connecting path. There is another interesting play structure here, but again, sand makes it difficult from an accessibility stand point. The day use and beach areas are great for families. A little packing and firming on the unpaved paths, particularly to the washrooms, would improve the ability to draw the mobility challenged into attendance.



**Description of Photo 1 :** Typical path paralleling beach



**Description of Photo 2 :** Playground above the beach, needs a connecting path and accessible play surface.



**Description of Photo 3 :** Path from beach to change house washroom and parking lot



**Description of Photo 4 :** Typical table on the path above the beach

Goods and Services