

Mt Robson Visitors Centre ▼

Information

Date of Audit: 2016-08-30

Park Name: Forest Rose Campground

Key Features: Camping,Picnic\_Site

Location: Cariboo, Quesnel, Cariboo Chilcotin Coast - Regional : Campground (Heritage Discovery Circle Route)

Description:

Parking

Access Routes

Trails

Washrooms

**Date of Audit** : 2016-08-30

**Auditors Names** : Ryan

**Weather condition during audit** : Sunny

**Description of washroom location** : n/a

**Type of Washroom** : Out-house

**1. If washrooms are available to the public, is at least one washroom designated as accessible? (Either one for each sex, or one unisex.)** : Yes (Rating: 1)

**Directional signage**

**2. Are there signs at inaccessible washrooms that give directions to accessible washrooms?** : No (Rating: 0)

**3. Is there an accessible route to the accessible washroom?** : Yes (Rating: 1)

**4. If not all washrooms are accessible, is there a sign at the accessible washroom with the International Symbol of Accessibility?** : Yes (Rating: 1)

**6. Are text characters raised?** : No (Rating: 0)

**7. Is there Braille?** : No (Rating: 0)

**8. Is the sign mounted on the wall, on latch side of the door?**

**Note: Signs are permitted on the push side of doors with closers and without hold-open devices.** : No (Rating: 0)

**Comments/Description** : mounted on the door.

**9. So the baseline of the lowest character is at least 1220mm above the floor and the baseline of the highest character is no more than 1525mm above the floor?**

**Note: If the sign is at double doors with one active leaf, the sign should be on the inactive leaf; if both leaves are active, the sign should be on the wall to the right of the right leaf.** : Yes (Rating: 1)

**Measurement****(mm) : 1460****Interior doors****10. Is the door opening width at least 815mm clear, between the face of the door and the stop, when the door is open 90°? : Yes (Rating: 1)****Measurement****(mm) : 830****11. If there is a front approach to the pull side of the door, is there at least 455mm of maneuvering clearance beyond the latch side plus at least 1525mm clear depth? : N\_A (Rating: 0)****12. On both sides of the door, is the floor surface of the maneuvering clearance level (no steeper than 1°)? : Yes (Rating: 1)****Measurement****(angle °) : 1****14. If the threshold is beveled, is it no more than 19mm high? : No (Rating: 0)****Measurement****(mm) : 20****Comments/Description : 20mm lip at door entrance****15. Is the door equipped with hardware that is operable with one hand and does not require tight grasping, pinching or twisting of the wrist? : N\_A (Rating: 0)****16. Are the operable parts of the hardware no less than 865mm and no greater than 1220mm above the floor? : N\_A (Rating: 0)****17. Can the door be opened easily, maximum 2.3kg of force?****Note: You can use a pressure gauge or fish scale to measure force. : No (Rating: 0)****Measurement****(kg) : 3****18. If the door has a closer, does it take at least 5 seconds to close from open position of 90° to a position of 12° from the latch? : No (Rating: 0)****Measurement****(seconds) : 3****19. If there are two doors in a series, e.g. vestibule, is the distance between the doors at least 1220mm plus the width of the doors when swinging into the space? : N\_A (Rating: 0)****20. If there is a privacy wall and the door swings out, is there at least 610mm of maneuvering clearance beyond the door latch side and 1065mm to the privacy wall? : N\_A (Rating: 0)****21. If there is a privacy wall and the door swings in, is there at least 610mm of maneuvering clearance beyond the door latch side and at least 1220mm to the privacy wall if there is no door closer or at least**

**1370mm if there is a door closer? : N\_A (Rating: 0)**

**22. In a unisex washroom if the door swings in and over a clear floor space at an accessible fixture, is there a clear floor space at least 760mm x 1220mm beyond the swing of the door? : N\_A (Rating: 0)**

### **Toilet stall**

**23. Is there an individual accessible toilet stall? : Yes (Rating: 1)**

**24. Is the stall door opening width at least 815mm clear, between the face of the door and the stop, when the door is open 90°? : Yes (Rating: 1)**

**Measurement  
(mm) : 830**

**25. If there is a front approach to the pull side of the stall door, is there at least 455mm of maneuvering clearance beyond the latch side plus 1525mm clear depth? : No (Rating: 0)**

**Clearance  
(mm) : 2180**

**Depth  
(mm) : 1080**

**Comments/Description : 1080d x 2180w**

**26. Is the door self-closing? : Yes (Rating: 1)**

**27. Are there door pulls on both sides of the door that are operable with one hand and do not require tight grasping pinching or twisting of the wrist?\* : Yes (Rating: 1)**

**28. Is the lock operable with one hand and without tight grasping, pinching or twisting of the wrist? : Yes (Rating: 1)**

**29. Are the operable parts of the door hardware mounted no less than 865mm and no greater than 1220mm above the floor? : Yes (Rating: 1)**

**Measurement  
(mm) : 960**

**Comments/Description : 960mm to bottom of large D handle. 1380mm to turn lock latch inside of the door.**

**30. Is the stall at least 1525mm wide? : Yes (Rating: 1)**

**Measurement  
(mm) : 2210**

**Comments/Description : 2210mm from toilet side of wall to the sinks edge.**

**31. If the toilet is wall hung, is the stall at least 1420mm deep?**

**Or : N\_A (Rating: 0)**

**32. If the toilet is floor mounted, is the stall at least 1500mm deep? : Yes (Rating: 1)**

**Measurement  
(mm) : 1890**

**If the door swings in, is the stall area beyond the swing of the door:**

**33. A minimum of 1525mm wide x 1420mm deep for wall hung toilet?**

**Or : No (Rating: 0)**

**34. A minimum of 1525mm wide x 1500mm deep for floor mounted toilet? : N\_A (Rating: 0)**

**Toilet**

**35. Is the centerline of the toilet no less than 405mm and no greater than 455mm from the side wall or partition? : No (Rating: 0)**

**Measurement  
(mm) : 550**

**36. Is clearance provided around the toilet measuring at least 1525mm from the side wall and at least 1420mm from the rear wall? : Yes (Rating: 1)**

**From side wall  
(mm) : 1890**

**From rear wall  
(mm) : 2210**

**37. Is the height of the toilet no less than 430mm and no greater than 485mm above the floor measured to the top of the seat? : Yes (Rating: 1)**

**Measurement  
(mm) : 470**

**Grab bars**

**38. Is there a grab bar at least 1065mm long on the side wall? : No (Rating: 0)**

**Measurement  
(mm) : 610**

**Comments/Description : grab bar is angled upwards**

**39. Is it located no more than 305mm from the rear wall? : Yes (Rating: 1)**

**Measurement  
(mm) : 605**

**40. Does it extend at least 1370mm from the rear wall? : No (Rating: 0)**

**Comments/Description : 605 botton of grab bar 1130 top of grab bar**

**41. Is it mounted no less than 840mm and no greater than 915mm above the floor to the top of the**

**gripping surface?** : No (Rating: 0)

**Comments/Description** : 750 bottom 1055 top

**42. Is there at least 305mm clearance between the grab bar and protruding objects above?** : Yes (Rating: 1)

**Comments/Description** : 400mm from bottom of the grab bar.

**43. Is there at least 38mm clearance between the grab bar and projecting objects below?** : N\_A (Rating: 0)

**44. Is the space between the wall and the grab bar 38mm** : Yes (Rating: 1)

**Measurement  
(mm)** : 45

**45. Is there a grab bar at least 915mm long on the rear wall?** : No (Rating: 0)

**Measurement  
(mm)** : 615

**46. Does the grab bar extend at least 305mm from the centerline of the toilet on one side (side wall)?** : No (Rating: 0)

**Measurement  
(mm)** : 290

**47. Does the grab bar extend at least 610mm on the other (open) side?** : No (Rating: 0)

**Measurement  
(mm)** : 325

**48. Is the grab bar mounted no less than 840mm and no greater than 915mm above the floor to the top of the gripping surface?** : Yes (Rating: 1)

**Measurement  
(mm)** : 915

**49. Are there at least 305mm clearance between the grab bar and protruding objects above?** : N\_A (Rating: 0)

**50. Are there at least 38mm clearance between the grab bar and projecting objects below?** : Yes (Rating: 1)

**Measurement  
(mm)** : 130

**51. Is the space between the wall and the grab bar 38mm inches?** : Yes (Rating: 1)

**Measurement  
(mm)** : 45

#### **Toilet flush controls**

**52. If the flush control is hand operated, is the operable part located no higher than 1220mm above the floor?** : Yes (Rating: 1)

**Measurement****(mm) : 725**

**53. If the flush control is hand operated, can it be operated with one hand and without tight grasping, pinching, or twisting of the wrist? : Yes (Rating: 1)**

**54. Is the force required to activate the flush control no greater than 2.3kg? : Yes (Rating: 1)**

**Measurement****(kg) : 4**

**55. Is the flush control on the open side of the toilet? : Yes (Rating: 1)**

**Toilet paper dispenser**

**56. Is the toilet paper dispenser located no less than 180mm and no greater than 230mm from the front of the toilet to the center line of the dispenser? : No (Rating: 0)**

**Comments/Description** : dispenser is to far back, refer to picture for example.

**57. Is the outlet of the dispenser: Located no less than 380mm and no greater than 1220mm above the floor? : Yes (Rating: 1)**

**Measurement****(mm) : 1170**

**58. Is the dispenser located behind grab bars? : No (Rating: 0)**

**59. Does the dispenser allow continuous paper flow? : Yes (Rating: 1)**

**Sink**

**60. Does at least one sink have a clear floor space for a forward approach at least 760mm wide and 1220mm long? : Yes (Rating: 1)**

**Comments/Description** : 1480 from sink to outside edge of toilet 1890 from wall to shower stall.

**61. Do no less than 430mm and no greater than 635mm of the clear floor space extend under the sink so that a person using a wheelchair can get close enough to reach the faucet? : Yes (Rating: 1)**

**Measurement****(mm) : 565**

**Comments/Description** : 565 from wall to sinks edge.

**62. Is the front of the sink or counter surface, whichever is higher, no more than 865mm above the floor? : Yes (Rating: 1)**

**Measurement****(mm) : 835**

**63. Is there at least 685mm height clearance from the floor to the bottom of the sink that extends at least 205mm deep under the sink for knee clearance? : Yes (Rating: 1)**

**Height**  
**(mm) : 665**

**Depth**  
**(mm) : 370**

**64. Is there toe clearance at least 230mm high?**

**Note: Space extending greater than 150mm beyond the available toe clearance at 230mm above the floor is not considered toe clearance. : Yes (Rating: 1)**

**Measurement**  
**(mm) : 395**

**Comments/Description** : there is no insulated box so toe clearance is really good. see picture for example. 395mm from floor to bottom of pipe.

**65. Are pipes below the sink insulated or otherwise configured to protect against contact? : No (Rating: 0)**

**66. Can the faucet be operated without tight grasping, pinching, or twisting of the wrist? : Yes (Rating: 1)**

**Comments/Description** : lift handle

**67. Is the force required to activate the faucet no greater than 2.3 kg? : Yes (Rating: 1)**

**Comments/Description** : 2.3kg

#### **Washroom fixtures**

**68. Is there a clear path to at least one of each type of fixture, e.g. sink, hand dryer, garbage bin etc., that is at least 915mm wide? : Yes (Rating: 1)**

**Comments/Description** : they are all at the sink. see picture for example.

**69. Is there clear floor space available for a person in a wheelchair to turn around, i.e. a circle at least 1525mm in diameter or a T-shaped space within a 1525mm square? : Yes (Rating: 1)**

**Measurement**  
**(mm) : 1525**

**Comments/Description** : exactly 1525mm of clear floor space.

#### **Mirror**

**70. If the mirror is over a sink or countertop, is the bottom edge of the reflecting surface no higher than 1015mm above the floor?**

**Or : Yes (Rating: 1)**

**Measurement**  
**(mm) : 885**

**Comments/Description** : 885mm from floor to mirror 50mm from counter to bottom of the mirror.

**71. If the mirror is not over the sink or countertop, is the bottom edge of the reflecting surface no higher than 890mm above the floor? : N\_A (Rating: 0)**

#### **Coat hook**

**72. If there is a coat hook, is it no less than 380mm and no greater than 1220mm above the floor? : N\_A (Rating: 0)**

#### **Soap dispenser**

**Are the operable parts of the soap dispenser within one of the following reach ranges:**

**73. Above sinks or counters no less than 510mm and no greater than 635mm deep: no higher than 1120mm above the floor?**

**Or : No (Rating: 0)**

**Measurement  
(mm) : 190**

**Comments/Description** : 190mm from counter to bottom of the dispenser. 425mm from mirror side of wall to the inside of the dispenser.

**74. Above sinks less than 510mm deep: no higher than 1220mm above the floor?**

**Or : N\_A (Rating: 0)**

**75. Not over an obstruction: no higher than 1220mm above the floor? : N\_A (Rating: 0)**

#### **Hand dryer/Towel dispenser**

**Are the operable parts of the hand dryer or towel dispenser within one of the following reach ranges:**

**76. Above sinks or counters no less than 510mm and no greater than 635mm deep: no higher than 1120mm above the floor?**

**Or : No (Rating: 0)**

**Comments/Description** : 410mm from dispenser to edge of the counter. 1140mm from the floor to the bottom of the paper dispenser.

**77. Above sinks less than 510mm deep: no higher than 1220mm above the floor?**

**Or : N\_A (Rating: 0)**

**78. Not over an obstruction: no higher than 1220mm above the floor? : N\_A (Rating: 0)**

**79. Can the operable parts of the hand dryer or towel dispenser be operated without tight grasping, pinching or twisting of the wrist? : Yes (Rating: 1)**

**80. Is the force required to activate the hand dryer or towel dispenser no greater than 2.3kg? : Yes (Rating: 1)**

**Controls - light switches**

**81. Is there a clear floor space at least 760mm wide by at least 1220mm long for a forward or parallel approach? : Yes (Rating: 1)**

**Comments/Description : 1130 x1130**

**82. Are the operable parts no higher than 1220mm above the floor? : No (Rating: 0)**

**Measurement**

**(mm) : 1285**

**83. Can the control be operated with one hand and without tight grasping, pinching, or twisting of the wrist? : No (Rating: 0)**

**Comments/Description : its a twist dial.**

Camping

Water Access

Goods and Services