

Mt Robson Visitors Centre ▼

Information

Date of Audit: 2016-10-15

Park Name: Fulton River Spawning Channel

Key Features: View_Point,Picnic_Site,Trails

Location: Bulkley-Nechako, Smithers, Northern BC - Federal : Attraction (Heritage Discovery Circle Route)

Description: Fulton River Spawning Channel provides visitors with the opportunity to view spawning salmon and to learn about the salmon spawning enhancement program in this area. The site provides an accessible viewing area, accessible parking, an accessible washroom and 2 accessible picnic sites. There is also a second spawning channel area that provides a 2km accessible path around its perimeter. Interpretive information boards are also available on both channel sites. Benches have also been provided on both sites.

Parking

Access Routes

Trails

Washrooms

Date of Audit : 2016-10-15

Auditors Names : Barbara

Weather condition during audit : Cloudy

Washroom # : 1

Description of washroom location : Accessible washroom building located at the visitor parking area
Washroom building with separate M/F accessible washrooms (1 each, total of 2)

Type of Washroom : Washroom_Building



1. If washrooms are available to the public, is at least one washroom designated as accessible? (Either one for each sex, or one unisex.) : Yes (Rating: 1)

Comments/Description : 1 washroom building with 1 female, 1 male accessible washrooms

Directional signage

2. Are there signs at inaccessible washrooms that give directions to accessible washrooms? : No (Rating: 0)

3. Is there an accessible route to the accessible washroom? : Yes (Rating: 1)

4. If not all washrooms are accessible, is there a sign at the accessible washroom with the International Symbol of Accessibility? : No (Rating: 0)

5. Do text characters contrast with their backgrounds? : Yes (Rating: 1)

Comments/Description : white on dark grey

6. Are text characters raised? : No (Rating: 0)

7. Is there Braille? : No (Rating: 0)

8. Is the sign mounted on the wall, on latch side of the door?

Note: Signs are permitted on the push side of doors with closers and without hold-open devices. : Yes (Rating: 1)

Comments/Description : Sign mounted on push side of door with closer; no hold-open device on door

9. So the baseline of the lowest character is at least 1220mm above the floor and the baseline of the highest character is no more than 1525mm above the floor?

Note: If the sign is at double doors with one active leaf, the sign should be on the inactive leaf; if both leaves are active, the sign should be on the wall to the right of the right leaf. : Yes (Rating: 1)

Measurement (mm) : 1520

Interior doors

10. Is the door opening width at least 815mm clear, between the face of the door and the stop, when the door is open 90°? : N_A (Rating: 0)

Comments/Description : washroom building has door that opens directly to single washroom

11. If there is a front approach to the pull side of the door, is there at least 455mm of maneuvering clearance beyond the latch side plus at least 1525mm clear depth? : N_A (Rating: 0)

12. On both sides of the door, is the floor surface of the maneuvering clearance level (no steeper than 1°)? : N_A (Rating: 0)

13. If the threshold is vertical is it no more than 6mm high?

Or : N_A (Rating: 0)

14. If the threshold is beveled, is it no more than 19mm high? : N_A (Rating: 0)

15. Is the door equipped with hardware that is operable with one hand and does not require tight grasping, pinching or twisting of the wrist? : N_A (Rating: 0)

16. Are the operable parts of the hardware no less than 865mm and no greater than 1220mm above the floor? : N_A (Rating: 0)

17. Can the door be opened easily, maximum 2.3kg of force?

Note: You can use a pressure gauge or fish scale to measure force. : N_A (Rating: 0)

18. If the door has a closer, does it take at least 5 seconds to close from open position of 90° to a position of 12° from the latch? : N_A (Rating: 0)

19. If there are two doors in a series, e.g. vestibule, is the distance between the doors at least 1220mm plus the width of the doors when swinging into the space? : N_A (Rating: 0)

20. If there is a privacy wall and the door swings out, is there at least 610mm of maneuvering clearance beyond the door latch side and 1065mm to the privacy wall? : N_A (Rating: 0)

21. If there is a privacy wall and the door swings in, is there at least 610mm of maneuvering clearance beyond the door latch side and at least 1220mm to the privacy wall if there is no door closer or at least 1370mm if there is a door closer? : N_A (Rating: 0)

22. In a unisex washroom if the door swings in and over a clear floor space at an accessible fixture, is there a clear floor space at least 760mm x 1220mm beyond the swing of the door? : N_A (Rating: 0)

Toilet stall

23. Is there an individual accessible toilet stall? : Yes (Rating: 1)

24. Is the stall door opening width at least 815mm clear, between the face of the door and the stop, when the door is open 90°? : Yes (Rating: 1)

**Measurement
(mm) : 840**

25. If there is a front approach to the pull side of the stall door, is there at least 455mm of maneuvering clearance beyond the latch side plus 1525mm clear depth? : N_A (Rating: 0)

Comments/Description : door pushes open

26. Is the door self-closing? : Yes (Rating: 1)

Comments/Description : 4 seconds Door requires 1.5 kg of force to pull open

27. Are there door pulls on both sides of the door that are operable with one hand and do not require tight grasping pinching or twisting of the wrist?* : No (Rating: 0)

Comments/Description : Vertical door pull on inside of door; fist hand does not fit inside

28. Is the lock operable with one hand and without tight grasping, pinching or twisting of the wrist? : Yes (Rating: 1)

Comments/Description : flip latch style lock

29. Are the operable parts of the door hardware mounted no less than 865mm and no greater than 1220mm above the floor? : Yes (Rating: 1)

**Measurement
(mm) : 960**

Comments/Description : door pull - 960 mm Lock - 1020 mm

30. Is the stall at least 1525mm wide? : Yes (Rating: 1)

**Measurement
(mm)** : 3130

31. If the toilet is wall hung, is the stall at least 1420mm deep?

Or : N_A (Rating: 0)

32. If the toilet is floor mounted, is the stall at least 1500mm deep? : Yes (Rating: 1)

**Measurement
(mm)** : 2130

If the door swings in, is the stall area beyond the swing of the door:

33. A minimum of 1525mm wide x 1420mm deep for wall hung toilet?

Or : N_A (Rating: 0)

34. A minimum of 1525mm wide x 1500mm deep for floor mounted toilet? : Yes (Rating: 1)

**Measurement
(mm x mm)** : 2130 x 2290

Comments/Description : 2130 mm x 2290 mm

Toilet

35. Is the centerline of the toilet no less than 405mm and no greater than 455mm from the side wall or partition? : Yes (Rating: 1)

**Measurement
(mm)** : 400

36. Is clearance provided around the toilet measuring at least 1525mm from the side wall and at least 1420mm from the rear wall? : Yes (Rating: 1)

**From side wall
(mm)** : 3130

**From rear wall
(mm)** : 2130

37. Is the height of the toilet no less than 430mm and no greater than 485mm above the floor measured to the top of the seat? : Yes (Rating: 1)

**Measurement
(mm)** : 460

Grab bars

38. Is there a grab bar at least 1065mm long on the side wall? : No (Rating: 0)

**Measurement
(mm) : 620**

39. Is it located no more than 305mm from the rear wall? : Yes (Rating: 1)

**Measurement
(mm) : 220**

40. Does it extend at least 1370mm from the rear wall? : No (Rating: 0)

**Measurement
(mm) : 850**

41. Is it mounted no less than 840mm and no greater than 915mm above the floor to the top of the gripping surface? : Yes (Rating: 1)

**Measurement
(mm) : 860**

42. Is there at least 305mm clearance between the grab bar and protruding objects above? : N_A (Rating: 0)

Comments/Description : no objecets above

43. Is there at least 38mm clearance between the grab bar and projecting objects below? : Yes (Rating: 1)

**Measurement
(mm) : 100**

Comments/Description : toilet paper dispenser below

44. Is the space between the wall and the grab bar 38mm : Yes (Rating: 1)

**Measurement
(mm) : 40**

45. Is there a grab bar at least 915mm long on the rear wall? : No (Rating: 0)

Comments/Description : no grab bar along rear wall

46. Does the grab bar extend at least 305mm from the centerline of the toilet on one side (side wall)? : N_A (Rating: 0)

47. Does the grab bar extend at least 610mm on the other (open) side? : N_A (Rating: 0)

48. Is the grab bar mounted no less than 840mm and no greater than 915mm above the floor to the top of the gripping surface? : N_A (Rating: 0)

49. Are there at least 305mm clearance between the grab bar and protruding objects above? : N_A (Rating: 0)

50. Are there at least 38mm clearance between the grab bar and projecting objects below? : N_A (Rating: 0)

0)

51. Is the space between the wall and the grab bar 38mm inches? : N_A (Rating: 0)

Toilet flush controls

52. If the flush control is hand operated, is the operable part located no higher than 1220mm above the floor? : Yes (Rating: 1)

**Measurement
(mm) : 720**

53. If the flush control is hand operated, can it be operated with one hand and without tight grasping, pinching, or twisting of the wrist? : Yes (Rating: 1)

54. Is the force required to activate the flush control no greater than 2.3kg? : Yes (Rating: 1)

**Measurement
(kg) : 0**

Comments/Description : little force required

55. Is the flush control on the open side of the toilet? : No (Rating: 0)

Toilet paper dispenser

56. Is the toilet paper dispenser located no less than 180mm and no greater than 230mm from the front of the toilet to the center line of the dispenser? : No (Rating: 0)

Comments/Description : dispenser is not located past the front of the toilet. Far end of dispenser flush with end of toilet

57. Is the outlet of the dispenser: Located no less than 380mm and no greater than 1220mm above the floor? : Yes (Rating: 1)

**Measurement
(mm) : 730**

58. Is the dispenser located behind grab bars? : No (Rating: 0)

59. Does the dispenser allow continuous paper flow? : Yes (Rating: 1)

Sink

60. Does at least one sink have a clear floor space for a forward approach at least 760mm wide and 1220mm long? : Yes (Rating: 1)

**Measurement
(mm x mm) : 1660 x 1500**

Comments/Description : 1660 mm x 1500 mm

61. Do no less than 430mm and no greater than 635mm of the clear floor space extend under the sink so that a person using a wheelchair can get close enough to reach the faucet? : Yes (Rating: 1)

Measurement**(mm) : 310****Comments/Description** : clear space under sink - front of sink to pipe under sink (attached to floor) is 310.**62. Is the front of the sink or counter surface, whichever is higher, no more than 865mm above the floor? :**

Yes (Rating: 1)

Measurement**(mm) : 820****63. Is there at least 685mm height clearance from the floor to the bottom of the sink that extends at least 205mm deep under the sink for knee clearance? :** Yes (Rating: 1)**Height****(mm) : 730****Depth****(mm) : 310****64. Is there toe clearance at least 230mm high?****Note: Space extending greater than 150mm beyond the available toe clearance at 230mm above the floor is not considered toe clearance. :** No (Rating: 0)**Comments/Description** : Pipe extends all the way to the floor; clearance from pipe to begin of sink is 310 mm**65. Are pipes below the sink insulated or otherwise configured to protect against contact? :** No (Rating: 0)**66. Can the faucet be operated without tight grasping, pinching, or twisting of the wrist? :** Yes (Rating: 1)**67. Is the force required to activate the faucet no greater than 2.3 kg? :** Yes (Rating: 1)**Comments/Description** : push faucet**Washroom fixtures****68. Is there a clear path to at least one of each type of fixture, e.g. sink, hand dryer, garbage bin etc., that is at least 915mm wide? :** Yes (Rating: 1)**Measurement****(mm) : 1660****69. Is there clear floor space available for a person in a wheelchair to turn around, i.e. a circle at least 1525mm in diameter or a T-shaped space within a 1525mm square? :** Yes (Rating: 1)**Measurement****(mm) : 1660****Mirror****70. If the mirror is over a sink or countertop, is the bottom edge of the reflecting surface no higher than 1015mm above the floor?**

Or : No (Rating: 0)

**Measurement
(mm) : 1190**

71. If the mirror is not over the sink or countertop, is the bottom edge of the reflecting surface no higher than 890mm above the floor? : N_A (Rating: 0)

Coat hook

72. If there is a coat hook, is it no less than 380mm and no greater than 1220mm above the floor?* : No (Rating: 0)

**Measurement
(mm) : 1530**

Soap dispenser

Are the operable parts of the soap dispenser within one of the following reach ranges:

73. Above sinks or counters no less than 510mm and no greater than 635mm deep: no higher than 1120mm above the floor?

Or : N_A (Rating: 0)

Comments/Description : no soap dispenser

74. Above sinks less than 510mm deep: no higher than 1220mm above the floor?

Or : N_A (Rating: 0)

75. Not over an obstruction: no higher than 1220mm above the floor? : N_A (Rating: 0)

Hand dryer/Towel dispenser

Are the operable parts of the hand dryer or towel dispenser within one of the following reach ranges:

76. Above sinks or counters no less than 510mm and no greater than 635mm deep: no higher than 1120mm above the floor?

Or : N_A (Rating: 0)

77. Above sinks less than 510mm deep: no higher than 1220mm above the floor?

Or : N_A (Rating: 0)

78. Not over an obstruction: no higher than 1220mm above the floor? : Yes (Rating: 1)

**Measurement
(mm) : 1060**

79. Can the operable parts of the hand dryer or towel dispenser be operated without tight grasping, pinching or twisting of the wrist? : N_A (Rating: 0)

Comments/Description : pull paper dispenser

80. Is the force required to activate the hand dryer or towel dispenser no greater than 2.3kg? : N_A
(Rating: 0)

Controls - light switches

81. Is there a clear floor space at least 760mm wide by at least 1220mm long for a forward or parallel approach? : N_A (Rating: 0)

Comments/Description : natural light; no switches

82. Are the operable parts no higher than 1220mm above the floor? : N_A (Rating: 0)

83. Can the control be operated with one hand and without tight grasping, pinching, or twisting of the wrist? : N_A (Rating: 0)

1. Has the route to the washroom been evaluated? : No -
_ACCESS_ROUTE_checklist_must_also_be_completed

Additional comments regarding assessment: : Washroom is located immediately adjacent to parking lot; hard pack gravel surface; level route (1-2 degree slope).

Camping

Water Access

Goods and Services