

Mt Robson Visitors Centre ▼

#### Information

Date of Audit: 2016-07-27

Park Name: Horsefly?

Key Features: Camping,Picnic\_Site,Beach,Fishing

Location: Cariboo, One Hundred Mile House, Cariboo Chilcotin Coast - Provincial : Park (Heritage Discovery Circle Route)

#### Description:

Parking

Access Routes

**From:** : campsite 14

**To:** : accessible washroom

**Comments/Description** : 59 to accessible washroom

**2. What is the condition of the surface along this route?** : Moderate (Rating: 1)

**4. What is the type of surface?** : Gravel

#### Clear Width

**5. What is the typical route width (mm)?** : More\_than\_1525 (Rating: 0)

**6. What is the narrowest route width (mm)?** : between\_1525\_-\_1220

#### Obstacles

**7. If the route is concrete, asphalt or boardwalk, are there any obstacles that exceed 13mm from the surface?** : N\_A (Rating: 0)

**8. If yes, are the obstacles at least 1220mm apart?** : N\_A (Rating: 0)

**9. If the route is anything other than concrete, asphalt or boardwalk, are there any obstacles that exceed 25mm from the surface?** : No (Rating: 0)

**10. If yes, are the obstacles at least 1220mm apart?** : N\_A (Rating: 0)

#### Openings

**11. Are there any gaps or grates present that have an opening greater than 13mm?** : No (Rating: 0)

**12. If gaps/grates are present, do they run perpendicular to the path of travel?** : No (Rating: 0)

#### Running Slope

**13. What is the typical running slope on the route?** : Flat\_Gentle\_1\_or\_less

**14. What is the maximum running slope on the route?** : Flat\_Gentle\_1\_or\_less

## Cross Slope

15. What is the typical cross slope on the route? : Flat\_Gentle\_1\_or\_less

16. What is the maximum cross slope on the route? : Flat\_Gentle\_1\_or\_less

## Resting Intervals

17. Are there resting intervals at the top and bottom of a route where the grade exceeds 3°? : No (Rating: 0)

18. If the running slope is greater than 3°, are there resting intervals in the middle of the route when the length exceeds 9.1m? : N\_A (Rating: 0)

## Protruding Objects

19. Is there a minimum of 2030mm vertical clearance for users to safely pass along the route without coming into contact with overhanging obstacles? : No\_-\_below\_standard (Rating: 0)

## Benches

21. Are there any benches along the route? : No (Rating: 0)

22. If yes, are the benches located approximately every 61m? : N\_A (Rating: 0)

23. Is the bench seat height between 485mm - 510mm? : N\_A (Rating: 0)

## Ramps

24. Is there is a ramp? : No (Rating: 0)

25. Is the ramp at least 915mm wide?

Note: If there are handrails, measure between the handrails. : N\_A (Rating: 0)

26. Is the surface stable, firm and slip resistant? : N\_A (Rating: 0)

27. For each section of the ramp, is the running slope no greater than 5°?

Note: Rises no greater than 76mm with a slope no steeper than 7° and rises no greater than 150mm with a slope no steeper than 6° are permitted when due to space limitations. : N\_A (Rating: 0)

28. Is there a level landing that is at least 1525mm long and at least as wide as the ramp: At the top of the ramp? : N\_A (Rating: 0)

29. At the bottom of the ramp? : N\_A (Rating: 0)

30. Is there a level landing where the ramp changes direction that is at least 1525mm x 1525mm? : N\_A (Rating: 0)

31. If the ramp has a rise higher than 150mm are there handrails on both sides? : N\_A (Rating: 0)

32. Is the top of the handrail gripping surface no less than 865mm and no greater than 965mm above the

**ramp surface? : N\_A (Rating: 0)**

**33. Is the handrail gripping surface continuous and not obstructed along the top or sides? : N\_A (Rating: 0)**

**34. If there are obstructions, is the bottom of the gripping surface obstructed no more than 20%? : N\_A (Rating: 0)**

### **Stairs**

**35. Are there floors or surfaces connected only by stairs, not an elevator or ramp? : No (Rating: 0)**

**36. How many flights of stairs are there? : N\_A**

**37. If there are less than a flight, how many stairs are there? : N\_A**

**38. Do all stair treads have a horizontal strip at the edge that is: 40mm-60mm deep, colour contrasted & extends the full width of the step? : N\_A (Rating: 0)**

**39. If the stairs are not enclosed, is there a tactile warning system present at the landing of entrance to stairs system? : N\_A (Rating: 0)**

**40. Are there handrails on both sides of the stairs at a uniform height of 860mm-920mm above the front step? : N\_A (Rating: 0)**

**41. Do the handrails extend horizontally at the top and bottom of each flight of stairs? : N\_A (Rating: 0)**

**42. Are the handrails continuous around landings? : N\_A (Rating: 0)**

**43. Are the handrails continuously graspable, without interruption by vertical supports, newel posts, or other construction elements which require repositioning the hands while ascending or descending? : N\_A (Rating: 0)**

**44. Do the handrails have a graspable cross-section that is either circular with an outside diameter of 30mm-40mm or elliptical with an outside perimeter of 100mm-125mm? : N\_A (Rating: 0)**

Trails

Washrooms

**Date of Audit : 2016-07-27**

**Auditors Names : Ryan**

**Weather condition during audit : Sunny**

**Washroom # : 1**

**Description of washroom location : washroom near site 14**

**Type of Washroom : Out-house**



### Directional signage

2. Are there signs at inaccessible washrooms that give directions to accessible washrooms? : No (Rating: 0)

3. Is there an accessible route to the accessible washroom? : Yes (Rating: 1)

4. If not all washrooms are accessible, is there a sign at the accessible washroom with the International Symbol of Accessibility? : Yes (Rating: 1)

5. Do text characters contrast with their backgrounds? : Yes (Rating: 1)

6. Are text characters raised? : No (Rating: 0)

7. Is there Braille? : No (Rating: 0)

8. Is the sign mounted on the wall, on latch side of the door?

Note: Signs are permitted on the push side of doors with closers and without hold-open devices. : No (Rating: 0)

9. So the baseline of the lowest character is at least 1220mm above the floor and the baseline of the highest character is no more than 1525mm above the floor?

Note: If the sign is at double doors with one active leaf, the sign should be on the inactive leaf; if both leaves are active, the sign should be on the wall to the right of the right leaf. : No (Rating: 0)

### Interior doors

10. Is the door opening width at least 815mm clear, between the face of the door and the stop, when the door is open 90°? : N\_A (Rating: 0)

11. If there is a front approach to the pull side of the door, is there at least 455mm of maneuvering clearance beyond the latch side plus at least 1525mm clear depth? : N\_A (Rating: 0)

12. On both sides of the door, is the floor surface of the maneuvering clearance level (no steeper than 1°)? : N\_A (Rating: 0)

13. If the threshold is vertical is it no more than 6mm high?

Or : N\_A (Rating: 0)

14. If the threshold is beveled, is it no more than 19mm high? : N\_A (Rating: 0)

**15. Is the door equipped with hardware that is operable with one hand and does not require tight grasping, pinching or twisting of the wrist? : N\_A (Rating: 0)**

**16. Are the operable parts of the hardware no less than 865mm and no greater than 1220mm above the floor? : N\_A (Rating: 0)**

**17. Can the door be opened easily, maximum 2.3kg of force?**

**Note: You can use a pressure gauge or fish scale to measure force. : N\_A (Rating: 0)**

**18. If the door has a closer, does it take at least 5 seconds to close from open position of 90° to a position of 12° from the latch? : N\_A (Rating: 0)**

**19. If there are two doors in a series, e.g. vestibule, is the distance between the doors at least 1220mm plus the width of the doors when swinging into the space? : N\_A (Rating: 0)**

**20. If there is a privacy wall and the door swings out, is there at least 610mm of maneuvering clearance beyond the door latch side and 1065mm to the privacy wall? : N\_A (Rating: 0)**

**21. If there is a privacy wall and the door swings in, is there at least 610mm of maneuvering clearance beyond the door latch side and at least 1220mm to the privacy wall if there is no door closer or at least 1370mm if there is a door closer? : N\_A (Rating: 0)**

**22. In a unisex washroom if the door swings in and over a clear floor space at an accessible fixture, is there a clear floor space at least 760mm x 1220mm beyond the swing of the door? : N\_A (Rating: 0)**

#### **Toilet stall**

**23. Is there an individual accessible toilet stall? : Yes (Rating: 1)**

**24. Is the stall door opening width at least 815mm clear, between the face of the door and the stop, when the door is open 90°? : Yes (Rating: 1)**

**Measurement  
(mm) : 850**

**25. If there is a front approach to the pull side of the stall door, is there at least 455mm of maneuvering clearance beyond the latch side plus 1525mm clear depth? : Yes (Rating: 1)**

**Clearance  
(mm) : 365**

**Depth  
(mm) : 1640**

**Comments/Description : clearance doesn't meet standards.**

**26. Is the door self-closing? : No (Rating: 0)**

**27. Are there door pulls on both sides of the door that are operable with one hand and do not require tight grasping pinching or twisting of the wrist?\* : No (Rating: 0)**

**28. Is the lock operable with one hand and without tight grasping, pinching or twisting of the wrist? : No (Rating: 0)**

**Comments/Description** : has a eye hole latch system.

**Recommendations** : replace eye hole latch with door slider.

**Improvement Priority** : Low

**Estimated Cost** : Low

**29. Are the operable parts of the door hardware mounted no less than 865mm and no greater than 1220mm above the floor?** : No (Rating: 0)

**Measurement  
(mm)** : 930

**Comments/Description** : 930mm top and 710mm bottom angle grab bar inside of the door.

**Recommendations** : to be mounted straight across at 865mm from floor

**Improvement Priority** : Low

**Estimated Cost** : Low

**30. Is the stall at least 1525mm wide?** : Yes (Rating: 1)

**Measurement  
(mm)** : 1645

**31. If the toilet is wall hung, is the stall at least 1420mm deep?**

**Or** : N\_A (Rating: 0)

**32. If the toilet is floor mounted, is the stall at least 1500mm deep?** : Yes (Rating: 1)

**Measurement  
(mm)** : 1640

**If the door swings in, is the stall area beyond the swing of the door:**

**33. A minimum of 1525mm wide x 1420mm deep for wall hung toilet?**

**Or** : N\_A (Rating: 0)

**34. A minimum of 1525mm wide x 1500mm deep for floor mounted toilet?** : N\_A (Rating: 0)

**Toilet**

**35. Is the centerline of the toilet no less than 405mm and no greater than 455mm from the side wall or partition?** : No (Rating: 0)

**Measurement  
(mm)** : 930

**Comments/Description** : grab bar to far from toilet

**Recommendations** : possible solution install folding grab bar

**Improvement Priority** : Med

**Estimated Cost** : Med

**36. Is clearance provided around the toilet measuring at least 1525mm from the side wall and at least 1420mm from the rear wall? : Yes (Rating: 1)**

**From side wall  
(mm) : 1645**

**From rear wall  
(mm) : 1640**

**37. Is the height of the toilet no less than 430mm and no greater than 485mm above the floor measured to the top of the seat? : No (Rating: 0)**

**Measurement  
(mm) : 500**

**Grab bars**

**38. Is there a grab bar at least 1065mm long on the side wall? : No (Rating: 0)**

**Measurement  
(mm) : 775**

**39. Is it located no more than 305mm from the rear wall? : No (Rating: 0)**

**Measurement  
(mm) : 140**

**40. Does it extend at least 1370mm from the rear wall? : No (Rating: 0)**

**Measurement  
(mm) : 910**

**41. Is it mounted no less than 840mm and no greater than 915mm above the floor to the top of the gripping surface? : Yes (Rating: 1)**

**Measurement  
(mm) : 885**

**42. Is there at least 305mm clearance between the grab bar and protruding objects above? : N\_A (Rating: 0)**

**43. Is there at least 38mm clearance between the grab bar and projecting objects below? : N\_A (Rating: 0)**

**44. Is the space between the wall and the grab bar 38mm : Yes (Rating: 1)**

**Measurement  
(mm) : 42**

**45. Is there a grab bar at least 915mm long on the rear wall? : No (Rating: 0)**

**Measurement  
(mm) : 610**

**Comments/Description : replace angle grab bar with a straight grab bar to meet code.**

**46. Does the grab bar extend at least 305mm from the centerline of the toilet on one side (side wall)? : No (Rating: 0)**

**47. Does the grab bar extend at least 610mm on the other (open) side? : No (Rating: 0)**

**48. Is the grab bar mounted no less than 840mm and no greater than 915mm above the floor to the top of the gripping surface? : No (Rating: 0)**

**49. Are there at least 305mm clearance between the grab bar and protruding objects above? : No (Rating: 0)**

**50. Are there at least 38mm clearance between the grab bar and projecting objects below? : No (Rating: 0)**

**51. Is the space between the wall and the grab bar 38mm inches? : No (Rating: 0)**

#### **Toilet flush controls**

**52. If the flush control is hand operated, is the operable part located no higher than 1220mm above the floor? : N\_A (Rating: 0)**

**53. If the flush control is hand operated, can it be operated with one hand and without tight grasping, pinching, or twisting of the wrist? : N\_A (Rating: 0)**

**54. Is the force required to activate the flush control no greater than 2.3kg? : N\_A (Rating: 0)**

**55. Is the flush control on the open side of the toilet? : N\_A (Rating: 0)**

#### **Toilet paper dispenser**

**56. Is the toilet paper dispenser located no less than 180mm and no greater than 230mm from the front of the toilet to the center line of the dispenser? : No (Rating: 0)**

**57. Is the outlet of the dispenser: Located no less than 380mm and no greater than 1220mm above the floor? : No (Rating: 0)**

**Measurement  
(mm) : 955**

**58. Is the dispenser located behind grab bars? : No (Rating: 0)**

**59. Does the dispenser allow continuous paper flow? : Yes (Rating: 1)**

#### **Sink**

**60. Does at least one sink have a clear floor space for a forward approach at least 760mm wide and 1220mm long? : N\_A (Rating: 0)**



**61. Do no less than 430mm and no greater than 635mm of the clear floor space extend under the sink so that a person using a wheelchair can get close enough to reach the faucet? : N\_A (Rating: 0)**

**62. Is the front of the sink or counter surface, whichever is higher, no more than 865mm above the floor? : N\_A (Rating: 0)**

**63. Is there at least 685mm height clearance from the floor to the bottom of the sink that extends at least 205mm deep under the sink for knee clearance? : N\_A (Rating: 0)**

**64. Is there toe clearance at least 230mm high?**

**Note: Space extending greater than 150mm beyond the available toe clearance at 230mm above the floor is not considered toe clearance. : N\_A (Rating: 0)**

**65. Are pipes below the sink insulated or otherwise configured to protect against contact? : N\_A (Rating: 0)**

**66. Can the faucet be operated without tight grasping, pinching, or twisting of the wrist? : N\_A (Rating: 0)**

**67. Is the force required to activate the faucet no greater than 2.3 kg? : N\_A (Rating: 0)**

#### **Washroom fixtures**

**68. Is there a clear path to at least one of each type of fixture, e.g. sink, hand dryer, garbage bin etc., that is at least 915mm wide? : N\_A (Rating: 0)**

**69. Is there clear floor space available for a person in a wheelchair to turn around, i.e. a circle at least 1525mm in diameter or a T-shaped space within a 1525mm square? : N\_A (Rating: 0)**

#### **Mirror**

**70. If the mirror is over a sink or countertop, is the bottom edge of the reflecting surface no higher than 1015mm above the floor?**

**Or : N\_A (Rating: 0)**

**71. If the mirror is not over the sink or countertop, is the bottom edge of the reflecting surface no higher than 890mm above the floor? : N\_A (Rating: 0)**

#### **Coat hook**

**72. If there is a coat hook, is it no less than 380mm and no greater than 1220mm above the floor?\*: No (Rating: 0)**

**Measurement (mm) : 1380**

#### **Soap dispenser**

**Are the operable parts of the soap dispenser within one of the following reach ranges:**

**73. Above sinks or counters no less than 510mm and no greater than 635mm deep: no higher than 1120mm above the floor?**

**Or : N\_A (Rating: 0)**

**74. Above sinks less than 510mm deep: no higher than 1220mm above the floor?**

**Or : N\_A (Rating: 0)**

**75. Not over an obstruction: no higher than 1220mm above the floor? : N\_A (Rating: 0)**

**Hand dryer/Towel dispenser**

**Are the operable parts of the hand dryer or towel dispenser within one of the following reach ranges:**

**76. Above sinks or counters no less than 510mm and no greater than 635mm deep: no higher than 1120mm above the floor?**

**Or : N\_A (Rating: 0)**

**78. Not over an obstruction: no higher than 1220mm above the floor? : N\_A (Rating: 0)**

**79. Can the operable parts of the hand dryer or towel dispenser be operated without tight grasping, pinching or twisting of the wrist? : N\_A (Rating: 0)**

**80. Is the force required to activate the hand dryer or towel dispenser no greater than 2.3kg? : N\_A (Rating: 0)**

**Controls - light switches**

**81. Is there a clear floor space at least 760mm wide by at least 1220mm long for a forward or parallel approach? : N\_A (Rating: 0)**

**82. Are the operable parts no higher than 1220mm above the floor? : N\_A (Rating: 0)**

**83. Can the control be operated with one hand and without tight grasping, pinching, or twisting of the wrist? : N\_A (Rating: 0)**

**1. Has the route to the washroom been evaluated? : No -  
\_ACCESS\_ROUTE\_checklist\_must\_also\_be\_completed**

**Additional comments regarding assessment:** : The accessible pit toilet needs to have the grab bars replaced with proper grab bars that meet the recommended or above code standards. The grab bar on the door should be removed and have a proper D handle installed that meets the recommended or above code standards.

Camping

**Date of Audit (YYYY-MM-DD) :** 2016-07-27

**Name of Campground :** Horsefly Lake Provincial Park Campground

**Location of Campsite :** #14

**Weather condition during audit :** Sunny



**1. Does the number of accessible camp sites comply with the table above? :** No - \_Below\_Standard (Rating: 0)

### Campsite

**2. Is the camp site surface firm and stable? :** Yes (Rating: 1)

**3. What type of surface is in the campsite? :** Gravel

**4. Is the accessible campsite at least 4.9m wide?**

**Or :** Yes - \_Exceeds\_Standard

### Measurement

**(m) :** 8

**5. If it is an RV site, is the parking area at least 6m wide? :** No - \_Below\_Standard (Rating: 0)

### Measurement

**(m) :** 5

**6. If the campsite surface is concrete or asphalt, is the slope 1° or less? :** Yes - \_Meets\_Standard (Rating: 1)

**7. If the campsite surface is anything other than concrete & asphalt, is the slope 3° or less? :** Yes - \_Meets\_Standard (Rating: 1)

### Tent Pads/Platforms

**8. Is there a minimum of 1220mm clear space on all sides surrounding the tent pad or platform? :** N\_A (Rating: 0)

**Comments/Description :** no tent pad

**9. What type of surface is the tent pad/ platform? :** Gravel

**10. What is the slope of the tent pad/ platform? :** Flat\_Gentle\_1\_or\_less

**11. Is there an accessible entrance or ramp on to the tent pad/platform? :** Yes (Rating: 1)

### Utility & Sewage Hook Ups

**12. Is there sufficient clear ground space, a minimum of 1220mm x 1525mm surrounding the hook ups? :** N\_A (Rating: 0)

**13. If there are operable parts, can they be operated using one hand, without tightly grasping, pinching, or twisting the wrist and with no more than 2.3kg of force? :** N\_A (Rating: 0)

**Campfires & Grills**

**14. Is there an area for campfires? : Yes (Rating: 1)**

**15. Is there a minimum of 1220mm clear ground space on all sides? : Yes - Exceeds Standard**

**Measurement  
(mm) : 1380**

**16. Is the slope 3° or less in all directions? : Yes (Rating: 1)**

**Measurement  
(angle °) : 2**

**17. Is the grill height between 380mm - 865mm above the ground? : No (Rating: 0)**

**Measurement  
(mm) : 300**

**18. Is the fire building surface height at least 230mm above the ground? : N\_A (Rating: 0)**

**Measurement  
(mm) : 230**

**19. If there is a raised edge or wall around the fire building area, is the thickness less than 255mm? : N\_A  
(Rating: 0)**

**20. Is there a clear, level accessible route to the campfire area? : Yes (Rating: 1)**

**21. Are picnic tables provided? : Yes (Rating: 1)**

**22. How many accessible picnic tables are there? : 1**

**23. If the picnic table is up to 2.7m long, is there one wheelchair seating space? : Yes (Rating: 1)**

**Comments/Description : 2331**

**24. If the picnic table is longer than 2.7m, are there at least two wheelchair spaces provided? : No (Rating: 0)**

**25. Is there clear and level ground space, 915mm measured from back edge of seats/benches? : No -  
\_Below\_ Standard (Rating: 0)**

**Measurement  
(mm) : 195**

**26. Do the accessible spaces have adequate knee clearance, 685mm high x 760mm wide x 430mm deep? :  
N\_A (Rating: 0)**

**Measurement  
(mm) h x w x d : 720**

**27. Is the ground surface surrounding the accessible picnic table firm and stable? : Yes (Rating: 1)**

**28. Is there a clear, level accessible route to the picnic table? : No (Rating: 0)**

### **Water Taps**

**1. Are there any water taps? : No (Rating: 0)**

**2. Is there sufficient clear ground space, a minimum of 1829mm x 1220mm surrounding the water tap? : N\_A (Rating: 0)**

**3. Is the water spout height between 280mm - 305mm? : N\_A (Rating: 0)**

**4. Is the height of operable parts (i.e. taps or levers) between 380mm - 1220mm above the ground? : N\_A (Rating: 0)**

**5. If there are operable parts, can they be operated using one hand, without tightly grasping, pinching, or twisting the wrist and with no more than 2.3kg of force? : N\_A (Rating: 0)**

**6. Is there a clear, level accessible route to the water tap? : N\_A (Rating: 0)**

### **Water Fountains**

**1. Is there a water fountain? : No (Rating: 0)**

**2. Does it have a lever or push bar control on the front or both sides? : N\_A (Rating: 0)**

**3. Is the spout opening height between 750mm - 915mm above the ground? : N\_A (Rating: 0)**

**4. Is there a minimum width of 800mm clearance space directly in front of the water fountain? : N\_A (Rating: 0)**

**5. Is there a clear, level accessible route to the water fountain? : N\_A (Rating: 0)**

### **Trash & Recycling Receptacles**

**1. Are there any trash &/or recycling receptacles? : No (Rating: 0)**

**2. Is the approach to the receptacle level, with no-step? : N\_A (Rating: 0)**

**3. If there are operable parts, is their height between 380mm - 1220mm above the ground? : N\_A (Rating: 0)**

**4. If there are operable parts, can they be operated using one hand, without tightly grasping, pinching, or twisting the wrist and with no more than 2.3kg of force? : N\_A (Rating: 0)**

**5. Is there a clear, level accessible route to the trash/recycling receptacle? : N\_A (Rating: 0)**

### **Shelters**

**1. Are there any camp shelters? : No (Rating: 0)**

**2. What is the slope at the entrance to the camp shelter? : N\_A (Rating: 0)**

**3. What type of surface is in the camp shelter? : N\_A**

**4. Is the shelter surface firm and stable? : N\_A (Rating: 0)**

**5. Is there a clear, level accessible route to the camp shelter? : N\_A (Rating: 0)**

### **Benches**

**1. Are any benches provided? : No (Rating: 0)**

**2. If yes, how many benches are there? : N\_A**

**3. Is the bench seat height between 485mm - 510mm? : N\_A (Rating: 0)**

**4. Is there a minimum of 915mm x 1220mm clear ground space beside the bench? : N\_A (Rating: 0)**

**5. Is there a clear, level accessible route to the bench? : N\_A (Rating: 0)**

### **Playground**

**1. Is there a playground? : No (Rating: 0)**

**2 What type of surface is in the play area? : N\_A**

**3. Is the play area surface firm and stable? : N\_A (Rating: 0)**

**4. Are any of the playground components accessible to wheelchair users? If yes, please describe. : N\_A (Rating: 0)**

**5. Is there a clear, level accessible route to the playground? : N\_A (Rating: 0)**

### **Amphitheatre**

**1. Is there an amphitheatre? : No (Rating: 0)**

### **Amphitheatre Seating**

**2. Are an adequate number of wheelchair spaces provided? : N\_A (Rating: 0)**

**3. Are wheelchair spaces dispersed to allow location choices and viewing angles equivalent to other seating, including specialty seating areas that provide distinct services and amenities? : N\_A (Rating: 0)**

**4. Where people are expected to remain seated, do people in wheelchair spaces have a clear line of sight over and between the heads of others in front of them? : N\_A (Rating: 0)**

**5. Where people are expected to stand, do people in wheelchair spaces have a clear line of sight over and between the heads heads of others in front of them? : N\_A (Rating: 0)**

**6. If there is a single wheelchair space, is it at least 915mm wide? : N\_A (Rating: 0)**

**7. If there are two adjacent wheelchair spaces, are they each at least 840mm wide? : N\_A (Rating: 0)**

**8. If the wheelchair space can be entered from the front or rear, is it at least 1220mm deep? : N\_A (Rating: 0)**

**9. If the wheelchair space can only be entered from the side, is it at least 1525mm deep? : N\_A (Rating: 0)**

**10. Do wheelchair spaces adjoin, but not overlap, accessible routes? : N\_A (Rating: 0)**

**11. Is there at least one companion seat for each wheelchair space? : N\_A (Rating: 0)**

**12. Is the companion seat located so the companion is shoulder-to-shoulder with the person in a wheelchair? : N\_A (Rating: 0)**

**13. Is the companion seat equivalent in size, quality, comfort and amenities to seating in the immediate area? : N\_A (Rating: 0)**

**2. Are there any public buildings (visitors centre/ interpretive centre/cafes etc) at the campground? : No (Rating: 0)**

**3. Are there any trails at the campground? : No (Rating: 0)**

**4. Is there a beach, dock/fishing platform or boat launch? : No (Rating: 0)**

**Additional comments regarding assessment:** : cross slopes from 1 to 10 degrees raised picnic pad above grade or ground 50 mm not accessible rec wider space needed surface needs to be built up and evened out hard packed even with picnic table pad



Water Access  
Goods and Services