

Mt Robson Visitors Centre ▼

Information

Date of Audit: 2016-08-12

Park Name: Kleanza Creek Provincial Park

Key Features: View_Point,Camping,Picnic_Site,Beach,Trails

Location: Kitimat-Stikine, Terrace, Northern BC - Provincial : Park (Heritage Discovery Circle Route)

Description: Kleanza Creek boasts a spectacular view of its small but impressive canyon and waterfall. This view is available from the picnic site, the rocky beach and the top of the trail (Canyon Trail) that ends at a viewing area above the canyon. The beach and viewpoint are not accessible areas. The campground runs alongside Kleanza Creek as well, which is another viewing feature at this site. o Kleanza Creek accessible features include: two outhouse washrooms, although only one has a designated sign posted on the building. The one without the sign is in fact a larger and more accessible facility, as well as being located at the parking lot (picnic site area). Areas for viewing the Canyon are also accessible although may require good upper body strength to access as their locations due to surfaces that are sloped and/or not level. These areas are located at the Day Use Picnic Area. Campsites at Kleanza do not have accessible features other than firm, level surfaces, and adequate room for smaller tents/trailers. o There are no designated parking spaces in the day use parking lot. o The Day Use Picnic site has benches in the picnic area, at a lower viewpoint near the Canyon, and along a Creekside trail. Please note: Beach is a rocky access to the creek and falls area. The creek is used for swimming by visitors

Parking

2. Are an adequate number of accessible spaces provided? : No - Below Standard (Rating: 0)

3. Of the accessible spaces, is at least one a van accessible space?* : N_A (Rating: 0)

4. Are accessible spaces at least 2.4m wide with an access aisle at least 1.5m wide? Note: Two spaces may share an access aisle. : N_A (Rating: 0)

5. Are the access aisles marked to discourage parking in them? : N_A (Rating: 0)

6. Is the slope of the accessible parking spaces and access aisles no steeper than 1Â° in all directions? : N_A (Rating: 0)

7. Does the access aisle adjoin an accessible route? : N_A (Rating: 0)

8. Are accessible spaces identified with a sign that includes the International Symbol of Accessibility? Note: The International Symbol of Accessibility is not required on the ground. : N_A (Rating: 0)

9. Of the total parking spaces, are the accessible spaces located on the closest accessible route to the accessible entrance(s)? Note: If parking serves multiple entrances, accessible parking should be dispersed. : N_A (Rating: 0)

Access Routes

From: : Day Use Parking Lot

To: : Day use Picnic Site

2. What is the condition of the surface along this route? : Good

4. What is the type of surface? : Gravel

Comments/Description : hard packed gravel; there is a paved section leading to this connection route, and it is not completely flush with gravel section. Some spots with edge up to 70 mm

Clear Width

5. What is the typical route width (mm)? : More_than_1525 (Rating: 0)

6. What is the narrowest route width (mm)? : between_1525_-_1220

Comments/Description : narrow section between concrete barriers of parking lot

Obstacles

7. If the route is concrete, asphalt or boardwalk, are there any obstacles that exceed 13mm from the surface? : N_A (Rating: 0)

8. If yes, are the obstacles at least 1220mm apart? : N_A (Rating: 0)

9. If the route is anything other than concrete, asphalt or boardwalk, are there any obstacles that exceed 25mm from the surface? : No (Rating: 0)

Comments/Description : no obstacles on route

10. If yes, are the obstacles at least 1220mm apart? : N_A (Rating: 0)

Openings

11. Are there any gaps or grates present that have an opening greater than 13mm? : No (Rating: 0)

12. If gaps/grates are present, do they run perpendicular to the path of travel? : N_A (Rating: 0)

Running Slope

13. What is the typical running slope on the route? : Flat_Gentle_1_or_less

14. What is the maximum running slope on the route? : Steep_3_-_5 (Rating: 0)

Comments/Description : There are three paths leading to two picnic areas. Two of the paths have steep slopes, as described, going down to the picnic area from the parking lot. The upper picnic area, closer to the Creek viewpoint, has a gentler slope but has a grass/gravel surface that is not level.

Cross Slope

15. What is the typical cross slope on the route? : Moderate_2_-_3 (Rating: 1)

16. What is the maximum cross slope on the route? : Steep_3_-_5 (Rating: 0)

Resting Intervals

17. Are there resting intervals at the top and bottom of a route where the grade exceeds 3°? : N_A (Rating: 0)

Comments/Description : this route is a short one from parking lot to picnic ground (8 m approx)

18. If the running slope is greater than 3°, are there resting intervals in the middle of the route when the length exceeds 9.1m? : N_A (Rating: 0)

Comments/Description : no objects along routeno objects along route

Comments/Description : no objects along route

Benches

21. Are there any benches along the route? : No (Rating: 0)

Comments/Description : short route

22. If yes, are the benches located approximately every 61m? : N_A (Rating: 0)

23. Is the bench seat height between 485mm - 510mm? : N_A (Rating: 0)

Ramps

24. Is there is a ramp? : No (Rating: 0)

25. Is the ramp at least 915mm wide?

Note: If there are handrails, measure between the handrails. : N_A (Rating: 0)

26. Is the surface stable, firm and slip resistant? : N_A (Rating: 0)

27. For each section of the ramp, is the running slope no greater than 5°?

Note: Rises no greater than 76mm with a slope no steeper than 7° and rises no greater than 150mm with a slope no steeper than 6° are permitted when due to space limitations. : N_A (Rating: 0)

28. Is there a level landing that is at least 1525mm long and at least as wide as the ramp: At the top of the ramp? : N_A (Rating: 0)

29. At the bottom of the ramp? : N_A (Rating: 0)

30. Is there a level landing where the ramp changes direction that is at least 1525mm x 1525mm? : N_A (Rating: 0)

31. If the ramp has a rise higher than 150mm are there handrails on both sides? : N_A (Rating: 0)

32. Is the top of the handrail gripping surface no less than 865mm and no greater than 965mm above the ramp surface? : N_A (Rating: 0)

33. Is the handrail gripping surface continuous and not obstructed along the top or sides? : N_A (Rating: 0)

34. If there are obstructions, is the bottom of the gripping surface obstructed no more than 20%? : N_A (Rating: 0)

Stairs

35. Are there floors or surfaces connected only by stairs, not an elevator or ramp? : No (Rating: 0)
36. How many flights of stairs are there? : N_A
37. If there are less than a flight, how many stairs are there? : N_A
38. Do all stair treads have a horizontal strip at the edge that is: 40mm-60mm deep, colour contrasted & extends the full width of the step? : N_A (Rating: 0)
39. If the stairs are not enclosed, is there a tactile warning system present at the landing of entrance to stairs system? : N_A (Rating: 0)
40. Are there handrails on both sides of the stairs at a uniform height of 860mm-920mm above the front step? : N_A (Rating: 0)
41. Do the handrails extend horizontally at the top and bottom of each flight of stairs? : N_A (Rating: 0)
42. Are the handrails continuous around landings? : N_A (Rating: 0)
43. Are the handrails continuously graspable, without interruption by vertical supports, newel posts, or other construction elements which require repositioning the hands while ascending or descending? : N_A (Rating: 0)
44. Do the handrails have a graspable cross-section that is either circular with an outside diameter of 30mm-40mm or elliptical with an outside perimeter of 100mm-125mm? : N_A (Rating: 0)

Trails

Date of Audit : 2016-08-12

Name of Trail : Canyon and Falls Lookout Trail

Section of trail audited : Full trail

Weather condition during audit : Sunny



Clear Width

5. What is the typical trail width (mm)? : More_than_1525 (Rating: 0)
6. What is the narrowest trail width (mm)? : between_1220_-915 (Rating: 1)

Obstacles

7. If the trail is concrete, asphalt or boardwalk, are there any obstacles that exceed 13mm from the surface? : No (Rating: 0)

8. If yes, are the obstacles at least 1220mm apart? : N_A (Rating: 0)

Comments/Description : last 30 m or so of the trail has many roots, and would not be considered accessible for a wheelchair, and may be difficult to manage for persons with other mobility issues

Recommendations : Boardwalk over root areas to allow greater accessibility

Improvement Priority : Low

Estimated Cost : High

10. If yes, are the obstacles at least 1220mm apart? : No (Rating: 0)

Openings

11. Are there any gaps or grates present that have an opening greater than 13mm? : No (Rating: 0)

12. If gaps/grates are present, do they run perpendicular to the path of travel? : N_A (Rating: 0)

Running Slope

13. What is the typical running slope on the trail? : Moderate_2_-_3 (Rating: 1)

Comments/Description : Ranges in some areas, 1 degree and gentle to 2-3 degrees

14. What is the maximum running slope on the trail? : Steep_3_-_5 (Rating: 0)

Cross Slope

15. What is the typical cross slope on the trail? : Moderate_2_-_3 (Rating: 1)

Comments/Description : Cross slope is moderate on creek side, gentle (1-2) on campsite side; trail follows along steep hillside adjacent to the creek.

16. What is the maximum cross slope on the trail? : Moderate_2_-_3 (Rating: 1)

Comments/Description : There are three spots in the trail that are fairly steep, up to 12.5 degrees of slope. The trail has switchbacks that allow some spots to be considered resting intervals. This trail may not be suitable for all persons in wheelchairs, and may require very good upper body strength.

Comments/Description : no protruding obstacles

Comments/Description : no protruding obstacles in the trail

Recommendations : Clear trail to maximize width for greater accessibility

Improvement Priority : High

Estimated Cost : Low

Comments/Description : There is one bench located at the end of the trail where the viewpoint is located

Recommendations : Add 1-2 benches to strategic areas along the trail route. There are spots where there would be room for benches.

Improvement Priority : Med

Estimated Cost : High

22. If yes, are the benches located approximately every 61m? : No - _below_ standard (Rating: 0)

Comments/Description : Benches are approx 100m or more in between

23. Is the bench seat height between 485mm - 510mm? : No - _below_ standard (Rating: 0)

**Measurement
(mm)** : 440

Ramps

24. Is there is a ramp? : No (Rating: 0)

25. Is the ramp at least 915mm wide?

Note: If there are handrails, measure between the handrails. : N_A (Rating: 0)

26. Is the surface stable, firm and slip resistant? : N_A (Rating: 0)

27. For each section of the ramp, is the running slope no greater than 5°?

Note: Rises no greater than 76mm with a slope no steeper than 7° and rises no greater than 150mm with a slope no steeper than 6° are permitted when due to space limitations. : N_A (Rating: 0)

28. Is there a level landing that is at least 1525mm long and at least as wide as the ramp: At the top of the ramp? : N_A (Rating: 0)

29. At the bottom of the ramp? : N_A (Rating: 0)

30. Is there a level landing where the ramp changes direction that is at least 1525mm x 1525mm? : N_A (Rating: 0)

31. If the ramp has a rise higher than 150mm are there handrails on both sides? : N_A (Rating: 0)

32. Is the top of the handrail gripping surface no less than 865mm and no greater than 965mm above the ramp surface? : N_A (Rating: 0)

33. Is the handrail gripping surface continuous and not obstructed along the top or sides? : N_A (Rating: 0)

34. If there are obstructions, is the bottom of the gripping surface obstructed no more than 20%? : N_A (Rating: 0)

Stairs

35. Are there floors or surfaces connected only by stairs, not an elevator or ramp? : No (Rating: 0)

36. How many flights of stairs are there? : N_A

37. If there are less than a flight, how many stairs are there? : N_A

38. Do all stair treads have a horizontal strip at the edge that is: 40mm-60mm deep, colour contrasted & extends the full width of the step? : N_A (Rating: 0)

39. If the stairs are not enclosed, is there a tactile warning system present at the landing of entrance to stairs system? : N_A (Rating: 0)

40. Are there handrails on both sides of the stairs at a uniform height of 860mm-920mm above the front step? : N_A (Rating: 0)

41. Do the handrails extend horizontally at the top and bottom of each flight of stairs? : N_A (Rating: 0)

42. Are the handrails continuous around landings? : N_A (Rating: 0)

43. Are the handrails continuously graspable, without interruption by vertical supports, newel posts, or other construction elements which require repositioning the hands while ascending or descending? : N_A (Rating: 0)

44. Do the handrails have a graspable cross-section that is either circular with an outside diameter of 30mm-40mm or elliptical with an outside perimeter of 100mm-125mm? : N_A (Rating: 0)

Comments/Description : No specific viewing area however there is a view of the creek from the trail, and spots to sit and view that are off to the side of the trail

2. Is there sufficient clear ground space, a minimum of 915mm x 1220mm for the user to view the key features? : No - Below Standard (Rating: 0)

Comments/Description : This view point is not accessible for wheelchairs due to roots on trail leading up to the viewpoint, and the extreme slope upon which the viewpoint sits.

Recommendations : Build over root trail with boardwalk; build up viewpoint as a level deck for greater accessibility

Improvement Priority : Low

Estimated Cost : High

3. Is the viewing area surface firm and stable? : No (Rating: 0)

4. What type of surface is the viewing area? : Other_add_in_comments

Comments/Description : Packed dirt surface.

5. Is there a clear space between 815mm - 1320mm above the ground, free of obstructions and extending the full width of clear space? : No - Below Standard (Rating: 0)

Comments/Description : Surface has some rocks/roots. Also surface is uneven and has varied (averagely 5 degrees, up to 10 degrees in some spots)

Picnic Area

1. Are picnic tables provided? : No (Rating: 0)

Comments/Description : Picnic tables are locate nearby at the day use area

2. How many accessible picnic tables are there? : N_A

3. If the picnic table is up to 2.7m long, is there one wheelchair seating space? : N_A (Rating: 0)

4. If the picnic table is longer than 2.7m, are there at least two wheelchair spaces provided? : N_A (Rating: 0)

5. Is there clear and level ground space, 915mm measured from back edge of seats/benches? : N_A (Rating: 0)

6. Do the accessible spaces have adequate knee clearance, 685mm high x 760mm wide x 430mm deep? : N_A (Rating: 0)

7. Is the ground surface surrounding the accessible picnic table firm and stable? : N_A (Rating: 0)

8. Is there a clear, level accessible route to the picnic table? : N_A (Rating: 0)

Shelters

1. Are there any camp shelters? : No (Rating: 0)

2. What is the slope at the entrance to the camp shelter? : N_A (Rating: 0)

3. What type of surface is in the camp shelter? : N_A

4. Is the shelter surface firm and stable? : N_A (Rating: 0)

5. Is there a clear, level accessible route to the camp shelter? : N_A (Rating: 0)

Comments/Description : Located at the end of the trail, at the view point, which is not accessible for wheelchairs and may be difficult to manage for people with mobility issues

2. If yes, how many benches are there? : 1

Measurement
(mm) : 495

Comments/Description : Bench sits on an area that is sloped (over 5 degrees)

4. Is there a minimum of 915mm x 1220mm clear ground space beside the bench? : N_A (Rating: 0)

Comments/Description : sloped area; not set up for space for wheelchairs to access

5. Is there a clear, level accessible route to the bench? : N_A (Rating: 0)

Comments/Description : At the beginning of the trail

**Measurement
(mm) : 960**

4. If there are operable parts, can they be operated using one hand, without tightly grasping, pinching, or twisting the wrist and with no more than 2.3kg of force? : No (Rating: 0)

Comments/Description : parts are used with flattened hand reaching into slot, push level and lift up. Lid is heavy and requires over 2.3 kg of force.

Campfires & Grills

1. Is there an area for campfires? : No (Rating: 0)

Comments/Description : campfires located nearby in day use area

2. Is there a minimum of 1220mm clear ground space on all sides? : N_A (Rating: 0)

3. Is the slope 3° or less in all directions? : N_A (Rating: 0)

4. Is the grill height between 380mm - 865mm above the ground? : N_A (Rating: 0)

5. Is the fire building surface height at least 230mm above the ground? : N_A (Rating: 0)

6. If there is a raised edge or wall around the fire building area, is the thickness less than 255mm? : N_A (Rating: 0)

7. Is there a clear, level accessible route to the campfire area? : N_A (Rating: 0)

1. Are any public washrooms located at the trail head or on the trail? : No



Description of Photo 1 : Trail is covered by roots for approx. the last 30 metres heading to the viewpoint.



Description of Photo 2 : Viewpoint overlooking creek and canyon. Bench is located in the foreground. Not suitable for wheelchairs and possibly those with mobility issues. Recommend use of boardwalk/deck to make this a more accessible part of the park.

Description of Photo 3 : View of north east section of canyon from viewpoint

Washrooms

Date of Audit : 2016-08-12

Auditors Names : Barbara

Weather condition during audit : Sunny

Washroom # : 1

Description of washroom location : Parking Lot adjacent to Day use area

Type of Washroom : Out-house



1. If washrooms are available to the public, is at least one washroom designated as accessible? (Either one for each sex, or one unisex.) : Yes (Rating: 1)

Directional signage

2. Are there signs at inaccessible washrooms that give directions to accessible washrooms? : No (Rating: 0)

3. Is there an accessible route to the accessible washroom? : Yes (Rating: 1)

4. If not all washrooms are accessible, is there a sign at the accessible washroom with the International Symbol of Accessibility? : No (Rating: 0)

Comments/Description : This outhouse is one of two with accessible features; this audited outhouse is in fact bigger than the other which does have the symbol of accessibility

Recommendations : Add International sign of Accessibility

Improvement Priority : High

Estimated Cost : Low

5. Do text characters contrast with their backgrounds? : N_A (Rating: 0)

6. Are text characters raised? : N_A (Rating: 0)

7. Is there Braille? : N_A (Rating: 0)

8. Is the sign mounted on the wall, on latch side of the door?

Note: Signs are permitted on the push side of doors with closers and without hold-open devices. : No (Rating: 0)

9. So the baseline of the lowest character is at least 1220mm above the floor and the baseline of the highest character is no more than 1525mm above the floor?

Note: If the sign is at double doors with one active leaf, the sign should be on the inactive leaf; if both leaves are active, the sign should be on the wall to the right of the right leaf. : No (Rating: 0)

**Measurement
(mm) : 1640**

Comments/Description : Washroom symbol

Interior doors

10. Is the door opening width at least 815mm clear, between the face of the door and the stop, when the door is open 90°? : N_A (Rating: 0)

11. If there is a front approach to the pull side of the door, is there at least 455mm of maneuvering clearance beyond the latch side plus at least 1525mm clear depth? : N_A (Rating: 0)

12. On both sides of the door, is the floor surface of the maneuvering clearance level (no steeper than 1°)? : N_A (Rating: 0)

13. If the threshold is vertical is it no more than 6mm high?

Or : N_A (Rating: 0)

14. If the threshold is beveled, is it no more than 19mm high? : N_A (Rating: 0)

15. Is the door equipped with hardware that is operable with one hand and does not require tight grasping, pinching or twisting of the wrist? : N_A (Rating: 0)

16. Are the operable parts of the hardware no less than 865mm and no greater than 1220mm above the floor? : N_A (Rating: 0)

17. Can the door be opened easily, maximum 2.3kg of force?

Note: You can use a pressure gauge or fish scale to measure force. : N_A (Rating: 0)

18. If the door has a closer, does it take at least 5 seconds to close from open position of 90° to a position of 12° from the latch? : N_A (Rating: 0)

19. If there are two doors in a series, e.g. vestibule, is the distance between the doors at least 1220mm plus the width of the doors when swinging into the space? : N_A (Rating: 0)

20. If there is a privacy wall and the door swings out, is there at least 610mm of maneuvering clearance beyond the door latch side and 1065mm to the privacy wall? : N_A (Rating: 0)

21. If there is a privacy wall and the door swings in, is there at least 610mm of maneuvering clearance beyond the door latch side and at least 1220mm to the privacy wall if there is no door closer or at least 1370mm if there is a door closer? : N_A (Rating: 0)

22. In a unisex washroom if the door swings in and over a clear floor space at an accessible fixture, is there a clear floor space at least 760mm x 1220mm beyond the swing of the door? : N_A (Rating: 0)

Toilet stall

23. Is there an individual accessible toilet stall? : Yes (Rating: 1)

Comments/Description : Outhouse is individual toilet stall

24. Is the stall door opening width at least 815mm clear, between the face of the door and the stop, when the door is open 90°? : Yes (Rating: 1)

**Measurement
(mm) :** 890

25. If there is a front approach to the pull side of the stall door, is there at least 455mm of maneuvering clearance beyond the latch side plus 1525mm clear depth? : Yes (Rating: 1)

**Clearance
(mm) :** 1000

**Depth
(mm) :** 1300

27. Are there door pulls on both sides of the door that are operable with one hand and do not require tight grasping pinching or twisting of the wrist?* : No (Rating: 0)

Comments/Description : Outer door handle - small vertical, hand does not fit in Inner door handle - horizontal grab bar (770 mm)

Recommendations : replace outer handle with larger accessible style handle

Improvement Priority : Med

Estimated Cost : Med

28. Is the lock operable with one hand and without tight grasping, pinching or twisting of the wrist? : No (Rating: 0)

Comments/Description : Latch hook style lock, needs two hands to close

Recommendations : Replace latch hook with accessible style such as a slide latch.

Improvement Priority : High

Estimated Cost : Med

29. Are the operable parts of the door hardware mounted no less than 865mm and no greater than 1220mm above the floor? : Yes (Rating: 1)

**Measurement
(mm) :** 940

Comments/Description : outer handle is 940mm high; inner handle is 900 mm high.

30. Is the stall at least 1525mm wide? : Yes (Rating: 1)

Measurement

(mm) : 1600

31. If the toilet is wall hung, is the stall at least 1420mm deep?

Or : N_A (Rating: 0)

32. If the toilet is floor mounted, is the stall at least 1500mm deep? : Yes (Rating: 1)

Measurement

(mm) : 1620

If the door swings in, is the stall area beyond the swing of the door:

33. A minimum of 1525mm wide x 1420mm deep for wall hung toilet?

Or : N_A (Rating: 0)

34. A minimum of 1525mm wide x 1500mm deep for floor mounted toilet? : N_A (Rating: 0)

Toilet

35. Is the centerline of the toilet no less than 405mm and no greater than 455mm from the side wall or partition? : No (Rating: 0)

Measurement

(mm) : 470

36. Is clearance provided around the toilet measuring at least 1525mm from the side wall and at least 1420mm from the rear wall? : Yes (Rating: 1)

From side wall

(mm) : 1600

From rear wall

(mm) : 1620

37. Is the height of the toilet no less than 430mm and no greater than 485mm above the floor measured to the top of the seat? : No (Rating: 0)

Measurement

(mm) : 400

Grab bars

38. Is there a grab bar at least 1065mm long on the side wall? : No (Rating: 0)

Measurement

(mm) : 620

Recommendations : Replace with longer grab bar to meet minimum standards

Improvement Priority : High

Estimated Cost : Med

39. Is it located no more than 305mm from the rear wall? : Yes (Rating: 1)

**Measurement
(mm) : 270**

40. Does it extend at least 1370mm from the rear wall? : No (Rating: 0)

**Measurement
(mm) : 890**

Recommendations : Mount standard size grab bar using standard measurements

Improvement Priority : Med

Estimated Cost : Med

41. Is it mounted no less than 840mm and no greater than 915mm above the floor to the top of the gripping surface? : Yes (Rating: 1)

**Measurement
(mm) : 900**

42. Is there at least 305mm clearance between the grab bar and protruding objects above? : N_A (Rating: 0)

Comments/Description : no objects above grab bar

43. Is there at least 38mm clearance between the grab bar and projecting objects below? : Yes (Rating: 1)

**Measurement
(mm) : 120**

Comments/Description : Toilet paper dispenser is below grab bar

45. Is there a grab bar at least 915mm long on the rear wall? : Yes (Rating: 1)

**Measurement
(mm) : 40**

46. Does the grab bar extend at least 305mm from the centerline of the toilet on one side (side wall)? : Yes (Rating: 1)

**Measurement
(mm) : 470**

Improvement Priority : N_A

Estimated Cost : Med

47. Does the grab bar extend at least 610mm on the other (open) side? : No (Rating: 0)

**Measurement
(mm) : 310**

Recommendations : replace bar with standard length grab bar, mounted using standard measurements

Improvement Priority : Med

Estimated Cost : Low

48. Is the grab bar mounted no less than 840mm and no greater than 915mm above the floor to the top of the gripping surface? : Yes (Rating: 1)

**Measurement
(mm)** : 900

49. Are there at least 305mm clearance between the grab bar and protruding objects above? : N_A
(Rating: 0)

Comments/Description : no protruding objects

50. Are there at least 38mm clearance between the grab bar and projecting objects below? : N_A (Rating: 0)

Comments/Description : no protruding objects

51. Is the space between the wall and the grab bar 38mm inches? : Yes (Rating: 1)

**Measurement
(mm)** : 40

Comments/Description : please note measurement should read millimetres, not inches

Toilet flush controls

52. If the flush control is hand operated, is the operable part located no higher than 1220mm above the floor? : N_A (Rating: 0)

53. If the flush control is hand operated, can it be operated with one hand and without tight grasping, pinching, or twisting of the wrist? : N_A (Rating: 0)

54. Is the force required to activate the flush control no greater than 2.3kg? : N_A (Rating: 0)

55. Is the flush control on the open side of the toilet? : N_A (Rating: 0)

Toilet paper dispenser

56. Is the toilet paper dispenser located no less than 180mm and no greater than 230mm from the front of the toilet to the center line of the dispenser? : No (Rating: 0)

**Measurement
(mm)** : 140

Recommendations : adjust toilet paper dispenser location to standard measurements

Improvement Priority : Low

Estimated Cost : Low

57. Is the outlet of the dispenser: Located no less than 380mm and no greater than 1220mm above the floor? : Yes (Rating: 1)

**Measurement
(mm) : 700**

58. Is the dispenser located behind grab bars? : No (Rating: 0)

59. Does the dispenser allow continuous paper flow? : Yes (Rating: 1)

Sink

60. Does at least one sink have a clear floor space for a forward approach at least 760mm wide and 1220mm long? : N_A (Rating: 0)

61. Do no less than 430mm and no greater than 635mm of the clear floor space extend under the sink so that a person using a wheelchair can get close enough to reach the faucet? : N_A (Rating: 0)

62. Is the front of the sink or counter surface, whichever is higher, no more than 865mm above the floor? : N_A (Rating: 0)

63. Is there at least 685mm height clearance from the floor to the bottom of the sink that extends at least 205mm deep under the sink for knee clearance? : N_A (Rating: 0)

64. Is there toe clearance at least 230mm high?

Note: Space extending greater than 150mm beyond the available toe clearance at 230mm above the floor is not considered toe clearance. : N_A (Rating: 0)

65. Are pipes below the sink insulated or otherwise configured to protect against contact? : N_A (Rating: 0)

66. Can the faucet be operated without tight grasping, pinching, or twisting of the wrist? : N_A (Rating: 0)

67. Is the force required to activate the faucet no greater than 2.3 kg? : N_A (Rating: 0)

Washroom fixtures

68. Is there a clear path to at least one of each type of fixture, e.g. sink, hand dryer, garbage bin etc., that is at least 915mm wide? : N_A (Rating: 0)

69. Is there clear floor space available for a person in a wheelchair to turn around, i.e. a circle at least 1525mm in diameter or a T-shaped space within a 1525mm square? : N_A (Rating: 0)

Mirror

70. If the mirror is over a sink or countertop, is the bottom edge of the reflecting surface no higher than 1015mm above the floor?

Or : N_A (Rating: 0)

71. If the mirror is not over the sink or countertop, is the bottom edge of the reflecting surface no higher

than 890mm above the floor? : N_A (Rating: 0)

Coat hook

72. If there is a coat hook, is it no less than 380mm and no greater than 1220mm above the floor?* : No (Rating: 0)

Measurement (mm) : 1670

Soap dispenser

Are the operable parts of the soap dispenser within one of the following reach ranges:

73. Above sinks or counters no less than 510mm and no greater than 635mm deep: no higher than 1120mm above the floor?

Or : N_A (Rating: 0)

74. Above sinks less than 510mm deep: no higher than 1220mm above the floor?

Or : N_A (Rating: 0)

75. Not over an obstruction: no higher than 1220mm above the floor? : N_A (Rating: 0)

Hand dryer/Towel dispenser

Are the operable parts of the hand dryer or towel dispenser within one of the following reach ranges:

76. Above sinks or counters no less than 510mm and no greater than 635mm deep: no higher than 1120mm above the floor?

Or : N_A (Rating: 0)

77. Above sinks less than 510mm deep: no higher than 1220mm above the floor?

Or : N_A (Rating: 0)

78. Not over an obstruction: no higher than 1220mm above the floor? : N_A (Rating: 0)

79. Can the operable parts of the hand dryer or towel dispenser be operated without tight grasping, pinching or twisting of the wrist? : N_A (Rating: 0)

80. Is the force required to activate the hand dryer or towel dispenser no greater than 2.3kg? : N_A (Rating: 0)

Controls - light switches

81. Is there a clear floor space at least 760mm wide by at least 1220mm long for a forward or parallel approach? : N_A (Rating: 0)

83. Can the control be operated with one hand and without tight grasping, pinching, or twisting of the wrist? : N_A (Rating: 0)

1. Has the route to the washroom been evaluated? : No -
 _ACCESS_ROUTE_checklist_must_also_be_completed



Description of Photo 1 : Access route to accessible bathroom from Parking in Day use area. Note: although this bathroom is accessible, it does not have the universal sign on the building

Description of Photo 2 : Two outhouses in campsite; not accessible for wheelchairs

Camping

Date of Audit (YYYY-MM-DD) : 2016-08-12

Name of Campground : Kleanza Creek

Location of Campsite : #10 - creekside; south east side of park, adjacent to day use area

Weather condition during audit : Sunny



1. Does the number of accessible camp sites comply with the table above? : N_A (Rating: 0)

Comments/Description : No campsites have accessible features

Recommendations : add accessible features to campsites; use table to determine number of sites needed for park

Improvement Priority : High

Estimated Cost : High

Campsite

2. Is the camp site surface firm and stable? : Yes (Rating: 1)

3. What type of surface is in the campsite? : Gravel

Comments/Description : hardpacked gravel

4. Is the accessible campsite at least 4.9m wide?

Or : Yes _ _ Exceeds _ Standard

Measurement

(m) : 5

5. If it is an RV site, is the parking area at least 6m wide? : N_A (Rating: 0)

6. If the campsite surface is concrete or asphalt, is the slope 1° or less? : N_A (Rating: 0)

7. If the campsite surface is anything other than concrete & asphalt, is the slope 3° or less? : Yes _ _ Exceeds _ Standard

Comments/Description : slope is 1-2 degrees

Tent Pads/Platforms

8. Is there a minimum of 1220mm clear space on all sides surrounding the tent pad or platform? : N_A (Rating: 0)

Measurement

(mm) : 1220

Comments/Description : no pads or platforms; space for tent measuring no more than 2 metres by 3.6 metres will have 1220 clear space on all sides in the space provided.

9. What type of surface is the tent pad/ platform? : Gravel

Comments/Description : area for tent placement

10. What is the slope of the tent pad/ platform? : Flat _ Gentle _ 1 _ or _ less

Comments/Description : - this refers to space available for tent in campsite

11. Is there an accessible entrance or ramp on to the tent pad/platform? : N_A (Rating: 0)

Utility & Sewage Hook Ups

12. Is there sufficient clear ground space, a minimum of 1220mm x 1525mm surrounding the hook ups? : N_A (Rating: 0)

Comments/Description : no sewage/utility

13. If there are operable parts, can they be operated using one hand, without tightly grasping, pinching, or twisting the wrist and with no more than 2.3kg of force? : N_A (Rating: 0)

Campfires & Grills

14. Is there an area for campfires? : Yes (Rating: 1)

15. Is there a minimum of 1220mm clear ground space on all sides? : No _ _ Below _ Standard (Rating: 0)

Measurement**(mm) : 800****Comments/Description** : Three sides of the campfire have clearance above 1220 mm; one side has 800**16. Is the slope 3° or less in all directions? : Yes (Rating: 1)****Measurement****(angle °) : 1****17. Is the grill height between 380mm - 865mm above the ground? : Yes (Rating: 1)****Measurement****(mm) : 395****18. Is the fire building surface height at least 230mm above the ground? : No (Rating: 0)****Measurement****(mm) : 0****Comments/Description** : fire building surface is flush with the ground surface**Recommendations** : Build up fire building surface to at least 230 mm**Improvement Priority** : Med**Estimated Cost** : Low**19. If there is a raised edge or wall around the fire building area, is the thickness less than 255mm? : Yes (Rating: 1)****Measurement****(mm) : 5****20. Is there a clear, level accessible route to the campfire area? : Yes (Rating: 1)****21. Are picnic tables provided? : Yes (Rating: 1)****22. How many accessible picnic tables are there? : N_A****Comments/Description** : Older style of picnic table; set on concrete pad; table has attached bench with obstructed clearance for feet/legs when sliding on to bench**23. If the picnic table is up to 2.7m long, is there one wheelchair seating space? : N_A (Rating: 0)****24. If the picnic table is longer than 2.7m, are there at least two wheelchair spaces provided? : N_A (Rating: 0)****25. Is there clear and level ground space, 915mm measured from back edge of seats/benches? : No - _Below_Standard (Rating: 0)****Measurement****(mm) : 850**

Comments/Description : Clearance at rear of table; tent side is more than 2 metres

26. Do the accessible spaces have adequate knee clearance, 685mm high x 760mm wide x 430mm deep? : N_A (Rating: 0)

27. Is the ground surface surrounding the accessible picnic table firm and stable? : Yes (Rating: 1)

28. Is there a clear, level accessible route to the picnic table? : Yes (Rating: 1)

Water Taps

1. Are there any water taps? : Yes (Rating: 1)

Comments/Description : There is one water pump with a pumping handle. See photo in this checklist. Measurement surrounding pump are as follows: Handle height: 1700mm Force required to pull handle: 4.5 kg Spout is 890 mm high Pump sits in centre of concrete pad 1500 x 1500 mm Pad edge is 65 mm high Other access route, from parking lot, is quite steep (more than 6 degrees)

2. Is there sufficient clear ground space, a minimum of 1829mm x 1220mm surrounding the water tap? : No - Below Standard (Rating: 0)

Measurement

(mm x mm) : 1500 x 1500

Comments/Description : Pump sits in centre of concrete pad 1500 x 1500 mm Pad edge is 65 mm high

3. Is the water spout height between 280mm - 305mm? : No (Rating: 0)

Measurement

(mm) : 890

4. Is the height of operable parts (i.e. taps or levers) between 380mm - 1220mm above the ground? : No (Rating: 0)

Measurement

(mm) : 1700

Comments/Description : Handle for water pump is at 1700 mm, and would be difficult to access due to where the pump sits (concrete pad)

5. If there are operable parts, can they be operated using one hand, without tightly grasping, pinching, or twisting the wrist and with no more than 2.3kg of force? : Yes (Rating: 1)

Comments/Description : Handle is a pump; may not be accessible for some due to the height.

6. Is there a clear, level accessible route to the water tap? : No (Rating: 0)

Comments/Description : Access route is a path from campsite road that is 1600 mm wide; narrow section 1300mm. Running slope is 2-3 degrees, with steepest part 6 degrees. Cross slope is 4 degrees, steepest part is 5 degrees. The pump can also be accessed from day use parking however the path is steeper.

Water Fountains

1. Is there a water fountain? : Yes (Rating: 1)

2. Does it have a lever or push bar control on the front or both sides? : N_A (Rating: 0)

3. Is the spout opening height between 750mm - 915mm above the ground? : N_A (Rating: 0)

4. Is there a minimum width of 800mm clearance space directly in front of the water fountain? : N_A (Rating: 0)

Trash & Recycling Receptacles

1. Are there any trash &/or recycling receptacles? : Yes (Rating: 1)

Comments/Description : Campground has three locations with trash and recycling receptacles.

2. Is the approach to the receptacle level, with no-step? : Yes (Rating: 1)

3. If there are operable parts, is their height between 380mm - 1220mm above the ground? : Yes (Rating: 1)

Measurement (mm) : 940

4. If there are operable parts, can they be operated using one hand, without tightly grasping, pinching, or twisting the wrist and with no more than 2.3kg of force? : No (Rating: 0)

Comments/Description : receptacles need one hand with fingers extended to fit into lever; fingers then needs to push lever and hand needs to lift upwards to open. Force needed to lift up lid is more than 2.3 kg

5. Is there a clear, level accessible route to the trash/recycling receptacle? : Yes (Rating: 1)

Comments/Description : Access routes to two of three locations are accessible; one location, in the day use area, has access routes that are very steep. As there is another location close by, it would not matter.

Shelters

1. Are there any camp shelters? : No (Rating: 0)

2. What is the slope at the entrance to the camp shelter? : N_A (Rating: 0)

3. What type of surface is in the camp shelter? : N_A

4. Is the shelter surface firm and stable? : N_A (Rating: 0)

5. Is there a clear, level accessible route to the camp shelter? : N_A (Rating: 0)

Benches

1. Are any benches provided? : Yes (Rating: 1)

Comments/Description : There are 6 benches located in the campground. These will be added to the WATER ACCESS checklist

3. Is the bench seat height between 485mm - 510mm? : N_A (Rating: 0)

4. Is there a minimum of 915mm x 1220mm clear ground space beside the bench? : N_A (Rating: 0)

5. Is there a clear, level accessible route to the bench? : N_A (Rating: 0)

Playground

1. Is there a playground? : No (Rating: 0)

Comments/Description : There is a spot to play horseshoes in a dirt lot adjacent to the parking lot. The surface of this area is uneven and has a lot of loose dirt. The horseshoe pitch also uneven. note: There is a bench at this location

2 What type of surface is in the play area? : N_A

3. Is the play area surface firm and stable? : N_A (Rating: 0)

4. Are any of the playground components accessible to wheelchair users? If yes, please describe. : N_A (Rating: 0)

5. Is there a clear, level accessible route to the playground? : N_A (Rating: 0)

Amphitheatre

1. Is there an amphitheatre? : No (Rating: 0)

Amphitheatre Seating

2. Are an adequate number of wheelchair spaces provided? : N_A (Rating: 0)

3. Are wheelchair spaces dispersed to allow location choices and viewing angles equivalent to other seating, including specialty seating areas that provide distinct services and amenities? : N_A (Rating: 0)

4. Where people are expected to remain seated, do people in wheelchair spaces have a clear line of sight over and between the heads of others in front of them? : N_A (Rating: 0)

5. Where people are expected to stand, do people in wheelchair spaces have a clear line of sight over and between the heads heads of others in front of them? : N_A (Rating: 0)

6. If there is a single wheelchair space, is it at least 915mm wide? : N_A (Rating: 0)

7. If there are two adjacent wheelchair spaces, are they each at least 840mm wide? : N_A (Rating: 0)

8. If the wheelchair space can be entered from the front or rear, is it at least 1220mm deep? : N_A (Rating: 0)

9. If the wheelchair space can only be entered from the side, is it at least 1525mm deep? : N_A (Rating: 0)

10. Do wheelchair spaces adjoin, but not overlap, accessible routes? : N_A (Rating: 0)

11. Is there at least one companion seat for each wheelchair space? : N_A (Rating: 0)

12. Is the companion seat located so the companion is shoulder-to-shoulder with the person in a wheelchair? : N_A (Rating: 0)

13. Is the companion seat equivalent in size, quality, comfort and amenities to seating in the immediate area? : N_A (Rating: 0)

2. Are there any public buildings (visitors centre/ interpretive centre/cafes etc) at the campground? : No (Rating: 0)

3. Are there any trails at the campground? : Yes - _TRAILS_checklist_must_also_be_completed (Rating: 0)

4. Is there a beach, dock/fishing platform or boat launch? : Yes - _WATER_ACCESS_checklist_must_also_be_completed (Rating: 0)



Description of Photo 1 : Water pump and access path from campsite road. Recommend adding a water tap with universal design features



Description of Photo 2 : Although there is no playground, there is a horseshoe pitch, with a bench, which sits in a shady area next to the day use parking area, and in close proximity to accessible outhouse. Pitch has a somewhat uneven surface.



Description of Photo 3 : Short trail near campsites that connects creekside campsites to day use picnic area. There are also benches along this trail. Could be made wider with a stable, level surface for universal access. The trail loops around to campsite paved road, and would then make a good loop trail that would be accessible.

Description of Photo 4 : recycling and trash receptacles

Water Access

Date of Audit : 2016-08-12

Body of water : Ocean

Location : Runs the length of the park on the south side

Weather condition during audit : Sunny



Comments/Description : 16 assigned spaces

2. Are an adequate number of accessible spaces provided? : No - _Below_Standard (Rating: 0)

Total # : 16

Accessible # : 0

Comments/Description : No designated accessible parking

Recommendations : Add accessible parking spaces to lot using chart to determine number of spaces. Put spaces adjacent to accessible outhouse, located near parking lot

Improvement Priority : High

Estimated Cost : Low

3. Of the accessible spaces, is at least one a van accessible space?* : N_A (Rating: 0)

4. Are accessible spaces at least 2.4m wide with an access aisle at least 1.5m wide? Note: Two spaces may share an access aisle. : N_A (Rating: 0)

5. Are the access aisles marked to discourage parking in them? : N_A (Rating: 0)

6. Is the slope of the accessible parking spaces and access aisles no steeper than 1Â° in all directions? : N_A (Rating: 0)

7. Does the access aisle adjoin an accessible route? : N_A (Rating: 0)

8. Are accessible spaces identified with a sign that includes the International Symbol of Accessibility? Note: The International Symbol of Accessibility is not required on the ground. : N_A (Rating: 0)

9. Of the total parking spaces, are the accessible spaces located on the closest accessible route to the accessible entrance(s)? Note: If parking serves multiple entrances, accessible parking should be dispersed. : N_A (Rating: 0)

From : Picnic site

To : Creek beach area

General

1. Is there at least one route from site arrival points (parking, loading zone, bus stop etc) that does not require the use of stairs? : No (Rating: 0)

Comments/Description : The beach area beside the creek is accessed by a short (5 metre)but steep trail with rocks and dirt; the surface is somewhat unstable with loose dirt/rocks. A second access route exists, leading from a viewing/bench area of the day use area but this is also a short steep trail that cuts through an area of large rocks. Not wheelchair accessible.

Recommendations : Dirt trail leading from the picnic area could be redone to include board or rock style low steps, with a rail, for greater accessibility and safety.

Improvement Priority : Med

Estimated Cost : High

2. What is the condition of the surface along this route? : Poor (Rating: 0)

Comments/Description : The trail itself is not firm, but has larger rocks, and a somewhat loose dirt/rock surface which can be difficult to manage, especially going down. Also to note: this beach area is not always accessible in the spring time. High water can cover the beach area until May or June.

Recommendations : Trail could be remade with steps or remade with a more gentle slope

Improvement Priority : Med

Estimated Cost : High

Surface

3. Is the surface firm and stable? : No (Rating: 0)

4. What is the type of surface? : Other_add_in_comments

Comments/Description : Combination of dirt and rock, with larger rocks in the pathway as well.

Clear Width

5. What is the typical route width (mm)? : less_than_915 (Rating: 0)

Recommendations : There is space for the trail to be widened.

Improvement Priority : Med

Estimated Cost : High

6. What is the narrowest route width (mm)? : less_than_915 (Rating: 0)

Obstacles

7. If the route is concrete, asphalt or boardwalk, are there any obstacles that exceed 13mm from the surface? : N_A (Rating: 0)

8. If yes, are the obstacles at least 1220mm apart? : N_A (Rating: 0)

Comments/Description : There are some larger sized rocks in the path (from 100 - 200 mm in size)

Recommendations : Make a wider, clear path that can be packed for stability, or make steps.

Improvement Priority : Med

Estimated Cost : High

10. If yes, are the obstacles at least 1220mm apart? : No (Rating: 0)

Comments/Description : rocks are present all the way up the short path.

Openings

11. Are there any gaps or grates present that have an opening greater than 13mm? : No (Rating: 0)

12. If gaps/grates are present, do they run perpendicular to the path of travel? : N_A (Rating: 0)

Running Slope

13. What is the typical running slope on the route? : Very_steep_above_5 (Rating: 0)

Comments/Description : This trail is not recommended for wheelchairs - may also be difficult to manage for people with other mobility issues.

14. What is the maximum running slope on the route? : Very_steep_above_5 (Rating: 0)

Cross Slope

15. What is the typical cross slope on the route? : Moderate_2_-_3 (Rating: 1)

16. What is the maximum cross slope on the route? : Moderate_2_-_3 (Rating: 1)

Resting Intervals

17. Are there resting intervals at the top and bottom of a route where the grade exceeds 3°? : N_A (Rating: 0)

Comments/Description : short route

18. If the running slope is greater than 3°, are there resting intervals in the middle of the route when the length exceeds 9.1m? : N_A (Rating: 0)

Protruding Objects

19. Is there a minimum of 2030mm vertical clearance for users to safely pass along the route without coming into contact with overhanging obstacles? : Yes_-_meets_standard (Rating: 1)

Comments/Description : Overhanging branches are kept clear to this height

20. Is there a minimum of 100mm horizontal clearance for users to safely pass along the route without coming into contact with side obstacles? : Yes_-_meets_standard (Rating: 1)

Comments/Description : route is kept clear from protruding bushes to provide standard clearance

Benches

21. Are there any benches along the route? : No (Rating: 0)

Comments/Description : short route

22. If yes, are the benches located approximately every 61m? : N_A (Rating: 0)

23. Is the bench seat height between 485mm - 510mm? : N_A (Rating: 0)

Ramps

24. Is there is a ramp? : No (Rating: 0)

25. Is the ramp at least 915mm wide?

Note: If there are handrails, measure between the handrails. : N_A (Rating: 0)

26. Is the surface stable, firm and slip resistant? : N_A (Rating: 0)

27. For each section of the ramp, is the running slope no greater than 5°?

Note: Rises no greater than 76mm with a slope no steeper than 7° and rises no greater than 150mm with a slope no steeper than 6° are permitted when due to space limitations. : N_A (Rating: 0)

30. Is there a level landing where the ramp changes direction that is at least 1525mm x 1525mm? : N_A (Rating: 0)

31. If the ramp has a rise higher than 150mm are there handrails on both sides? : N_A (Rating: 0)

32. Is the top of the handrail gripping surface no less than 865mm and no greater than 965mm above the ramp surface? : N_A (Rating: 0)

33. Is the handrail gripping surface continuous and not obstructed along the top or sides? : N_A (Rating: 0)

34. If there are obstructions, is the bottom of the gripping surface obstructed no more than 20%? : N_A (Rating: 0)

Stairs

35. Are there floors or surfaces connected only by stairs, not an elevator or ramp? : No (Rating: 0)

36. How many flights of stairs are there? : N_A

37. If there are less than a flight, how many stairs are there? : N_A

38. Do all stair treads have a horizontal strip at the edge that is: 40mm-60mm deep, colour contrasted & extends the full width of the step? : N_A (Rating: 0)

39. If the stairs are not enclosed, is there a tactile warning system present at the landing of entrance to stairs system? : N_A (Rating: 0)

40. Are there handrails on both sides of the stairs at a uniform height of 860mm-920mm above the front step? : N_A (Rating: 0)

41. Do the handrails extend horizontally at the top and bottom of each flight of stairs? : N_A (Rating: 0)

42. Are the handrails continuous around landings? : N_A (Rating: 0)

43. Are the handrails continuously graspable, without interruption by vertical supports, newel posts, or other construction elements which require repositioning the hands while ascending or descending? : N_A (Rating: 0)

44. Do the handrails have a graspable cross-section that is either circular with an outside diameter of 30mm-40mm or elliptical with an outside perimeter of 100mm-125mm? : N_A (Rating: 0)

2. What type of surface is the beach area? : Other_add_in_comments

Comments/Description : Mostly rocks with some gravel areas. This area is under water during the spring time, and debris from the creek and from the cliffs above fall onto this area. It would not likely be possible to change this beach area from it's natural state, other than to possibly clear larger rocks if needed.

Measurement (m) : 7

Comments/Description : This distance will vary depending on the time of year, rainfall, spring run-off, etc.

4. Is there a clear route to the water edge that is: at least 915mm wide, level and has a firm/stable surface? : N_A (Rating: 0)

Comments/Description : The beach does not have an accessible route and is not suitable for wheelchair access. Could be difficult to manage for anyone with mobility issues.

Dock/Fishing Platform

1. Is there a dock or fishing platform? : No (Rating: 0)

2. For each section of the gangway, is the running slope no greater than 5°? : N_A (Rating: 0)

3. Is the gangway at least 9.1m long? : N_A (Rating: 0)

4. If a transition plate is steeper than 3°, is there a landing at the end of the transition plate? : N_A (Rating: 0)

5. Are there any gaps or grates present that have an opening greater than 13mm? : N_A (Rating: 0)

6. If gaps/grates are present, do they run perpendicular to the path of travel? : N_A (Rating: 0)

7. If there are railings/guards/handrails on the dock/fishing platform, are at least 25% accessible with no more than 865mm above the ground or deck? : N_A (Rating: 0)

8. Are the accessible railings dispersed throughout the dock/fishing platform? : N_A (Rating: 0)

9. Is there a clear space at least 1220mm long x 760mm wide at the accessible railing? : N_A (Rating: 0)

10. Is there a curb or barrier extending 51mm minimum above the surface of the dock/fishing platform? :
N_A (Rating: 0)

11. If there are no railings, is there a clear space at least 1220mm long x 760mm wide on the dock/fishing platform surface? : N_A (Rating: 0)

12. Is there a clear space for a person in a wheelchair to turn around, i.e. a circle at least 1525mm in diameter? : N_A (Rating: 0)

Boat Launch

1. Is there a boat launch? : No (Rating: 0)

Comments/Description : n/a

Comments/Description : n/a

4. What type of surface is the boat launch? : N_A

5. Is the boat launch surface firm and stable? : N_A (Rating: 0)

6. Is there a clear, level accessible route to the boat launch? : N_A (Rating: 0)

2. How many accessible picnic tables are there? : N_A

Comments/Description : None of the tables in the picnic area are accessible

Recommendations : Lots of space and open areas for accessible tables.

Improvement Priority : High

Estimated Cost : High

3. If the picnic table is up to 2.7m long, is there one wheelchair seating space? : N_A (Rating: 0)

4. If the picnic table is longer than 2.7m, are there at least two wheelchair spaces provided? : N_A (Rating: 0)

5. Is there clear and level ground space, 915mm measured from back edge of seats/benches? : Yes -
_Exceeds_Standard

**Measurement
(mm) :** 2000

Comments/Description : more than 2 m

6. Do the accessible spaces have adequate knee clearance, 685mm high x 760mm wide x 430mm deep? :
N_A (Rating: 0)

Shelters

1. Are there any camp shelters? : No (Rating: 0)

2. What is the slope at the entrance to the camp shelter? : N_A (Rating: 0)

3. What type of surface is in the camp shelter? : N_A

4. Is the shelter surface firm and stable? : N_A (Rating: 0)

5. Is there a clear, level accessible route to the camp shelter? : N_A (Rating: 0)

Comments/Description : Benches are located in strategic areas for views of the creek although not located directly down by the water/beach area.

2. If yes, how many benches are there? : 6

Comments/Description : Three benches are located within view of the creek area; one bench located at horseshoe pitch; 2 benches are located along the creek side trail. Another bench is located at the viewpoint (trail leads uphill to an area that overlooks beach area)

3. Is the bench seat height between 485mm - 510mm? : No (Rating: 0)

**Measurement
(mm) :** 440

4. Is there a minimum of 915mm x 1220mm clear ground space beside the bench? : Yes -
_Exceeds_Standard

**Measurement
(mm x mm) :** 1300 x 1500

Comments/Description : Benches in picnic area have these measurements. Benches on trail - see trail checklist.

**Measurement
(mm) :** 960

4. If there are operable parts, can they be operated using one hand, without tightly grasping, pinching, or twisting the wrist and with no more than 2.3kg of force? : No (Rating: 0)

Comments/Description : receptacles are opened with straight, flattened hand to insert into opening, push lever, then pull upwards to open. More than 2.3 to pull lids upwards (heavy).

Comments/Description : picnic sites beside water access area has 4 campfire pits

2. Is there a minimum of 1220mm clear ground space on all sides? : Yes -_Exceeds_Standard

**Measurement
(mm) :** 1300

Comments/Description : Clear space from picnic tables; edge of picnic area (steep hill down to creek)

**Measurement
(angle °) :** 2

**Measurement
(mm) :** 560

5. Is the fire building surface height at least 230mm above the ground? : No (Rating: 0)

Measurement**(mm) : 0****Comments/Description** : building surface flush with with ground**Measurement****(mm) : 5****Playground****1. Is there a playground?** : No (Rating: 0)**2 What type of surface is in the play area?** : N_A**3. Is the play area surface firm and stable?** : N_A (Rating: 0)**4. Are any of the playground components accessible to wheelchair users? If yes, please describe.** : N_A (Rating: 0)**5. Is there a clear, level accessible route to the playground?** : N_A (Rating: 0)**1. Is there water access in separate areas at the site?** : No**2. Are there any trails commencing from water access?** : No**3. Are any public washrooms located at water access?** : Yes -
_WASHROOMS_checklist_must_also_be_completed

Description of Photo 1 : Start of the access route to the water. This path begins at the parking lot, then goes through the grassy area, to a short, steep path down to the Creek beach area which is rocky. The grassy area shown here is also not very level. This area could be leveled out, and the path widened and/or a low stair path put in for greater accessibility. This spot is also a good viewpoint for the Creek canyon (where the picnic table is). Included is a park interpretive sign with info on this area.



Description of Photo 2 : One of the benches, at the end of the creekside picnic area. This leads to a creekside/campsite trail which could be widened and made to be accessible (currently narrow and unstable in parts, very close to steep hill going down to creek).

Description of Photo 3 : View of creekside water access area. This is accessible from the picnic site.

Goods and Services