

Mt Robson Visitors Centre ▼

Information

Date of Audit: 2016-08-09

Park Name: Mt Robson Visitors Centre

Key Features: Visitors_Centre,View_Point,Picnic_Site,Trails,Playground

Location: Fraser Fort George, Valemount, Northern BC - Provincial : Goods & Services (Lakes and Trails Circle Route)

Description: While not a viewpoint per se, the large accessible deck at the visitor centre is a great place to view Mt. Robson and surrounding peaks

Parking

Parking

1. **Is parking provided for the public?** : No (Rating: 0)
2. **Are an adequate number of accessible spaces provided?** : N_A (Rating: 0)
3. **Of the accessible spaces, is at least one a van accessible space?*** : N_A (Rating: 0)
4. **Are accessible spaces at least 2.4m wide with an access aisle at least 1.5m wide? Note: Two spaces may share an access aisle.** : N_A (Rating: 0)
5. **Are the access aisles marked to discourage parking in them?** : N_A (Rating: 0)
6. **Is the slope of the accessible parking spaces and access aisles no steeper than 1Â° in all directions?** : N_A (Rating: 0)
7. **Does the access aisle adjoin an accessible route?** : N_A (Rating: 0)
8. **Are accessible spaces identified with a sign that includes the International Symbol of Accessibility? Note: The International Symbol of Accessibility is not required on the ground.** : N_A (Rating: 0)
9. **Of the total parking spaces, are the accessible spaces located on the closest accessible route to the accessible entrance(s)? Note: If parking serves multiple entrances, accessible parking should be dispersed.** : N_A (Rating: 0)

Access Routes

From: : End of Interpretive Trail

To: : Accessible out house

Comments/Description : distance is 29 meters. Add Distance to the Access route Checklist

2. **What is the condition of the surface along this route?** : Good

Comments/Description : Concrete walkway features 3 level (less than 1 degree running slope) resting intervals

4. **What is the type of surface?** : Other_add_in_comments

Comments/Description : compact dirt and gravel

Clear Width

5. What is the typical route width (mm)? : More_than_1525 (Rating: 0)

Comments/Description : 2000mm

6. What is the narrowest route width (mm)? : More_than_1525 (Rating: 0)

Comments/Description : 1800mm

Obstacles

7. If the route is concrete, asphalt or boardwalk, are there any obstacles that exceed 13mm from the surface? : No (Rating: 0)

8. If yes, are the obstacles at least 1220mm apart? : N_A (Rating: 0)

9. If the route is anything other than concrete, asphalt or boardwalk, are there any obstacles that exceed 25mm from the surface? : N_A (Rating: 0)

10. If yes, are the obstacles at least 1220mm apart? : N_A (Rating: 0)

Openings

11. Are there any gaps or grates present that have an opening greater than 13mm? : No (Rating: 0)

12. If gaps/grates are present, do they run perpendicular to the path of travel? : N_A (Rating: 0)

Running Slope

13. What is the typical running slope on the route? : Flat_Gentle_1_or_less

Comments/Description : 1 degree typical running slope

14. What is the maximum running slope on the route? : Flat_Gentle_1_or_less

Comments/Description : 1.8 degree max running slope

Cross Slope

15. What is the typical cross slope on the route? : Flat_Gentle_1_or_less

Comments/Description : 3.7 degree typical running slope

16. What is the maximum cross slope on the route? : Flat_Gentle_1_or_less

Comments/Description : 5 degree max running slope

Resting Intervals

17. Are there resting intervals at the top and bottom of a route where the grade exceeds 3°? : N_A (Rating: 0)

Comments/Description : with the concrete pathway there was still 3 resting intervals even though the grad didn't exceed 3 degrees

18. If the running slope is greater than 3°, are there resting intervals in the middle of the route when the length exceeds 9.1m? : N_A (Rating: 0)

Comments/Description : running and cross slopes on the resting intervals were from 0 to 1 degrees

Benches

21. Are there any benches along the route? : No (Rating: 0)

22. If yes, are the benches located approximately every 61m? : N_A (Rating: 0)

23. Is the bench seat height between 485mm - 510mm? : N_A (Rating: 0)

Ramps

24. Is there is a ramp? : No (Rating: 0)

25. Is the ramp at least 915mm wide?

Note: If there are handrails, measure between the handrails. : N_A (Rating: 0)

26. Is the surface stable, firm and slip resistant? : N_A (Rating: 0)

27. For each section of the ramp, is the running slope no greater than 5°?

Note: Rises no greater than 76mm with a slope no steeper than 7° and rises no greater than 150mm with a slope no steeper than 6° are permitted when due to space limitations. : N_A (Rating: 0)

28. Is there a level landing that is at least 1525mm long and at least as wide as the ramp: At the top of the ramp? : N_A (Rating: 0)

29. At the bottom of the ramp? : N_A (Rating: 0)

30. Is there a level landing where the ramp changes direction that is at least 1525mm x 1525mm? : N_A (Rating: 0)

31. If the ramp has a rise higher than 150mm are there handrails on both sides? : N_A (Rating: 0)

32. Is the top of the handrail gripping surface no less than 865mm and no greater than 965mm above the ramp surface? : N_A (Rating: 0)

33. Is the handrail gripping surface continuous and not obstructed along the top or sides? : N_A (Rating: 0)

34. If there are obstructions, is the bottom of the gripping surface obstructed no more than 20%? : N_A (Rating: 0)

Stairs

35. Are there floors or surfaces connected only by stairs, not an elevator or ramp? : No (Rating: 0)

36. How many flights of stairs are there? : N_A

37. If there are less than a flight, how many stairs are there? : N_A

38. Do all stair treads have a horizontal strip at the edge that is: 40mm-60mm deep, colour contrasted & extends the full width of the step? : N_A (Rating: 0)

39. If the stairs are not enclosed, is there a tactile warning system present at the landing of entrance to stairs system? : N_A (Rating: 0)

40. Are there handrails on both sides of the stairs at a uniform height of 860mm-920mm above the front step? : N_A (Rating: 0)

41. Do the handrails extend horizontally at the top and bottom of each flight of stairs? : N_A (Rating: 0)

42. Are the handrails continuous around landings? : N_A (Rating: 0)

43. Are the handrails continuously graspable, without interruption by vertical supports, newel posts, or other construction elements which require repositioning the hands while ascending or descending? : N_A (Rating: 0)

44. Do the handrails have a graspable cross-section that is either circular with an outside diameter of 30mm-40mm or elliptical with an outside perimeter of 100mm-125mm? : N_A (Rating: 0)

Trails

Date of Audit : 2016-08-08

Name of Trail : Interpretive Trail

Section of trail audited : Entire trail

Weather condition during audit : Sunny



Clear Width

5. What is the typical trail width (mm)? : More_than_1525 (Rating: 0)

Comments/Description : 1530 mm

6. What is the narrowest trail width (mm)? : between_1525_-_1220

Comments/Description : 1200

Obstacles

7. If the trail is concrete, asphalt or boardwalk, are there any obstacles that exceed 13mm from the surface? : N_A (Rating: 0)

8. If yes, are the obstacles at least 1220mm apart? : N_A (Rating: 0)

Comments/Description : there were occasional protruding rocks on trail refer to pictures for examples.

10. If yes, are the obstacles at least 1220mm apart? : N_A (Rating: 0)

Openings

11. Are there any gaps or grates present that have an opening greater than 13mm? : No (Rating: 0)

12. If gaps/grates are present, do they run perpendicular to the path of travel? : N_A (Rating: 0)

Comments/Description : 1.3 degree typical running slope

14. What is the maximum running slope on the trail? : Steep_3_-_5 (Rating: 0)

Comments/Description : 4.4 degree max running slope

Cross Slope

15. What is the typical cross slope on the trail? : Moderate_2_-_3 (Rating: 1)

Comments/Description : 2.4 degree typical cross slope

16. What is the maximum cross slope on the trail? : Very_steep_above_5 (Rating: 0)

Comments/Description : 6 degree max cross slope

Resting Intervals

17. Are there resting intervals at the top and bottom of a trail where the grade exceeds 3°? : N_A (Rating: 0)

18. If the running slope is greater than 3°, are there resting intervals in the middle of the trail when the length exceeds 9.1m? : N_A (Rating: 0)

Benches

21. Are there any benches along the trail? : No (Rating: 0)

22. If yes, are the benches located approximately every 61m? : N_A (Rating: 0)

23. Is the bench seat height between 485mm - 510mm? : N_A (Rating: 0)

Ramps

24. Is there is a ramp? : No (Rating: 0)

25. Is the ramp at least 915mm wide?

Note: If there are handrails, measure between the handrails. : N_A (Rating: 0)

26. Is the surface stable, firm and slip resistant? : N_A (Rating: 0)

27. For each section of the ramp, is the running slope no greater than 5°?

Note: Rises no greater than 76mm with a slope no steeper than 7° and rises no greater than 150mm with a slope no steeper than 6° are permitted when due to space limitations. : N_A (Rating: 0)

28. Is there a level landing that is at least 1525mm long and at least as wide as the ramp: At the top of the ramp? : N_A (Rating: 0)

29. At the bottom of the ramp? : N_A (Rating: 0)

30. Is there a level landing where the ramp changes direction that is at least 1525mm x 1525mm? : N_A (Rating: 0)

31. If the ramp has a rise higher than 150mm are there handrails on both sides? : N_A (Rating: 0)

32. Is the top of the handrail gripping surface no less than 865mm and no greater than 965mm above the ramp surface? : N_A (Rating: 0)

33. Is the handrail gripping surface continuous and not obstructed along the top or sides? : N_A (Rating: 0)

34. If there are obstructions, is the bottom of the gripping surface obstructed no more than 20%? : N_A (Rating: 0)

Stairs

35. Are there floors or surfaces connected only by stairs, not an elevator or ramp? : No (Rating: 0)

36. How many flights of stairs are there? : N_A

37. If there are less than a flight, how many stairs are there? : N_A

38. Do all stair treads have a horizontal strip at the edge that is: 40mm-60mm deep, colour contrasted & extends the full width of the step? : N_A (Rating: 0)

39. If the stairs are not enclosed, is there a tactile warning system present at the landing of entrance to stairs system? : N_A (Rating: 0)

40. Are there handrails on both sides of the stairs at a uniform height of 860mm-920mm above the front step? : N_A (Rating: 0)

41. Do the handrails extend horizontally at the top and bottom of each flight of stairs? : N_A (Rating: 0)

42. Are the handrails continuous around landings? : N_A (Rating: 0)

43. Are the handrails continuously graspable, without interruption by vertical supports, newel posts, or other construction elements which require repositioning the hands while ascending or descending? : N_A

(Rating: 0)

44. Do the handrails have a graspable cross-section that is either circular with an outside diameter of 30mm-40mm or elliptical with an outside perimeter of 100mm-125mm? : N_A (Rating: 0)

Viewing Area

1. Is there a viewing area on the trail? : No (Rating: 0)

2. Is there sufficient clear ground space, a minimum of 915mm x 1220mm for the user to view the key features? : N_A (Rating: 0)

3. Is the viewing area surface firm and stable? : N_A (Rating: 0)

4. What type of surface is the viewing area? : N_A

5. Is there a clear space between 815mm - 1320mm above the ground, free of obstructions and extending the full width of clear space? : N_A (Rating: 0)

Picnic Area

1. Are picnic tables provided? : No (Rating: 0)

2. How many accessible picnic tables are there? : N_A

3. If the picnic table is up to 2.7m long, is there one wheelchair seating space? : N_A (Rating: 0)

4. If the picnic table is longer than 2.7m, are there at least two wheelchair spaces provided? : N_A (Rating: 0)

5. Is there clear and level ground space, 915mm measured from back edge of seats/benches? : N_A (Rating: 0)

6. Do the accessible spaces have adequate knee clearance, 685mm high x 760mm wide x 430mm deep? : N_A (Rating: 0)

7. Is the ground surface surrounding the accessible picnic table firm and stable? : N_A (Rating: 0)

8. Is there a clear, level accessible route to the picnic table? : N_A (Rating: 0)

Shelters

1. Are there any camp shelters? : No (Rating: 0)

2. What is the slope at the entrance to the camp shelter? : N_A (Rating: 0)

3. What type of surface is in the camp shelter? : N_A

4. Is the shelter surface firm and stable? : N_A (Rating: 0)

5. Is there a clear, level accessible route to the camp shelter? : N_A (Rating: 0)

Benches

1. Are any benches provided? : No (Rating: 0)

2. If yes, how many benches are there? : N_A

3. Is the bench seat height between 485mm - 510mm? : N_A (Rating: 0)

4. Is there a minimum of 915mm x 1220mm clear ground space beside the bench? : N_A (Rating: 0)

5. Is there a clear, level accessible route to the bench? : N_A (Rating: 0)

Comments/Description : bear-proof trash bin is in the picnic/ play area before the first interpretive sign starts on nature trail.

2. Is the approach to the receptacle level, with no-step? : No (Rating: 0)

Comments/Description : 75 mm lip to cement pad

Measurement

(mm) : 1020

4. If there are operable parts, can they be operated using one hand, without tightly grasping, pinching, or twisting the wrist and with no more than 2.3kg of force? : No (Rating: 0)

Comments/Description : 4 kg force required

5. Is there a clear, level accessible route to the trash/recycling receptacle? : No (Rating: 0)

Campfires & Grills

1. Is there an area for campfires? : No (Rating: 0)

2. Is there a minimum of 1220mm clear ground space on all sides? : N_A (Rating: 0)

3. Is the slope 3° or less in all directions? : N_A (Rating: 0)

4. Is the grill height between 380mm - 865mm above the ground? : N_A (Rating: 0)

5. Is the fire building surface height at least 230mm above the ground? : N_A (Rating: 0)

6. If there is a raised edge or wall around the fire building area, is the thickness less than 255mm? : N_A (Rating: 0)

7. Is there a clear, level accessible route to the campfire area? : N_A (Rating: 0)

1. Are any public washrooms located at the trail head or on the trail? : Yes -
_WASHROOMS_checklist_must_also_be_completed

Additional comments regarding assessment: : Overall, this a fairly accessible and very enjoyable trail with gentle grades. There are occasional undulations in the running and cross slopes.

Suggestions for improvement of audit tool: : instead of having 2 categories for benches have just one category for benches to prevent confusion in the checklists.




Description of Photo 1 : The interpretive information sign are sitting at a good height for someone in a wheelchair to be able to read without much issues.



Description of Photo 2 : Really nice interpretive information about Mt Robson that they have setup through out the trail.



Description of Photo 3 : The pathway is in pretty good shape to take a wheelchair or a walker down.



Description of Photo 4 : these are the type of rocks you'll see through out the trail, they're spaced out pretty good along the trail.

Washrooms

Date of Audit : 2016-08-08

Auditors Names : Ryan and Bob

Weather condition during audit : Sunny

Washroom # : 1

Description of washroom location : Just off the Interpretive Nature Trail

Type of Washroom : Out-house



1. If washrooms are available to the public, is at least one washroom designated as accessible? (Either one for each sex, or one unisex.) : Yes (Rating: 1)

Comments/Description : there is a raised cement pad that is 30mm above the ground.

Recommendations : REMOVE 'LIP' BY FILLING AND COMPACTING SPACE WITH GRAVEL

Improvement Priority : High

Estimated Cost : Low

Directional signage

2. Are there signs at inaccessible washrooms that give directions to accessible washrooms? : Yes (Rating: 1)

3. Is there an accessible route to the accessible washroom? : Yes (Rating: 1)

4. If not all washrooms are accessible, is there a sign at the accessible washroom with the International Symbol of Accessibility? : Yes (Rating: 1)

5. Do text characters contrast with their backgrounds? : Yes (Rating: 1)

Comments/Description : White on Blue background

6. Are text characters raised? : Yes (Rating: 1)

Improvement Priority : N_A

Estimated Cost : N_A

7. Is there Braille? : No (Rating: 0)

8. Is the sign mounted on the wall, on latch side of the door?

Note: Signs are permitted on the push side of doors with closers and without hold-open devices. : No (Rating: 0)

Comments/Description : Sign is on the side of the out house

Recommendations : PLACE SIGN ON WALL BY LATCH SIDE OF DOOR

Improvement Priority : High

Estimated Cost : Low

9. So the baseline of the lowest character is at least 1220mm above the floor and the baseline of the highest character is no more than 1525mm above the floor?

Note: If the sign is at double doors with one active leaf, the sign should be on the inactive leaf; if both leaves are active, the sign should be on the wall to the right of the right leaf. : Yes (Rating: 1)

**Measurement
(mm) : 955**

Interior doors

10. Is the door opening width at least 815mm clear, between the face of the door and the stop, when the door is open 90°? : Yes (Rating: 1)

**Measurement
(mm) : 825**

11. If there is a front approach to the pull side of the door, is there at least 455mm of maneuvering clearance beyond the latch side plus at least 1525mm clear depth? : No (Rating: 0)

**Measurement
(mm) w x d : 210 x 1065**

12. On both sides of the door, is the floor surface of the maneuvering clearance level (no steeper than 1°)? : Yes (Rating: 1)

**Measurement
(angle °) : 1**

13. If the threshold is vertical is it no more than 6mm high?

Or : N_A (Rating: 0)

Comments/Description : no threshold

14. If the threshold is beveled, is it no more than 19mm high? : N_A (Rating: 0)

15. Is the door equipped with hardware that is operable with one hand and does not require tight grasping, pinching or twisting of the wrist? : Yes (Rating: 1)

Comments/Description : Large D Handle.

16. Are the operable parts of the hardware no less than 865mm and no greater than 1220mm above the floor? : Yes (Rating: 1)

**Measurement
(mm) : 960**

17. Can the door be opened easily, maximum 2.3kg of force?

Note: You can use a pressure gauge or fish scale to measure force. : No (Rating: 0)

Measurement**(kg) : 4****Comments/Description : 4 kg force DOOR TO WASHROOM USUALLY REMAINS OPEN****Recommendations : ADJUST OR REPLACE HINGES****Improvement Priority : Med****Estimated Cost : Low****18. If the door has a closer, does it take at least 5 seconds to close from open position of 90° to a position of 12° from the latch? : Yes (Rating: 1)****Measurement****(seconds) : 4****19. If there are two doors in a series, e.g. vestibule, is the distance between the doors at least 1220mm plus the width of the doors when swinging into the space? : N_A (Rating: 0)****20. If there is a privacy wall and the door swings out, is there at least 610mm of maneuvering clearance beyond the door latch side and 1065mm to the privacy wall? : N_A (Rating: 0)****21. If there is a privacy wall and the door swings in, is there at least 610mm of maneuvering clearance beyond the door latch side and at least 1220mm to the privacy wall if there is no door closer or at least 1370mm if there is a door closer? : N_A (Rating: 0)****22. In a unisex washroom if the door swings in and over a clear floor space at an accessible fixture, is there a clear floor space at least 760mm x 1220mm beyond the swing of the door? : N_A (Rating: 0)****Toilet stall****23. Is there an individual accessible toilet stall? : Yes (Rating: 1)****24. Is the stall door opening width at least 815mm clear, between the face of the door and the stop, when the door is open 90°? : Yes (Rating: 1)****Measurement****(mm) : 845****25. If there is a front approach to the pull side of the stall door, is there at least 455mm of maneuvering clearance beyond the latch side plus 1525mm clear depth? : No (Rating: 0)****Clearance****(mm) : 510****Depth****(mm) : 1040****Comments/Description : 480 mm W x 1235 D****26. Is the door self-closing? : Yes (Rating: 1)****Comments/Description : 9 secs for stall door to close 0.5kg force to open the stall door**

27. Are there door pulls on both sides of the door that are operable with one hand and do not require tight grasping pinching or twisting of the wrist?* : Yes (Rating: 1)

Comments/Description : small D handle

Recommendations : REPLACE WITH LARGER D HANDLE

Improvement Priority : High

Estimated Cost : Low

28. Is the lock operable with one hand and without tight grasping, pinching or twisting of the wrist? : Yes (Rating: 1)

29. Are the operable parts of the door hardware mounted no less than 865mm and no greater than 1220mm above the floor? : Yes (Rating: 1)

Measurement (mm) : 855

Comments/Description : D handle height was 855mm from ground latch height was 1245mm from the ground

30. Is the stall at least 1525mm wide? : Yes (Rating: 1)

Measurement (mm) : 1720

Comments/Description : close to code - OK

31. If the toilet is wall hung, is the stall at least 1420mm deep?

Or : N_A (Rating: 0)

32. If the toilet is floor mounted, is the stall at least 1500mm deep? : Yes (Rating: 1)

Measurement (mm) : 1630

Comments/Description : close to code - OK

If the door swings in, is the stall area beyond the swing of the door:

33. A minimum of 1525mm wide x 1420mm deep for wall hung toilet?

Or : N_A (Rating: 0)

34. A minimum of 1525mm wide x 1500mm deep for floor mounted toilet? : N_A (Rating: 0)

Toilet

35. Is the centerline of the toilet no less than 405mm and no greater than 455mm from the side wall or partition? : Yes (Rating: 1)

**Measurement
(mm) : 480**

36. Is clearance provided around the toilet measuring at least 1525mm from the side wall and at least 1420mm from the rear wall? : Yes (Rating: 1)

**From side wall
(mm) : 1720**

**From rear wall
(mm) : 1630**

37. Is the height of the toilet no less than 430mm and no greater than 485mm above the floor measured to the top of the seat? : Yes (Rating: 1)

**Measurement
(mm) : 465**

Grab bars

38. Is there a grab bar at least 1065mm long on the side wall? : No (Rating: 0)

**Measurement
(mm) : 600**

Comments/Description : elbowed grab bar from bottom to upward slope. 600mm x 610mm upward slope

Recommendations : REPLACE WITH LONG STRAIGHT GRAB BAR

Improvement Priority : High

Estimated Cost : Low

39. Is it located no more than 305mm from the rear wall? : Yes (Rating: 1)

**Measurement
(mm) : 190**

40. Does it extend at least 1370mm from the rear wall? : No (Rating: 0)

**Measurement
(mm) : 790**

41. Is it mounted no less than 840mm and no greater than 915mm above the floor to the top of the gripping surface? : Yes (Rating: 1)

**Measurement
(mm) : 765**

42. Is there at least 305mm clearance between the grab bar and protruding objects above? : N_A (Rating: 0)

43. Is there at least 38mm clearance between the grab bar and projecting objects below? : Yes (Rating: 1)

**Measurement
(mm) : 75**

44. Is the space between the wall and the grab bar 38mm : Yes (Rating: 1)

**Measurement
(mm) : 40**

45. Is there a grab bar at least 915mm long on the rear wall? : No (Rating: 0)

**Measurement
(mm) : 460**

Comments/Description : 2 rear grab bars both 300mm (see picture)

Recommendations : REPLACE WITH LONG STRAIGHT GRAB BAR

Improvement Priority : High

Estimated Cost : Low

46. Does the grab bar extend at least 305mm from the centerline of the toilet on one side (side wall)? : No (Rating: 0)

**Measurement
(mm) : 200**

47. Does the grab bar extend at least 610mm on the other (open) side? : No (Rating: 0)

**Measurement
(mm) : 260**

48. Is the grab bar mounted no less than 840mm and no greater than 915mm above the floor to the top of the gripping surface? : Yes (Rating: 1)

**Measurement
(mm) : 765**

49. Are there at least 305mm clearance between the grab bar and protruding objects above? : No (Rating: 0)

50. Are there at least 38mm clearance between the grab bar and projecting objects below? : Yes (Rating: 1)

**Measurement
(mm) : 100**

Comments/Description : toilet pipe to grab bar

51. Is the space between the wall and the grab bar 38mm inches? : Yes (Rating: 1)

**Measurement
(mm) : 40**

Toilet flush controls

52. If the flush control is hand operated, is the operable part located no higher than 1220mm above the floor? : N_A (Rating: 0)

Comments/Description : motion sensor activated system with no flusher handle

53. If the flush control is hand operated, can it be operated with one hand and without tight grasping, pinching, or twisting of the wrist? : N_A (Rating: 0)

54. Is the force required to activate the flush control no greater than 2.3kg? : N_A (Rating: 0)

55. Is the flush control on the open side of the toilet? : N_A (Rating: 0)

Toilet paper dispenser

56. Is the toilet paper dispenser located no less than 180mm and no greater than 230mm from the front of the toilet to the center line of the dispenser? : Yes (Rating: 1)

**Measurement
(mm) : 230**

Comments/Description : dispenser is too far back to get the center line of the dispenser from front of the toilet.

Recommendations : RE-POSITION DISPENSER (IN CONJUNCTION WITH REPLACING SIDE GRAB BAR)

Improvement Priority : High

Estimated Cost : Low

57. Is the outlet of the dispenser: Located no less than 380mm and no greater than 1220mm above the floor? : Yes (Rating: 1)

**Measurement
(mm) : 860**

58. Is the dispenser located behind grab bars? : No (Rating: 0)

59. Does the dispenser allow continuous paper flow? : Yes (Rating: 1)

Sink

60. Does at least one sink have a clear floor space for a forward approach at least 760mm wide and 1220mm long? : Yes (Rating: 1)

**Measurement
(mm x mm) : 1830 x 950**

Comments/Description : 1830L x 950W

61. Do no less than 430mm and no greater than 635mm of the clear floor space extend under the sink so that a person using a wheelchair can get close enough to reach the faucet? : Yes (Rating: 1)

Measurement

(mm) : 580

62. Is the front of the sink or counter surface, whichever is higher, no more than 865mm above the floor? :
No (Rating: 0)

Measurement

(mm) : 890

Comments/Description : SLIGHTLY TOO HIGH

63. Is there at least 685mm height clearance from the floor to the bottom of the sink that extends at least 205mm deep under the sink for knee clearance? : No (Rating: 0)

Height

(mm) : 760

Depth

(mm) : 115

64. Is there toe clearance at least 230mm high?

Note: Space extending greater than 150mm beyond the available toe clearance at 230mm above the floor is not considered toe clearance. : No (Rating: 0)

Comments/Description : 370H X 235D

65. Are pipes below the sink insulated or otherwise configured to protect against contact? : Yes (Rating: 1)

Comments/Description : wood insulated box

66. Can the faucet be operated without tight grasping, pinching, or twisting of the wrist? : Yes (Rating: 1)

Comments/Description : motion sensor activated

67. Is the force required to activate the faucet no greater than 2.3 kg? : No (Rating: 0)

Comments/Description : motion sensor activated

Washroom fixtures

68. Is there a clear path to at least one of each type of fixture, e.g. sink, hand dryer, garbage bin etc., that is at least 915mm wide? : Yes (Rating: 1)

Measurement

(mm) : 1230

Comments/Description : 1230 mm from sink to stall

69. Is there clear floor space available for a person in a wheelchair to turn around, i.e. a circle at least 1525mm in diameter or a T-shaped space within a 1525mm square? : Yes (Rating: 1)

Measurement

(mm) : 1610

Mirror

70. If the mirror is over a sink or countertop, is the bottom edge of the reflecting surface no higher than 1015mm above the floor?

Or : No (Rating: 0)

Measurement

(mm) : 1050

Comments/Description : 1050 mm (SLIGHTLY TOO HIGH)

71. If the mirror is not over the sink or countertop, is the bottom edge of the reflecting surface no higher than 890mm above the floor? : N_A (Rating: 0)

Coat hook

72. If there is a coat hook, is it no less than 380mm and no greater than 1220mm above the floor?* : No (Rating: 0)

Measurement

(mm) : 1620

Soap dispenser

Are the operable parts of the soap dispenser within one of the following reach ranges:

73. Above sinks or counters no less than 510mm and no greater than 635mm deep: no higher than 1120mm above the floor?

Or : No (Rating: 0)

Measurement

(mm) : 605

Comments/Description : 605 D x 1150 H (SLIGHTLY TOO HIGH)

74. Above sinks less than 510mm deep: no higher than 1220mm above the floor?

Or : N_A (Rating: 0)

75. Not over an obstruction: no higher than 1220mm above the floor? : N_A (Rating: 0)

Hand dryer/Towel dispenser

Are the operable parts of the hand dryer or towel dispenser within one of the following reach ranges:

76. Above sinks or counters no less than 510mm and no greater than 635mm deep: no higher than 1120mm above the floor?

Or : N_A (Rating: 0)

77. Above sinks less than 510mm deep: no higher than 1220mm above the floor?

Or : N_A (Rating: 0)

78. Not over an obstruction: no higher than 1220mm above the floor? : No (Rating: 0)

**Measurement
(mm) : 1240**

Comments/Description : 1240 mm SLIGHTLY TOO HIGH

79. Can the operable parts of the hand dryer or towel dispenser be operated without tight grasping, pinching or twisting of the wrist? : Yes (Rating: 1)

Comments/Description : motion sensor activated

80. Is the force required to activate the hand dryer or towel dispenser no greater than 2.3kg? : Yes (Rating: 1)

Comments/Description : motion sensor activated

Controls - light switches

81. Is there a clear floor space at least 760mm wide by at least 1220mm long for a forward or parallel approach? : Yes (Rating: 1)

82. Are the operable parts no higher than 1220mm above the floor? : No (Rating: 0)

**Measurement
(mm) : 1310**

83. Can the control be operated with one hand and without tight grasping, pinching, or twisting of the wrist? : Yes (Rating: 1)

1. Has the route to the washroom been evaluated? : Yes

Additional comments regarding assessment: : OVERALL, THIS A VERY ACCESSIBLE WASHROOM. REPLACING GRAB BARS IS MAIN PRIORITY.

Suggestions for improvement of audit tool: : For the force of the door, have one for the interior doors and for toilet stall doors. Have for how many seconds it takes to close the door in both the interior and toilet stall categories. For sinks have it auto fill for N/A if there is no sinks in the bathroom or pit toilet.



Description of Photo 1 : outhouse



Description of Photo 2 : Cement pad outside outhouse door



Description of Photo 3 : sensor operated sink faucet



Description of Photo 4 : accessible sign directing you to the accessible washroom.

Camping

Date of Audit (YYYY-MM-DD) : 2016-08-08

Name of Campground : Picnic Table near accessible parking stalls

Location of Campsite : Picnic Table near accessible parking stalls

Weather condition during audit : Sunny



1. Does the number of accessible camp sites comply with the table above? : N_A (Rating: 0)

Campsite

2. Is the camp site surface firm and stable? : N_A (Rating: 0)

Comments/Description : NA

4. Is the accessible campsite at least 4.9m wide?

Or : N_A (Rating: 0)

5. If it is an RV site, is the parking area at least 6m wide? : N_A (Rating: 0)

6. If the campsite surface is concrete or asphalt, is the slope 1° or less? : N_A (Rating: 0)

7. If the campsite surface is anything other than concrete & asphalt, is the slope 3° or less? : N_A (Rating: 0)

Tent Pads/Platforms

8. Is there a minimum of 1220mm clear space on all sides surrounding the tent pad or platform? : N_A (Rating: 0)

Comments/Description : NA

10. What is the slope of the tent pad/ platform? : N_A (Rating: 0)

11. Is there an accessible entrance or ramp on to the tent pad/platform? : N_A (Rating: 0)

Utility & Sewage Hook Ups

12. Is there sufficient clear ground space, a minimum of 1220mm x 1525mm surrounding the hook ups? : N_A (Rating: 0)

13. If there are operable parts, can they be operated using one hand, without tightly grasping, pinching, or twisting the wrist and with no more than 2.3kg of force? : N_A (Rating: 0)

Campfires & Grills

14. Is there an area for campfires? : No (Rating: 0)

15. Is there a minimum of 1220mm clear ground space on all sides? : N_A (Rating: 0)

16. Is the slope 3° or less in all directions? : N_A (Rating: 0)

17. Is the grill height between 380mm - 865mm above the ground? : N_A (Rating: 0)

18. Is the fire building surface height at least 230mm above the ground? : N_A (Rating: 0)

19. If there is a raised edge or wall around the fire building area, is the thickness less than 255mm? : N_A (Rating: 0)

20. Is there a clear, level accessible route to the campfire area? : N_A (Rating: 0)

21. Are picnic tables provided? : Yes (Rating: 1)

22. How many accessible picnic tables are there? : 1

Comments/Description : Very accessible and well situated - close to parking lot and on access route to visitor

centre

23. If the picnic table is up to 2.7m long, is there one wheelchair seating space? : Yes (Rating: 1)

Comments/Description : 2.28 metres long

24. If the picnic table is longer than 2.7m, are there at least two wheelchair spaces provided? : N_A (Rating: 0)

25. Is there clear and level ground space, 915mm measured from back edge of seats/benches? : Yes - _Meets_Standard (Rating: 1)

Measurement (mm) : 975

26. Do the accessible spaces have adequate knee clearance, 685mm high x 760mm wide x 430mm deep? : Yes (Rating: 1)

Measurement (mm) h x w x d : 680 x 865 x 595

Comments/Description : 680 H x 865 W x 595 D

27. Is the ground surface surrounding the accessible picnic table firm and stable? : Yes (Rating: 1)

Comments/Description : level asphalt

28. Is there a clear, level accessible route to the picnic table? : Yes (Rating: 1)

Comments/Description : See Access Route from Parking Lot to Visitor Centre checklist

Water Taps

1. Are there any water taps? : No (Rating: 0)

2. Is there sufficient clear ground space, a minimum of 1829mm x 1220mm surrounding the water tap? : N_A (Rating: 0)

3. Is the water spout height between 280mm - 305mm? : N_A (Rating: 0)

4. Is the height of operable parts (i.e. taps or levers) between 380mm - 1220mm above the ground? : N_A (Rating: 0)

5. If there are operable parts, can they be operated using one hand, without tightly grasping, pinching, or twisting the wrist and with no more than 2.3kg of force? : N_A (Rating: 0)

6. Is there a clear, level accessible route to the water tap? : N_A (Rating: 0)

Water Fountains

1. Is there a water fountain? : No (Rating: 0)

2. Does it have a lever or push bar control on the front or both sides? : N_A (Rating: 0)

3. Is the spout opening height between 750mm - 915mm above the ground? : N_A (Rating: 0)

4. Is there a minimum width of 800mm clearance space directly in front of the water fountain? : N_A (Rating: 0)

5. Is there a clear, level accessible route to the water fountain? : N_A (Rating: 0)

Trash & Recycling Receptacles

1. Are there any trash &/or recycling receptacles? : No (Rating: 0)

2. Is the approach to the receptacle level, with no-step? : N_A (Rating: 0)

3. If there are operable parts, is their height between 380mm - 1220mm above the ground? : N_A (Rating: 0)

4. If there are operable parts, can they be operated using one hand, without tightly grasping, pinching, or twisting the wrist and with no more than 2.3kg of force? : N_A (Rating: 0)

5. Is there a clear, level accessible route to the trash/recycling receptacle? : N_A (Rating: 0)

Shelters

1. Are there any camp shelters? : No (Rating: 0)

2. What is the slope at the entrance to the camp shelter? : N_A (Rating: 0)

3. What type of surface is in the camp shelter? : N_A

4. Is the shelter surface firm and stable? : N_A (Rating: 0)

5. Is there a clear, level accessible route to the camp shelter? : N_A (Rating: 0)

Benches

1. Are any benches provided? : No (Rating: 0)

2. If yes, how many benches are there? : N_A

3. Is the bench seat height between 485mm - 510mm? : N_A (Rating: 0)

4. Is there a minimum of 915mm x 1220mm clear ground space beside the bench? : N_A (Rating: 0)

5. Is there a clear, level accessible route to the bench? : N_A (Rating: 0)

Playground

1. Is there a playground? : No (Rating: 0)

2 What type of surface is in the play area? : N_A

3. Is the play area surface firm and stable? : N_A (Rating: 0)

4. Are any of the playground components accessible to wheelchair users? If yes, please describe. : N_A

(Rating: 0)

5. Is there a clear, level accessible route to the playground? : N_A (Rating: 0)

Amphitheatre

1. Is there an amphitheatre? : No (Rating: 0)

Amphitheatre Seating

2. Are an adequate number of wheelchair spaces provided? : N_A (Rating: 0)

3. Are wheelchair spaces dispersed to allow location choices and viewing angles equivalent to other seating, including specialty seating areas that provide distinct services and amenities? : N_A (Rating: 0)

4. Where people are expected to remain seated, do people in wheelchair spaces have a clear line of sight over and between the heads of others in front of them? : N_A (Rating: 0)

5. Where people are expected to stand, do people in wheelchair spaces have a clear line of sight over and between the heads of others in front of them? : N_A (Rating: 0)

6. If there is a single wheelchair space, is it at least 915mm wide? : N_A (Rating: 0)

7. If there are two adjacent wheelchair spaces, are they each at least 840mm wide? : N_A (Rating: 0)

8. If the wheelchair space can be entered from the front or rear, is it at least 1220mm deep? : N_A (Rating: 0)

9. If the wheelchair space can only be entered from the side, is it at least 1525mm deep? : N_A (Rating: 0)

10. Do wheelchair spaces adjoin, but not overlap, accessible routes? : N_A (Rating: 0)

11. Is there at least one companion seat for each wheelchair space? : N_A (Rating: 0)

12. Is the companion seat located so the companion is shoulder-to-shoulder with the person in a wheelchair? : N_A (Rating: 0)

13. Is the companion seat equivalent in size, quality, comfort and amenities to seating in the immediate area? : N_A (Rating: 0)

2. Are there any public buildings (visitors centre/ interpretive centre/cafes etc) at the campground? : No (Rating: 0)

3. Are there any trails at the campground? : No (Rating: 0)

4. Is there a beach, dock/fishing platform or boat launch? : No (Rating: 0)

Water Access

Goods and Services

Date of Audit : 2016-08-08

Weather condition during audit : Sunny

Description of building & service : Mt. Robson Visitor Centre



Parking

1. Is parking provided for the public? : Yes (Rating: 1)

2. Are an adequate number of accessible spaces provided? : Yes_ - _Meets_Standard (Rating: 1)

Total # : 100

Accessible # : 4

Comments/Description : Approximately 100 parking stalls including RV parking stalls according to park operator. Accessibility symbols on asphalt are very faded.

Recommendations : Repaint stalls, install sign posts indicating accessible stalls

Improvement Priority : High

Estimated Cost : Low

3. Of the accessible spaces, is at least one a van accessible space?* : Yes_ - _Meets_Standard (Rating: 1)

4. Are accessible spaces at least 2.4m wide with an access aisle at least 1.5m wide? Note: Two spaces may share an access aisle. : Yes_ - _Meets_Standard (Rating: 1)

Measurement

(m) Space : 3.65

Comments/Description : 3.65m van stall and there are no access aisles 3.05m for non van accessible stalls and no access aisles

5. Are the access aisles marked to discourage parking in them? : N_A (Rating: 0)

6. Is the slope of the accessible parking spaces and access aisles no steeper than 1° in all directions? : Yes_ - _Meets_Standard (Rating: 1)

Comments/Description : Average in all directions is 1 degree slope for all 4 accessible stalls

7. Does the access aisle adjoin an accessible route? : N_A (Rating: 0)

Comments/Description : no access aisles

Recommendations : CREATE ACCESS AISLES OR AT LEAST PAINT THE "NO PARKING AREA WHICH IS PART OF THE ACCESS ROUTE

Improvement Priority : Med

Estimated Cost : Low

8. Are accessible spaces identified with a sign that includes the International Symbol of Accessibility?

Note: The International Symbol of Accessibility is not required on the ground. : No (Rating: 0)

9. Of the total parking spaces, are the accessible spaces located on the closest accessible route to the accessible entrance(s)? Note: If parking serves multiple entrances, accessible parking should be dispersed.

: Yes (Rating: 1)

From : Parking lot/Accessible Picnic table/Kiosk

To : Visitor Centre Building

General

1. Is there at least one route from site arrival points (parking, loading zone, bus stop etc) that does not require the use of stairs? : Yes (Rating: 1)

Comments/Description : 62.6 meters for distance traveled to visitor center access route 1 (steepest and most direct route). See "Access Route from parking lot to visitor centre" checklist for information on the longer, accessible route

2. What is the condition of the surface along this route? : Good

Surface

3. Is the surface firm and stable? : Yes (Rating: 1)

4. What is the type of surface? : Asphalt

Clear Width

5. What is the typical route width (mm)? : More_than_1525 (Rating: 0)

Comments/Description : 4000mm typical route width

6. What is the narrowest route width (mm)? : More_than_1525 (Rating: 0)

Comments/Description : 1820mm narrowest route width

Obstacles

7. If the route is concrete, asphalt or boardwalk, are there any obstacles that exceed 13mm from the surface? : Yes (Rating: 1)

8. If yes, are the obstacles at least 1220mm apart? : Yes (Rating: 1)

9. If the route is anything other than concrete, asphalt or boardwalk, are there any obstacles that exceed

25mm from the surface? : N_A (Rating: 0)

10. If yes, are the obstacles at least 1220mm apart? : N_A (Rating: 0)

Openings

11. Are there any gaps or grates present that have an opening greater than 13mm? : No (Rating: 0)

12. If gaps/grates are present, do they run perpendicular to the path of travel? : N_A (Rating: 0)

Running Slope

13. What is the typical running slope on the route? : Moderate_2_-_3 (Rating: 1)

Comments/Description : 3.4 degree running slope

14. What is the maximum running slope on the route? : Very_steep_above_5 (Rating: 0)

Comments/Description : 6.6 degree max running slope

Cross Slope

15. What is the typical cross slope on the route? : Flat_Gentle_1_or_less

Comments/Description : 0.7 degree typical cross slope

16. What is the maximum cross slope on the route? : Flat_Gentle_1_or_less

Comments/Description : 1.2 max cross slope

Resting Intervals

17. Are there resting intervals at the top and bottom of a route where the grade exceeds 3°? : N_A (Rating: 0)

18. If the running slope is greater than 3°, are there resting intervals in the middle of the route when the length exceeds 9.1m? : N_A (Rating: 0)

Protruding Objects

19. Is there a minimum of 2030mm vertical clearance for users to safely pass along the route without coming into contact with overhanging obstacles? : Yes_-_exceeds_standard

20. Is there a minimum of 100mm horizontal clearance for users to safely pass along the route without coming into contact with side obstacles? : Yes_-_exceeds_standard

Benches

21. Are there any benches along the route? : No (Rating: 0)

22. If yes, are the benches located approximately every 61m? : N_A (Rating: 0)

23. Is the bench seat height between 485mm - 510mm? : N_A (Rating: 0)

Ramps

24. Is there is a ramp? : No (Rating: 0)

25. Is the ramp at least 915mm wide?

Note: If there are handrails, measure between the handrails. : N_A (Rating: 0)

26. Is the surface stable, firm and slip resistant? : N_A (Rating: 0)

27. For each section of the ramp, is the running slope no greater than 5°?

Note: Rises no greater than 76mm with a slope no steeper than 7° and rises no greater than 150mm with a slope no steeper than 6° are permitted when due to space limitations. : N_A (Rating: 0)

28. Is there a level landing that is at least 1525mm long and at least as wide as the ramp: At the top of the ramp? : N_A (Rating: 0)

29. At the bottom of the ramp? : N_A (Rating: 0)

30. Is there a level landing where the ramp changes direction that is at least 1525mm x 1525mm? : N_A (Rating: 0)

31. If the ramp has a rise higher than 150mm are there handrails on both sides? : N_A (Rating: 0)

32. Is the top of the handrail gripping surface no less than 865mm and no greater than 965mm above the ramp surface? : N_A (Rating: 0)

33. Is the handrail gripping surface continuous and not obstructed along the top or sides? : N_A (Rating: 0)

34. If there are obstructions, is the bottom of the gripping surface obstructed no more than 20%? : N_A (Rating: 0)

Stairs

35. Are there floors or surfaces connected only by stairs, not an elevator or ramp? : Yes (Rating: 1)

Comments/Description : 170H x 400W x 1990L stair measurements EXTERIOR WOODEN STAIRS CONNECTING DECK TO BASEMENT/LOADING BAY. This is an alternate access route. The main route does not have stairs)

36. How many flights of stairs are there? : 1

37. If there are less than a flight, how many stairs are there? : N_A

38. Do all stair treads have a horizontal strip at the edge that is: 40mm-60mm deep, colour contrasted & extends the full width of the step? : No - Below Standard (Rating: 0)

Comments/Description : no stair treads

Recommendations : INSTALL TREADS

Improvement Priority : High

Estimated Cost : Low

39. If the stairs are not enclosed, is there a tactile warning system present at the landing of entrance to stairs system? : No (Rating: 0)

40. Are there handrails on both sides of the stairs at a uniform height of 860mm-920mm above the front step? : Yes - Meets Standard (Rating: 1)

**Measurement
(mm) : 925**

41. Do the handrails extend horizontally at the top and bottom of each flight of stairs? : No (Rating: 0)

Comments/Description : only at top on one side 500mm extends out before curving down height of bottom of hand rail 527mm

42. Are the handrails continuous around landings? : N_A (Rating: 0)

43. Are the handrails continuously graspable, without interruption by vertical supports, newel posts, or other construction elements which require repositioning the hands while ascending or descending? : Yes (Rating: 1)

44. Do the handrails have a graspable cross-section that is either circular with an outside diameter of 30mm-40mm or elliptical with an outside perimeter of 100mm-125mm? : Yes - Meets Standard (Rating: 1)

**Measurement
(mm) : 42**

1. Does the accessible entrance provide direct access to the main floor, lobby and elevator? : Yes (Rating: 1)

Interior Accessible Route

2. Are all public spaces on at least one accessible route? : Yes (Rating: 1)

3. Is the route stable, firm and slip-resistant? : Yes (Rating: 1)

4. Is the route at least 915mm wide?

Note: The accessible route can narrow to 815mm min. for a max. of 610mm. These narrower portions of the route must be at least 1220mm from each other. : No - Below Standard (Rating: 0)

Comments/Description : NA

5. If the route is greater than 61m in length and less than 1525mm wide, is there a passing space no less than 1525mm x 1525mm? : N_A (Rating: 0)

6. Is the running slope no steeper than 3°

Note: If the running slope is steeper than 3°, treat as a ramp, see ramps section on the next page. : N_A (Rating: 0)

7. Is the cross slope no steeper than 1°? : N_A (Rating: 0)

Ramps

8. Is there is a ramp? : No (Rating: 0)

9. Is the ramp at least 915mm wide?

Note: If there are handrails, measure between the handrails. : N_A (Rating: 0)

10. Is the surface stable, firm and slip resistant? : N_A (Rating: 0)

11. For each section of the ramp, is the running slope no greater than 5°?

Note: Rises no greater than 76mm with a slope no steeper than 7° and rises no greater than 150mm with a slope no steeper than 6° are permitted when due to space limitations. : N_A (Rating: 0)

12. Is there a level landing that is at least 1525mm long and at least as wide as the ramp:

At the top of the ramp? : N_A (Rating: 0)

13. At the bottom of the ramp? : N_A (Rating: 0)

14. Is there a level landing where the ramp changes direction that is at least 1525mm x 1525mm? : N_A (Rating: 0)

15. If the ramp has a rise higher than 150mm are there handrails on both sides? : N_A (Rating: 0)

16. Is the top of the handrail gripping surface no less than 865mm and no greater than 965mm above the ramp surface? : N_A (Rating: 0)

17. Is the handrail gripping surface continuous and not obstructed along the top or sides? : N_A (Rating: 0)

18. If there are obstructions, is the bottom of the gripping surface obstructed no more than 20%? : N_A (Rating: 0)

Stairs

19. Are there floors or surfaces connected only by stairs, not an elevator or ramp? : Yes (Rating: 1)

Comments/Description : INTERIOR STAIRS CONNECTING MAIN FLOOR TO BASEMENT 185H X 265W X 1050L stair measurement

20. How many flights of stairs are there? : 2

Comments/Description : there are 2 flights of stairs with one landing

21. If there are less than a flight, how many stairs are there? : N_A

22. Do all stair treads have a horizontal strip at the edge that is: 40mm-60mm deep, colour contrasted & extends the full width of the step? : Yes - Meets Standard (Rating: 1)

Measurement
(mm) : 50

Comments/Description : reddish grey blue carpet with grey stair strip treads

23. If the stairs are not enclosed, is there a tactile warning system present at the landing of entrance to stairs system? : N_A (Rating: 0)

24. Are there handrails on both sides of the stairs at a uniform height of 860mm-920mm above the front step? : No_-_Below_Standard (Rating: 0)

Comments/Description : No there is only 1 set of handrails going down the stairs.

25. Do the handrails extend horizontally at the top and bottom of each flight of stairs? : No (Rating: 0)

26. Are the handrails continuous around landings? : Yes (Rating: 1)

Comments/Description : on the one side

Recommendations : INSTALL HANDRAILS TO CODE ON BOTH SIDES OF STAIRS

Improvement Priority : High

Estimated Cost : Med

27. Are the handrails continuously graspable, without interruption by vertical supports, newel posts, or other construction elements which require repositioning the hands while ascending or descending? : Yes (Rating: 1)

28. Do the handrails have a graspable cross-section that is either circular with an outside diameter of 30mm-40mm or elliptical with an outside perimeter of 100mm-125mm? : No_-_Below_Standard (Rating: 0)

Comments/Description : 80mmW x 30mm thick first flight 2nd flight hand rail 65W x 40mm thick

Platform lifts

29. Is there a lift? : No (Rating: 0)

30. If a lift is provided, can it be used without assistance from others? : N_A (Rating: 0)

31. Is there a clear floor space at least 760mm wide by at least 1220mm long for a person using a wheelchair to approach and reach the controls to use the lift? : N_A (Rating: 0)

32. Are the lift controls no less than 380mm and no greater than 1220mm above the floor? : N_A (Rating: 0)

33. Is there a clear floor space at least 760mm wide by at least 1220mm long inside the lift? : N_A (Rating: 0)

34. If there is an end door, is the clear opening width at least 815mm? : N_A (Rating: 0)

35. If there is a side door, is the clear opening width at least 1065mm? : N_A (Rating: 0)

Directional signage

If there are signs designating permanent rooms and spaces not likely to change over time, e.g. room numbers and letters, room names, and exit signs:

36. Do text characters contrast with their backgrounds? : N_A (Rating: 0)

37. Are text characters raised? : N_A (Rating: 0)

38. Is there Braille? : N_A (Rating: 0)

39. Is the sign mounted on the wall, on latch side of the door?

Note: Signs are permitted on the push side of doors with closers and without hold-open devices. : N_A (Rating: 0)

40. So the baseline of the lowest character is at least 1220mm above the floor and the baseline of the highest character is no more than 1525mm above the floor?

Note: If the sign is at double doors with one active leaf, the sign should be on the inactive leaf; if both leaves are active, the sign should be on the wall to the right of the right leaf. : N_A (Rating: 0)

If there are signs that provide direction to or information about interior spaces:

41. Do text characters contrast with their background? : N_A (Rating: 0)

42. Is the sign mounted so that characters are at least 1015mm above the floor? : N_A (Rating: 0)

Interior doors

43. Is the door opening width at least 815mm clear, between the face of the door and the stop, when the door is open 90°? : Yes_ - _Meets_Standard (Rating: 1)

**Measurement
(mm) : 810**

Comments/Description : accessible door opened is 810mm from grab bar handle to door opening

44. If there is a front approach to the pull side of the door, is there at least 455mm of maneuvering clearance beyond the latch side plus at least 1525mm clear depth? : N_A (Rating: 0)

Comments/Description : accessible push button door openers on the wall

45. On both sides of the door, is the floor surface of the maneuvering clearance level (no steeper than 1°)? : Yes (Rating: 1)

**Measurement
(angle °) : 1**

46. If the threshold is vertical is it no more than 6mm high?

Or : N_A (Rating: 0)

47. If the threshold is beveled, is it no more than 19mm high? : Yes (Rating: 1)

**Measurement
(mm) : 7**

48. Is the door equipped with hardware that is operable with one hand and does not require tight grasping, pinching or twisting of the wrist? : Yes (Rating: 1)

Comments/Description : accessible push button door openers on the wall

49. Are the operable parts of the hardware no less than 865mm and no greater than 1220mm above the floor? : Yes (Rating: 1)

**Measurement
(mm) : 940**

Comments/Description : center 940mm rectangular push button 1140mm grab bar type push handle center 1040mm on curved D handle

50. Can the door be opened easily, maximum 2.3kg of force?

Note: You can use a pressure gauge or fish scale to measure force. : No (Rating: 0)

**Measurement
(kg) : 6**

Comments/Description : 6kg to get door started

51. If the door has a closer, does it take at least 5 seconds to close from open position of 90° to a position of 12° from the latch? : No (Rating: 0)

**Measurement
(seconds) : 3**

Recommendations : ADJUST HINGES SO THAT CLOSING TIME IS INCREASED TO MEET CODE

Improvement Priority : High

Estimated Cost : Low

Rooms & spaces

52. Are aisles and pathways to goods and services, and to one of each type of sales and service counters, at least 915mm wide? : N_A (Rating: 0)

Comments/Description : there are no designated aisles

53. Are floor surfaces stable, firm and slip resistant? : Yes (Rating: 1)

Controls - light switches, security & intercom systems, emergency/alarm boxes, etc.

54. Is there a clear floor space at least 760mm wide by at least 1220mm long for a forward or parallel approach? : Yes - Meets Standard (Rating: 1)

**Measurement
(mm) w x l : 1100 x 1220**

Comments/Description : 1100W X 1220L

55. Are the operable parts no higher than 1220mm above the floor? : No (Rating: 0)

**Measurement
(mm) : 1310**

Comments/Description : light switch is too high

56. Can the control be operated with one hand and without tight grasping, pinching, or twisting of the wrist? : Yes (Rating: 1)

57. Do fire alarm systems have both flashing lights and audible signals? : N_A (Rating: 0)

Comments/Description : can't see any fire alarms

Sales & Service Counters

Is there a portion of at least one of each type of counter that is:

58. No higher than 915mm above the floor? : Yes (Rating: 1)

**Measurement
(mm) : 765**

59. At least 915mm long? : Yes - Exceeds Standard

**Measurement
(mm) : 1235**

60. Is there a clear floor space at least 760mm wide by at least 1220mm long for a forward approach?

Or : Yes - Exceeds Standard

**Measurement
(mm) w x l : 1200 x 1800**

**61. Is there a clear floor space at least 1220mm wide by at least 760mm long for a parallel approach? :
Yes - Exceeds Standard**

**Measurement
(mm) w x l : 2160 x 1800**

Seating: At dining surfaces (restaurants, cafeterias, bars, etc.)

62. Are at least 5%, but no fewer than 1, of seating and standing spaces accessible for people who use wheelchairs? : N_A (Rating: 0)

63. Is there a route at least 915mm wide to accessible seating? : N_A (Rating: 0)

64. At the accessible space(s), is the top of the accessible surface no less than 710mm and no greater than 865mm above the floor? : N_A (Rating: 0)

65. Does it extend no less than 430mm and no greater than 635mm under the surface? : N_A (Rating: 0)

66. Is there knee space at least 685mm high and at least 760mm wide? : Yes (Rating: 1)

Measurement**(mm) h x w : 710 x 755****Comments/Description : 710H x 755W****Water Fountains****1. Is there a water fountain? : Yes (Rating: 1)****Comments/Description : VERY ACCESSIBLE AND EASY TO USE****2. Does it have a lever or push bar control on the front or both sides? : Yes (Rating: 1)****Comments/Description : PUSH BARS ON FRONT AND ON BOTH SIDES****3. Is the spout opening height between 750mm - 915mm above the ground? : Yes (Rating: 1)****Measurement****(mm) : 840****4. Is there a minimum width of 800mm clearance space directly in front of the water fountain? : Yes -
Exceeds Standard****Measurement****(mm) : 1170****5. Is there a clear, level accessible route to the water fountain? : Yes (Rating: 1)****Trash & Recycling Receptacles****6. Are there any trash &/or recycling receptacles? : Yes (Rating: 1)****7. Is the approach to the receptacle level, with no-step? : Yes (Rating: 1)****8. If there are operable parts, is their height between 380mm - 1220mm above the ground? : Yes (Rating:
1)****Measurement****(mm) : 570****9. If there are operable parts, can they be operated using one hand, without tightly grasping, pinching, or
twisting the wrist and with no more than 2.3kg of force? : Yes (Rating: 1)****Comments/Description : 0.5 kg force****10. Is there a clear, level accessible route to the trash/recycling receptacle? : Yes (Rating: 1)****Public Telephones****11. Are there telephones available to the public? : Yes (Rating: 1)****Comments/Description : YES 2 ACCESSIBLE TELEPHONES LOCATED ON OUTSIDE OF BUILDING.
No measurements**

**1. Are any public washrooms located at goods & services? : Yes -
_WASHROOMS_checklist_must_also_be_completed**

Additional comments regarding assessment: : ON THE WHOLE, MOUNT ROBSON VISITOR CENTRE IS VERY ACCESSIBLE. ACCESS ROUTE IS WIDE AND FIRM WITH A GENTLE SLOPE. ACCESS TO BUILDING IS FACILITATED BY WIDE DOORS WITH PUSH BUTTON OPENERS. SERVICE COUNTERS ARE READILY ACCESSIBLE. THE LARGE OBSERVATION DECK IS ACCESSIBLE VIA A WIDE OUTDOOR WOODEN WALKWAY WHICH ADJOINS THE ACCESS ROUTE AND ALSO VIA AN INTERIOR DOOR. ACCESS TO BASEMENT (WHICH FEATURES NATURE INTERPRETIVE DISPLAYS AND SMALL THEATRE FOR VIEWING VIDEOS) IS LESS ACCESSIBLE. HOWEVER, STAFF CAN ACCOMMODATE PERSONS IN WHEELCHAIRS BY ASSISTING THEM TO ENTER THROUGH THE OUTSIDE BASEMENT DOOR. IMPROVING THIS ASPECT OF THE VISITOR CENTRE SHOULD BE A PRIORITY.



Description of Photo 1 : Good signage directing you to the accessible washrooms.



Description of Photo 2 : Sign you see when you enter the visitor center showing you where the accessible washroom is.



Description of Photo 3 : nice accessible concrete pathway to the visitor center.