

Mt Robson Visitors Centre ▼

Information

Date of Audit: 2016-10-02

Park Name: Twin Falls Rec Site

Key Features: View_Point,Camping,Picnic_Site,Trails

Location: Bulkley-Nechako, Smithers, Northern BC - Recreation : Site (Heritage Discovery Circle Route)

Description: Twin Falls Recreation site provides camping and day use activities. There are 3 campsites and two outhouse washrooms. One is accessible, and located centrally between the camping and day use parking areas. The campsites are large with good clearance around non-accessible style picnic table and campfire (also has higher grille - 485 mm) The site provides a day use parking area and a trail to the Falls. Along the trail are three separate picnic areas (each with its own non-accessible style table), and a viewing platform. The parking area has no defined spaces or designated parking spots. Trail to base of Falls - approx 530 metres from parking lot. The first 200 metres of the trail leading to the first picnic site/viewing area is accessible for some wheelchairs (requires good upper body strength) The site provides a viewing platform approx 400 metres along the trail. Access to platform is a flight of 10 steps. The trail beyond the platform becomes more narrow and has rocks; not accessible for wheelchairs and those with certain mobility issues. The trail becomes increasingly steeper closer to the falls (more than 5 degrees, up to 10 degrees and more at the end). To Note: at the time of this audit there was no visible sign to identify the site as Twin Falls Recreation Site.

Parking

Access Routes

Trails

Washrooms

Date of Audit : 2016-10-02

Auditors Names : Barbara

Weather condition during audit : Cloudy

Washroom # : 1

Description of washroom location : Centrally located between campsites and the day use parking area

Type of Washroom : Out-house



1. If washrooms are available to the public, is at least one washroom designated as accessible? (Either one for each sex, or one unisex.) : Yes (Rating: 1)

Comments/Description : one accessible outhouse washroom (M/F)

Directional signage

2. Are there signs at inaccessible washrooms that give directions to accessible washrooms? : No (Rating: 0)

3. Is there an accessible route to the accessible washroom? : Yes (Rating: 1)

4. If not all washrooms are accessible, is there a sign at the accessible washroom with the International Symbol of Accessibility? : Yes (Rating: 1)

5. Do text characters contrast with their backgrounds? : Yes (Rating: 1)

Comments/Description : white on brown; symbols only, no text

6. Are text characters raised? : No (Rating: 0)

7. Is there Braille? : No (Rating: 0)

8. Is the sign mounted on the wall, on latch side of the door?

Note: Signs are permitted on the push side of doors with closers and without hold-open devices. : No (Rating: 0)

Comments/Description : sign mounted on door

9. So the baseline of the lowest character is at least 1220mm above the floor and the baseline of the highest character is no more than 1525mm above the floor?

Note: If the sign is at double doors with one active leaf, the sign should be on the inactive leaf; if both leaves are active, the sign should be on the wall to the right of the right leaf. : Yes (Rating: 1)

Measurement (mm) : 1050

Comments/Description : measurement to symbols on door; no text

Interior doors

10. Is the door opening width at least 815mm clear, between the face of the door and the stop, when the door is open 90°? : N_A (Rating: 0)

11. If there is a front approach to the pull side of the door, is there at least 455mm of maneuvering clearance beyond the latch side plus at least 1525mm clear depth? : N_A (Rating: 0)

12. On both sides of the door, is the floor surface of the maneuvering clearance level (no steeper than 1°)? : N_A (Rating: 0)

13. If the threshold is vertical is it no more than 6mm high?

Or : N_A (Rating: 0)

14. If the threshold is beveled, is it no more than 19mm high? : N_A (Rating: 0)

15. Is the door equipped with hardware that is operable with one hand and does not require tight grasping, pinching or twisting of the wrist? : N_A (Rating: 0)

17. Can the door be opened easily, maximum 2.3kg of force?

Note: You can use a pressure gauge or fish scale to measure force. : N_A (Rating: 0)

18. If the door has a closer, does it take at least 5 seconds to close from open position of 90° to a position of

12° from the latch? : N_A (Rating: 0)

19. If there are two doors in a series, e.g. vestibule, is the distance between the doors at least 1220mm plus the width of the doors when swinging into the space? : N_A (Rating: 0)

20. If there is a privacy wall and the door swings out, is there at least 610mm of maneuvering clearance beyond the door latch side and 1065mm to the privacy wall? : N_A (Rating: 0)

21. If there is a privacy wall and the door swings in, is there at least 610mm of maneuvering clearance beyond the door latch side and at least 1220mm to the privacy wall if there is no door closer or at least 1370mm if there is a door closer? : N_A (Rating: 0)

22. In a unisex washroom if the door swings in and over a clear floor space at an accessible fixture, is there a clear floor space at least 760mm x 1220mm beyond the swing of the door? : N_A (Rating: 0)

Toilet stall

23. Is there an individual accessible toilet stall? : Yes (Rating: 1)

24. Is the stall door opening width at least 815mm clear, between the face of the door and the stop, when the door is open 90°? : Yes (Rating: 1)

**Measurement
(mm) : 840**

25. If there is a front approach to the pull side of the stall door, is there at least 455mm of maneuvering clearance beyond the latch side plus 1525mm clear depth? : Yes (Rating: 1)

**Clearance
(mm) : 520**

**Depth
(mm) : 2000**

Comments/Description : more than 2m clear depth

26. Is the door self-closing? : Yes (Rating: 1)

Comments/Description : 5 seconds to close door

27. Are there door pulls on both sides of the door that are operable with one hand and do not require tight grasping pinching or twisting of the wrist?* : No (Rating: 0)

Comments/Description : vertical door pull on outside of pull door; cannot fit fist/wrist inside

28. Is the lock operable with one hand and without tight grasping, pinching or twisting of the wrist? : Yes (Rating: 1)

Comments/Description : flip latch style

29. Are the operable parts of the door hardware mounted no less than 865mm and no greater than 1220mm above the floor? : Yes (Rating: 1)

Measurement

(mm) : 940

Comments/Description : Door pull 940mm Lock - 1045 mm

30. Is the stall at least 1525mm wide? : Yes (Rating: 1)

Measurement

(mm) : 1770

31. If the toilet is wall hung, is the stall at least 1420mm deep?

Or : N_A (Rating: 0)

32. If the toilet is floor mounted, is the stall at least 1500mm deep? : Yes (Rating: 1)

Measurement

(mm) : 2130

If the door swings in, is the stall area beyond the swing of the door:

33. A minimum of 1525mm wide x 1420mm deep for wall hung toilet?

Or : N_A (Rating: 0)

34. A minimum of 1525mm wide x 1500mm deep for floor mounted toilet? : N_A (Rating: 0)

Toilet

35. Is the centerline of the toilet no less than 405mm and no greater than 455mm from the side wall or partition? : Yes (Rating: 1)

Measurement

(mm) : 430

36. Is clearance provided around the toilet measuring at least 1525mm from the side wall and at least 1420mm from the rear wall? : Yes (Rating: 1)

From side wall

(mm) : 1770

From rear wall

(mm) : 2130

37. Is the height of the toilet no less than 430mm and no greater than 485mm above the floor measured to the top of the seat? : Yes (Rating: 1)

Measurement

(mm) : 470

Grab bars

38. Is there a grab bar at least 1065mm long on the side wall? : No (Rating: 0)

Measurement

(mm) : 460

39. Is it located no more than 305mm from the rear wall? : No (Rating: 0)

Measurement

(mm) : 150

40. Does it extend at least 1370mm from the rear wall? : No (Rating: 0)

Measurement

(mm) : 610

41. Is it mounted no less than 840mm and no greater than 915mm above the floor to the top of the gripping surface? : No (Rating: 0)

Measurement

(mm) : 760

42. Is there at least 305mm clearance between the grab bar and protruding objects above? : N_A (Rating: 0)

Comments/Description : no objects above

43. Is there at least 38mm clearance between the grab bar and projecting objects below? : N_A (Rating: 0)

Comments/Description : no objects below

44. Is the space between the wall and the grab bar 38mm : Yes (Rating: 1)

Measurement

(mm) : 40

45. Is there a grab bar at least 915mm long on the rear wall? : No (Rating: 0)

Measurement

(mm) : 460

46. Does the grab bar extend at least 305mm from the centerline of the toilet on one side (side wall)? : No (Rating: 0)

Measurement

(mm) : 230

47. Does the grab bar extend at least 610mm on the other (open) side? : No (Rating: 0)

Measurement

(mm) : 230

48. Is the grab bar mounted no less than 840mm and no greater than 915mm above the floor to the top of the gripping surface? : No (Rating: 0)

Measurement

(mm) : 760

49. Are there at least 305mm clearance between the grab bar and protruding objects above? : N_A
(Rating: 0)

Comments/Description : no objects above

50. Are there at least 38mm clearance between the grab bar and projecting objects below? : N_A (Rating: 0)

Comments/Description : no objects below

51. Is the space between the wall and the grab bar 38mm inches? : Yes (Rating: 1)

Measurement
(mm) : 40

Toilet flush controls

52. If the flush control is hand operated, is the operable part located no higher than 1220mm above the floor? : N_A (Rating: 0)

53. If the flush control is hand operated, can it be operated with one hand and without tight grasping, pinching, or twisting of the wrist? : N_A (Rating: 0)

54. Is the force required to activate the flush control no greater than 2.3kg? : N_A (Rating: 0)

55. Is the flush control on the open side of the toilet? : N_A (Rating: 0)

Toilet paper dispenser

56. Is the toilet paper dispenser located no less than 180mm and no greater than 230mm from the front of the toilet to the center line of the dispenser? : No (Rating: 0)

Measurement
(mm) : 380

57. Is the outlet of the dispenser: Located no less than 380mm and no greater than 1220mm above the floor? : Yes (Rating: 1)

Measurement
(mm) : 760

58. Is the dispenser located behind grab bars? : No (Rating: 0)

59. Does the dispenser allow continuous paper flow? : Yes (Rating: 1)

Sink

60. Does at least one sink have a clear floor space for a forward approach at least 760mm wide and 1220mm long? : N_A (Rating: 0)

61. Do no less than 430mm and no greater than 635mm of the clear floor space extend under the sink so that a person using a wheelchair can get close enough to reach the faucet? : N_A (Rating: 0)

62. Is the front of the sink or counter surface, whichever is higher, no more than 865mm above the floor? :

N_A (Rating: 0)

63. Is there at least 685mm height clearance from the floor to the bottom of the sink that extends at least 205mm deep under the sink for knee clearance? : N_A (Rating: 0)

64. Is there toe clearance at least 230mm high?

Note: Space extending greater than 150mm beyond the available toe clearance at 230mm above the floor is not considered toe clearance. : N_A (Rating: 0)

65. Are pipes below the sink insulated or otherwise configured to protect against contact? : N_A (Rating: 0)

66. Can the faucet be operated without tight grasping, pinching, or twisting of the wrist? : N_A (Rating: 0)

67. Is the force required to activate the faucet no greater than 2.3 kg? : N_A (Rating: 0)

Washroom fixtures

68. Is there a clear path to at least one of each type of fixture, e.g. sink, hand dryer, garbage bin etc., that is at least 915mm wide? : N_A (Rating: 0)

69. Is there clear floor space available for a person in a wheelchair to turn around, i.e. a circle at least 1525mm in diameter or a T-shaped space within a 1525mm square? : N_A (Rating: 0)

Mirror

70. If the mirror is over a sink or countertop, is the bottom edge of the reflecting surface no higher than 1015mm above the floor?

Or : N_A (Rating: 0)

71. If the mirror is not over the sink or countertop, is the bottom edge of the reflecting surface no higher than 890mm above the floor? : N_A (Rating: 0)

Coat hook

72. If there is a coat hook, is it no less than 380mm and no greater than 1220mm above the floor?* : N_A (Rating: 0)

Comments/Description : n/a no coat hook

Soap dispenser

Are the operable parts of the soap dispenser within one of the following reach ranges:

73. Above sinks or counters no less than 510mm and no greater than 635mm deep: no higher than 1120mm above the floor?

Or : N_A (Rating: 0)

74. Above sinks less than 510mm deep: no higher than 1220mm above the floor?

Or : N_A (Rating: 0)

75. Not over an obstruction: no higher than 1220mm above the floor? : N_A (Rating: 0)

Hand dryer/Towel dispenser

Are the operable parts of the hand dryer or towel dispenser within one of the following reach ranges:

76. Above sinks or counters no less than 510mm and no greater than 635mm deep: no higher than 1120mm above the floor?

Or : N_A (Rating: 0)

77. Above sinks less than 510mm deep: no higher than 1220mm above the floor?

Or : N_A (Rating: 0)

79. Can the operable parts of the hand dryer or towel dispenser be operated without tight grasping, pinching or twisting of the wrist? : N_A (Rating: 0)

80. Is the force required to activate the hand dryer or towel dispenser no greater than 2.3kg? : N_A (Rating: 0)

Controls - light switches

81. Is there a clear floor space at least 760mm wide by at least 1220mm long for a forward or parallel approach? : N_A (Rating: 0)

82. Are the operable parts no higher than 1220mm above the floor? : N_A (Rating: 0)

83. Can the control be operated with one hand and without tight grasping, pinching, or twisting of the wrist? : N_A (Rating: 0)

**1. Has the route to the washroom been evaluated? : No -
_ACCESS_ROUTE_checklist_must_also_be_completed**

Additional comments regarding assessment: : Outhouse access route: no checklist completed. Route from campsites to washroom is along campsite road (dirt road, good surface). Washroom located approximately 100 metres from campsite area; running slope on road ranges from 1 - 4 degrees, cross slope 1 - 2 degrees. Width of road is approx 3 metres.

Camping

Water Access

Goods and Services